





中国认可
国际互认
检测
TESTING
CNAS L5313

Test Report issued under the responsibility of:




TEST REPORT EN 50549-1:2019 Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks Part 1: Connection to a LV distribution network - Generating plants up to and including Type B	
Report	
Report Number	6098561.50
Date of issue	2021-04-02
Total number of pages	232
Testing Laboratory	DEKRA Testing and Certification (Suzhou) Co., Ltd.
Address	No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China
Applicant's name	Soltaro Pty. Ltd. ATF Soltaro Unit Trust
Address	Level 9/440 Collins Street, Melbourne VIC, 3000, Australia
Test specification:	
Standard	EN 50549-1:2019
Test procedure	Type test
Non-standard test method	N/A
Test Report Form No.	EN 50549-1_V1.0
Test Report Form(s) Originator	DEKRA Testing and Certification (Suzhou) Co., Ltd.
Master TRF	Dated 2019-05-31
Test item description	Hyper inverter
Trade Mark	SOLTARO
Manufacturer	Soltaro Pty. Ltd. ATF Soltaro Unit Trust Level 9/440 Collins Street, Melbourne VIC, 3000, Australia
Model/Type reference	AIO2-INS-3000, AIO2-INS-3680, AIO2-INS-4600, AIO2-INS-5000


Ratings	<p>Operating temperature range: - 10°C to + 60°C Protective class: I Ingress protection rating: IP65 Power factor range (adjustable): 0.8 leading...0.8 lagging</p> <p>AIO2-INS-3000: PV input: Max. 600 Vdc, MPPT voltage range: 125-500 Vdc, max 12 A, Isc PV: 15 A Battery: Type: Lithium battery, voltage range: 40-60 Vdc, rated voltage: 48 Vdc, max charge/discharge current: 60 A Output: 230 Vac, 50 Hz, 3000 VA, max 13 A</p> <p>AIO2-INS-3680: PV input: Max. 600 Vdc, MPPT voltage range: 125-500 Vdc, max 2x12 A, Isc PV: 2x15 A Battery: Type: Lithium battery, voltage range: 40-60 Vdc, rated voltage: 48 Vdc, max charge/discharge current: 80 A Output: 230 Vac, 50 Hz, 3680 VA, max 16 A</p> <p>AIO2-INS-4600: PV input: Max. 600 Vdc, MPPT voltage range: 125-500 Vdc, max 2x12 A, Isc PV: 2x15 A Battery: Type: Lithium battery, voltage range: 40-60 Vdc, rated voltage: 48 Vdc, max charge/discharge current: 100 A Output: 230 Vac, 50 Hz, 4600 VA, max 20 A</p> <p>AIO2-INS-5000: PV input: Max. 600 Vdc, MPPT voltage range: 125-500 Vdc, max 2x12 A, Isc PV: 2x15 A Battery: Type: Lithium battery, voltage range: 40-60 Vdc, rated voltage: 48 Vdc, max charge/discharge current: 100 A Output: 230 Vac, 50 Hz, 5000 VA, max 21.7 A</p>
---------------	--

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	Testing Laboratory:	DEKRA Testing and Certification (Suzhou) Co., Ltd.
Testing location/ address:		No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China
<input type="checkbox"/>	Associated Testing Laboratory:	
Testing location/ address		
Tested by (name, function, signature):		Hua Yu 
Approved by (name, function, signature):		Jason Guo 
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address		
Tested by (name, function, signature)		
Approved by (name, function, signature)		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address		

Tested by (name + signature).....:			
Witnessed by (name, function, signature).....:			
Approved by (name, function, signature).....:			
<input type="checkbox"/>	Testing procedure: CTF Stage 3:		
<input type="checkbox"/>	Testing procedure: CTF Stage 4:		
Testing location/ address			
Tested by (name, function, signature).....:			
Witnessed by (name, function, signature).....:			
Approved by (name, function, signature).....:			
Supervised by (name, function, signature).....:			

Rating label:

SOLTARO
 Hybrid Inverter
AIO2-INS-3000




Max. PV Panel Power	4500W
Max. PV Voltage	600V d.c.
MPPT Voltage Range	125~500V d.c.
Max. PV Current	12A d.c.
PV Isc	15A d.c.
PV Inverter Topology	Non-isolated
Rated AC Voltage	230V a.c.
Rated AC Frequency	50Hz
Rated AC Power	3000VA
Max. Output Current	13.0A a.c.
Power Factor Range	-0.8~+0.8
Battery Type	Lithium
Rated Battery Voltage	48V d.c.
Battery Voltage Range	40~60V d.c.
Max. Charge Current	60A d.c.
Max. Discharge Current	60A d.c.
Galvanic Isolation for Bat.	Yes
AC Overvoltage-Category	III
DC Overvoltage-Category	II
IP Protection	IP65
Protective Class	Class I


Grid Regulations:
 AS/NZS4777.2; G98; G100; EN50549;
 C10/11; UTE C 15-712-1; NRS 097-2-1;


Serial Number

Soltaro Pty. Ltd.
 Level 9/440 Collins Street, Melbourne
 VIC, 3000, Australia
 www.soltaro.com

MADE IN CHINA
L_HYPER-S-3000_SOLTARO_02

DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8


SOLTARO
 Hybrid Inverter
AIO2-INS-3680




Max. PV Panel Power	5500W
Max. PV Voltage	600V d.c.
MPPT Voltage Range	125~500V d.c.
Max. PV Current	12A / 12A d.c.
PV Isc	15A / 15A d.c.
PV Inverter Topology	Non-isolated
Rated AC Voltage	230V a.c.
Rated AC Frequency	50Hz
Rated AC Power	3680VA
Max. Output Current	16.0A a.c.
Power Factor Range	-0.8~+0.8
Battery Type	Lithium
Rated Battery Voltage	48V d.c.
Battery Voltage Range	40~60V d.c.
Max. Charge Current	80A d.c.
Max. Discharge Current	80A d.c.
Galvanic Isolation for Bat.	Yes
AC Overvoltage-Category	III
DC Overvoltage-Category	II
IP Protection	IP65
Protective Class	Class I


Grid Regulations:
 AS/NZS4777.2; G98; G100; EN50549;
 C10/11; UTE C 15-712-1; NRS 097-2-1;


Serial Number

Soltaro Pty. Ltd.
 Level 9/440 Collins Street, Melbourne
 VIC, 3000, Australia
 www.soltaro.com

MADE IN CHINA
L_HYPER-S-3680_SOLTARO_02

DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8


SOLTARO
 Hybrid Inverter
 AIO2-INS-4600




Max. PV Panel Power	6900W
Max. PV Voltage	600V d.c.
MPPT Voltage Range	125~500V d.c.
Max. PV Current	12A / 12A d.c.
PV Isc	15A / 15A d.c.
PV Inverter Topology	Non-isolated
Rated AC Voltage	230V a.c.
Rated AC Frequency	50Hz
Rated AC Power	4600VA
Max. Output Current	20.0A a.c.
Power Factor Range	-0.8~+0.8
Battery Type	Lithium
Rated Battery Voltage	48V d.c.
Battery Voltage Range	40~60V d.c.
Max. Charge Current	100A d.c.
Max. Discharge Current	100A d.c.
Galvanic Isolation for Bat.	Yes
AC Overvoltage-Category	III
DC Overvoltage-Category	II
IP Protection	IP65
Protective Class	Class I


Grid Regulations:
 AS/NZS4777.2; G99; G100; EN50549;
 C10/11; UTE C 15-712-1; NRS 097-2-1;


Serial Number

Soltaro Pty. Ltd.
 Level 9/440 Collins Street, Melbourne
 VIC, 3000, Australia
 www.soltaro.com

MADE IN CHINA
L_HYPER-S-5000_SOLTARO_05

DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8


SOLTARO
 Hybrid Inverter
 AIO2-INS-5000




Max. PV Panel Power	7500W
Max. PV Voltage	600V d.c.
MPPT Voltage Range	125~500V d.c.
Max. PV Current	12A / 12A d.c.
PV Isc	15A / 15A d.c.
PV Inverter Topology	Non-isolated
Rated AC Voltage	230V a.c.
Rated AC Frequency	50Hz
Rated AC Power	5000VA
Max. Output Current	21.7A a.c.
Power Factor Range	-0.8~+0.8
Battery Type	Lithium
Rated Battery Voltage	48V d.c.
Battery Voltage Range	40~60V d.c.
Max. Charge Current	100A d.c.
Max. Discharge Current	100A d.c.
Galvanic Isolation for Bat.	Yes
AC Overvoltage-Category	III
DC Overvoltage-Category	II
IP Protection	IP65
Protective Class	Class I

Grid Regulations:
 AS/NZS4777.2; G99; G100; EN50549;
 C10/11; UTE C 15-712-1; NRS 097-2-1;

Serial Number

Soltaro Pty. Ltd.
 Level 9/440 Collins Street, Melbourne
 VIC, 3000, Australia
 www.soltaro.com

MADE IN CHINA
L_HYPER-S-5000_SOLTARO_05

DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8


Remark: According to customer's and market requirement, these models were evaluated under the grid frequency of 50 Hz.


Test item particulars:			
Equipment mobility	: movable <u>fixed</u>	hand-held transportable	stationary for building-in
Connection to the mains	: <u>pluggable equipment</u> permanent connection		direct plug-in for building-in
Environmental category	: <u>outdoor</u>	indoor unconditional	indoor conditional
Over voltage category Mains	: OVC I	OVC II	<u>OVC III</u> OVC IV
Over voltage category PV	: OVC I	<u>OVC II</u>	OVC III OVC IV
Mains supply tolerance (%).....	: ±10%		
Tested for power systems.....	: TN		
IT testing, phase-phase voltage (V).....	: N/A		
Class of equipment.....	: <u>Class I</u> Not classified	Class II	Class III
Mass of equipment (kg)	: 34 kg for AIO2-INS-4600, AIO2-INS-5000 29 kg for AIO2-INS-3680 27 kg for AIO2-INS-3000		
Pollution degree	: Outside PD3; Inside PD2		
IP protection class.....	: IP65		
Possible test case verdicts:			
- test case does not apply to the test object	: N/A		
- test object does meet the requirement.....	: P (Pass)		
- test object does not meet the requirement	: F (Fail)		
- this clause is information reference for installation ...	: Info.		
Testing:			
Date of receipt of test item	: 2021-03-02 (samples provided by applicant)		
Date (s) of performance of tests	: 2021-03-05 to 2021-03-25		
General remarks:			
"(see appended table)" refers to a table appended to the report.			
"(see Appendix #)" refers to additional information appended to the report.			
The test results presented in this report relate only to the object tested.			
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.			
The measurement result is considered in conformance with the requirement if it is within the prescribed limit, It is not necessary to account the uncertainty associated with the measurement result.			
The information provided by the customer in this report may affect the validity of the results, the test lab is not responsible for it.			
This report is only for reference and is not used for legal proof function in China market.			
Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.			
Name and address of factory (ies):			
Hangzhou livoltek power Co., Ltd.			
1418-35 Moganshan Road, Shangcheng Industrial Zone, Hangzhou, P.R. China			

General product information:

The products are single phase multiple functional hybrid inverter converts DC power from the photovoltaic (PV) arrays as well as batteries to AC power. The battery port is able to be charged by the energy from either PV port or AC grid port. The PCE does not provide galvanic separation between the PV input and AC output circuit. The battery circuit is galvanic isolation from the PV input or AC output circuit. The hybrid inverter also can operate under standalone mode.

The unit is providing EMC filtering at the input and output towards mains. The output was switched off redundant by the high power switching bridge and two relays in series. This assures that the opening of the output circuit will also operate in case of one error.

AIO2-INS Series Block Diagram:

**Description of the electrical circuit and functional safety (redundancy control):**

The internal control is redundant built. It consists out of two Microcontrollers (master DSP U1, slave DSP U21 and ARM U34), the master DSP can control the relays, sample the PV voltage, current and BUS voltage, measures grid voltage, frequency, AC current with injected DC, insulation resistance to ground and residual current. The slave CPU is redundant controller, it is using for control the relay, sample grid voltage, frequency and current. Both microcontrollers communicate with each other.

The voltage and frequency measurement were performed with resistors in serial that were connected directly to line and neutral. Both controllers get these signals and analyze the data.

The unit provides two relays in series in each line and neutral. The relays are test before each start-up. When single-fault applied to one relay, an error code will appear on display panel, another redundant relay provides basic insulation maintained between the PV array and the mains.

The passive LoM protection principles RoCoF and active methods reactive power injection was employed in hybrid inverter.

The AIO2-INS series are single phase storage inverters suitable for both on-grid and off-grid operation that use conjunction with Lithium batteries pack, PV panels and a smart meter.

Model difference:

The models AIO2-INS-3000, AIO2-INS-3680, AIO2-INS-4600, AIO2-INS-5000 are similar with each other in hardware except bus capacitor number, AC choke rating, IGBT number and electrical ratings differences. AIO2-INS-3000 has single channel MPP tracker function PV input while AIO2-INS-3680, AIO2-INS-4600 and AIO2-INS-5000 have dual channel MPP tracker function PV inputs.

The product was tested on:

Unless otherwise specified, all tests were performed on the representative model of AIO2-INS-5000 and applicable for other models since they are similar in hardware and just power derating by software.

Hardware version: 2.0

Software version: 2.0

The product operating temperature range: -10°C to +60°C.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4	Technical requirements		P
4.1	General		P
	This clause defines the requirements on generating plants to be operated in parallel with the distribution network. Where settings or a range of configurability is provided and respecting the legal framework the configurations and settings may be provided by the DSO. Where no settings are provided by the DSO, the specified default settings shall be used; if no default settings are provided, the producer shall propose settings and inform the DSO.		P
	The requirements of Clause 4 apply during normal operation of the generating units and do not apply in case of maintenance or units out of operation. The provisions apply to EESS in generation mode. In charging mode EESS should have the same characteristics, unless stated otherwise in the clauses of this European Standard.		P
	The applicability is independent of the duration the generating unit operates in parallel with the distribution network. It is the responsibility of the DSO to relax, if deemed appropriate, the requirements for an individual generating unit or plant whose operation in parallel only lasts for a short time (temporary operation in parallel). The relaxed requirements shall be agreed between the DSO and the producer, along with the maximum allowable duration of the temporary operation in parallel.		P
	If different requirements on the generating plant interfere with each other, the following hierarchy in descending order shall be applied:		P
	<ol style="list-style-type: none"> 1. Generating unit protection, including regarding the prime mover; 2. interface protection (see 4.9) and protection against faults within the generating plant; 3. voltage support during faults and voltage steps (see 4.7.4); 4. the lower value of: remote control command on active power limitation for distribution grid security (see 4.11) and local response to overfrequency (see 4.6.1); 5. local response to underfrequency if applicable (see 4.6.2); 6. reactive power (see 4.7.2) and active power (P(U) see 4.7.2) controls; 7. other control commands on active power set point for e.g. market, economic reasons, selfconsumption optimization. 		P
	The system shall be so designed that under foreseeable conditions no self-protection trips prior to the fulfilment of the requirements of this European Standard and all settings provided by the DSO or responsible party.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	For cogeneration plants embedded in industrial sites, active power requirements shall be agreed between the responsible party and the producer. In such a case the priority list is adapted accordingly.		P
	Besides the requirements of Clause 4, additional requirements apply for connecting a generating plant to the distribution network, e.g. assessment of the point of connection. However, this is excluded from the scope of this European Standard but some guidance is provided in the informative Annex A.		P
4.2	Connection scheme		Info.
	The connection scheme of the generating plant shall be in compliance with the requirements of the DSO. Different requirements may be subject to agreement between the producer and the DSO depending on the power system needs.	It's depended on installer.	Info.
	Inter alia, the generating plant shall ensure the following:		Info.
	<ul style="list-style-type: none"> synchronization, operation and disconnection under normal network operating conditions, i.e. in the absence of faults or malfunctions; faults and malfunctions within the generating plant shall not impair the normal functioning of the distribution network; coordinated operation of the interface switch with the generating unit switch, the main switch and switches in the distribution network, for faults or malfunctions within the generating plant or the DSO network during operation in parallel with the distribution network; and disconnection of the generating plant from the distribution network by tripping the interface switch according to 4.9. 		Info.
	In order to satisfy the above functions, coordinated but independent switches and protection equipment may be applied in the generating plant, as shown in the example in Figure 2.	It's depended on installer.	Info.
	<p>Figure 2 — Example of an generating plant connected to a distribution network (schematic view of switches)</p>		

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.3	Choice of switchgear		P
4.3.1	General		P
	Switches shall be chosen based on the characteristics of the power system in which they are intended to be installed. For this purpose, the short circuit current at the installation point shall be assessed, taking into account, inter alia, the short circuit current contribution of the generating plant.		P
4.3.2	Interface switch		P
	Switches shall be power relays, contactors or mechanical circuit breakers each having a breaking and making capacity corresponding to the rated current of the generating plant and corresponding to the short circuit contribution of the generating plant.	Two power relays in series installed each phase on the mains side of the unit to separate it from the grid.	P
	The short-time withstand current of the switching devices shall be coordinated with rated short circuit power at the point of connection.		P
	In case of loss of auxiliary supply power to the switchgear, a secure disconnection of the switch is required immediately.		P
	Where means of isolation (according to HD 60364-5-551) is not required to be accessible to the DSO at all times, automatic disconnection with single fault tolerance according to 4.13 shall be provided.		P
	NOTE 1 For PV-inverters, further requirements are stated in EN 62109-1 and EN 62109-2 with respect to the interface switch.	See separate EN 62109-1 test report no. 6091935.50A and EN 62109-2 test report no. 6091935.50B issued by DEKRA for reference.	P
	The function of the interface switch might be combined with either the main switch or the generating unit switch in a single switching device. In case of a combination, the single switching device shall be compliant to the requirements of both, the interface switch and the combined main switch or generating unit switch. As a consequence, at least two switches in series shall be present between any generating unit and the POC.		P
	NOTE 2 This does not refer to the number of series-connected switches in order to ensure single fault tolerance as required in 4.13 but to the number of different switching devices itself.		P
4.4	Normal operating range		P
4.4.1	General		P
	Generating plants when generating power shall have the capability to operate in the operating ranges specified below regardless of the topology and the settings of the interface protection.		P

EN 50549-1																								
Clause	Requirement - Test	Result - Remark	Verdict																					
4.4.2	Operating frequency range		P																					
	<p>The generating plant shall be capable of operating continuously when the frequency at the point of connection stays within the range of 49 Hz to 51 Hz.</p> <p>In the frequency range from 47 Hz to 52 Hz the generating plant should be capable of operating until the interface protection trips. Therefore, the generating plant shall at least be capable of operating in the frequency ranges, for the duration and for the minimum requirement as indicated in Table 1.</p> <p>Table 1 – Minimum time periods for operation in underfrequency and overfrequency situations</p> <table border="1"> <thead> <tr> <th>Frequency Range</th> <th>Time period for operation Minimum requirement</th> <th>Time period for operation stringent requirement</th> </tr> </thead> <tbody> <tr> <td>47,0 Hz – 47,5 Hz</td> <td>not required</td> <td>20 s</td> </tr> <tr> <td>47,5 Hz – 48,5 Hz</td> <td>30 min ^a</td> <td>90 min</td> </tr> <tr> <td>48,5 Hz – 49,0 Hz</td> <td>30 min ^a</td> <td>90 min ^a</td> </tr> <tr> <td>49,0 Hz – 51,0 Hz</td> <td>Unlimited</td> <td>Unlimited</td> </tr> <tr> <td>51,0 Hz – 51,5 Hz</td> <td>30 min ^a</td> <td>90 min</td> </tr> <tr> <td>51,5 Hz – 52,0 Hz</td> <td>not required</td> <td>15 min</td> </tr> </tbody> </table> <p>^a Respecting the legal framework, it is possible that longer time periods are required by the responsible party in some synchronous areas.</p>	Frequency Range	Time period for operation Minimum requirement	Time period for operation stringent requirement	47,0 Hz – 47,5 Hz	not required	20 s	47,5 Hz – 48,5 Hz	30 min ^a	90 min	48,5 Hz – 49,0 Hz	30 min ^a	90 min ^a	49,0 Hz – 51,0 Hz	Unlimited	Unlimited	51,0 Hz – 51,5 Hz	30 min ^a	90 min	51,5 Hz – 52,0 Hz	not required	15 min	(See appended table)	P
Frequency Range	Time period for operation Minimum requirement	Time period for operation stringent requirement																						
47,0 Hz – 47,5 Hz	not required	20 s																						
47,5 Hz – 48,5 Hz	30 min ^a	90 min																						
48,5 Hz – 49,0 Hz	30 min ^a	90 min ^a																						
49,0 Hz – 51,0 Hz	Unlimited	Unlimited																						
51,0 Hz – 51,5 Hz	30 min ^a	90 min																						
51,5 Hz – 52,0 Hz	not required	15 min																						
	<p>This permission does not affect the requirements for interface protection according to clause 4.9. In this case over and under frequency machine protection might trip prior to interface protection. If an integrated interface protection device is used, the reduction of the configuration range of the interface protection in clause 4.9 is acceptable.</p>		P																					
4.4.3	Minimal requirement for active power delivery at underfrequency		P																					
	<p>A generating plant shall be resilient to the reduction of frequency at the point of connection while reducing the maximum active power as little as possible.</p> <p>The admissible active power reduction due to underfrequency is limited by the full line in Figure 5 and is characterized by a maximum allowed reduction rate of 10 % of P_{max} per 1 Hz for frequencies below 49.5 Hz.</p> <p>Figure 5 — Maximum allowable power reduction in case of underfrequency</p>	(See appended table)	P																					

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	It is possible that a more stringent power reduction characteristic is required by the responsible party. Nevertheless this requirement is expected to be limited to an admissible active power reduction represented by the dotted line in Figure 5 which is characterised by a reduction rate of 2 % of the maximum power P_{\max} per 1 Hz for frequencies below 49 Hz.		P
	If any technologies intrinsic design or ambient conditions have influence on the power reduction behaviour of the system, the manufacturer shall specify at which ambient conditions the requirements can be fulfilled and eventual limitations. The information can be provided in the format of a graph showing the intrinsic behaviour of the generating unit for example at different ambient conditions. The power reduction and the ambient conditions shall comply with the specification given by the responsible party. If the generating unit does not meet the power reduction at the specified ambient conditions, the producer and the responsible party shall agree on acceptable ambient conditions.		P
4.4.4	Continuous operating voltage range		P
	When generating power, the generating plant shall be capable of operating continuously when the voltage at the point of connection stays within the range of 85 % U_n to 110 % U_n . Beyond these values the under and over voltage ride through immunity limits as specified in clause 4.5.3 and 4.5.4 shall apply.	(see appended table)	P
	In case of voltages below U_n , it is allowed to reduce the apparent power to maintain the current limits of the generating plant. The reduction shall be as small as technically feasible.		P
	For this requirement all phase to phase voltages and in case a neutral is connected, additionally all phase to neutral voltages shall be evaluated.		P
	The producer shall take into account the typical voltage rise and voltage drop within the generating plant.		Info.
4.5	Immunity to disturbances		P
4.5.1	In general, generating plants should contribute to overall power system stability by providing immunity towards dynamic voltage changes unless safety standards require a disconnection.		P
	The following clauses describe the required immunity for generating plants taking into account the connection technology of the generating modules.		P
	The following withstand capabilities shall be provided regardless of the settings of the interface protection.		P
4.5.2	Rate of change of frequency (ROCOF) immunity	(see appended table)	P


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	ROCOF immunity of a power generating plant means that the generating modules in this plant stay connected with the distribution network and are able to operate when the frequency on the distribution network changes with a specified ROCOF. The generating units and all elements in the generating plant that might cause their disconnection or impact their behaviour shall have this same level of immunity.		P
	The generating modules in a generating plant shall have ROCOF immunity for a ROCOF equal or exceeding the value specified by the responsible party. If no ROCOF immunity value is specified, the following ROCOF immunity shall apply, making distinction between generating technologies:		P
	Non-synchronous generating technology: at least 2 Hz/s		P
	Synchronous generating technology: at least 1 Hz/s		N/A
	The ROCOF immunity is defined with a sliding measurement window of 500 ms.		P
	NOTE 1 For control action based on frequency measurement shorter measurement periods are expected to be necessary.		P
	NOTE 2 For small isolated distribution networks (typically on islands) higher ROCOF immunity values may be required.		P
	NOTE 3 ROCOF is used as a means to detect loss of mains situations in some countries. The ROCOF immunity requirement is independent of the interface protection settings. Disconnection settings of the interface protection relay always overrule technical capabilities. So, whether the generating plant will stay connected or not will also depend upon those settings.		P
4.5.3	Under-voltage ride through (UVRT)	Refer to the testing guide line DIN VDE V 0124-100:2020-06	P
	Generating modules classified as type B modules according to COMMISSION REGULATION 2016/631 shall comply with the requirements of 4.5.3.2 and 4.5.3.3.	Type A Generating modules	N/A
	Generating modules classified as type A and smaller according to COMMISSION REGULATION 2016/631 should comply with these requirements.		P
	The actual behaviour of type A modules and smaller shall be specified in the connection agreement.		P
	NOTE 1 Based on the chosen banding threshold it is considered necessary to include generating modules classified as type A. Exemption is only acceptable for CHP and generating units based on rotating machinery below 50 kW as EN 50465 for gas appliance requests disconnection in case of under voltage.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	NOTE 2 A more distinctive differentiation for 1ph, 2ph and 3ph faults is under consideration.		N/A
	NOTE 3 These requirements are independent of the interface protection settings. Disconnection settings of the interface protection relay will always overrule technical capabilities. So, whether the generating plant will stay connected or not will also depend upon those settings.		P
	NOTE 4 The FRT curves in Figure 6, Figure 7 and Figure 8 describe the minimum requirements for continued connection of the generating plant to the grid. They are not designed for parameterising the interface protection.		P
4.5.3.2	Generating plant with non-synchronous generating technology		P
	<p>Generating modules shall be capable of remaining connected to the distribution network as long as the voltage at the point of connection remains above the voltage-time curve of Figure 6. The voltage is relative to U_n. The smallest phase to neutral voltage, or if no neutral is present, the smallest phase to phase voltage shall be evaluated.</p> <p>Figure 6 — Under-voltage ride through capability for non-synchronous generating technology</p>		P
	The responsible party may define a different UVRT characteristic. Nevertheless, this requirement is expected to be limited to the most stringent curve as indicated in Figure 6.		P
	This means that the whole generating module has to comply with the UVRT requirement. This includes all elements in a generating plant: the generating units and all elements that might cause their disconnection.		P
	For the generating unit, this requirement is considered to be fulfilled if it stays connected to the distribution grid as long as the voltage at its terminals remains above the defined voltage-time diagram.		P
	After the voltage returns to continuous operating voltage range, 90 % of pre-fault power or available power whichever is the smallest shall be resumed as fast as possible, but at the latest within 1 s unless the DSO and the responsible party requires another value.		P
4.5.3.3	Generating plant with synchronous generating technology		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	<p>Generating modules shall be capable of staying connected to the distribution network as long as the voltage at the point of connection remains above the voltage-time curve of Figure 7. The voltage is relative to U_n. The smallest phase to neutral voltage or if no neutral is present the smallest phase to phase voltage shall be evaluated.</p> <p>Figure 7 — Under-voltage ride through capability for synchronous generating technology</p>		P
4.5.4	Over-voltage ride through (OVRT)	Refer to the testing guide line DIN VDE V 0124-100:2020-06	P
	<p>Generating modules, except for micro-generating plants, shall be capable of staying connected to the distribution network as long as the voltage at the point of connection remains below the voltage-time curve of Figure 8.</p> <p>Figure 8 — Over-voltage ride through capability</p>		P
	The highest phase to neutral voltage or if no neutral is present the highest phase to phase voltage shall be evaluated.		P
	This means that not only the generating units shall comply with this OVRT requirement but also all elements in a generating plant that might cause its disconnection.		P
	NOTE 1 Based on the chosen banding threshold it is considered necessary to include generating modules classified as type A. Exemption is only acceptable for CHP and generating units based on rotating machinery below 50 kW as EN 50465 for gas appliance requests disconnection in case of over voltage.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	NOTE 2 These requirements are independent of the interface protection settings. Disconnection settings of the interface protection relay will always overrule technical capabilities. So, whether the generating plant will stay connected or not will also depend upon those settings.		P
	NOTE 3 This is a minimum requirement. Further power system stability aspects might be relevant. The technical discussion is still ongoing. A voltage jump of +10% of Un from any stable point of operation is considered. In case of steady state voltages near the maximum voltage before the event, this will result in an over voltage situation for many seconds. In later editions of this document, more stringent immunity might be required.		P
4.6	Active response to frequency deviation		P
4.6.1	Power response to over-frequency		P
	Generating plants shall be capable of activating active power response to over-frequency at a programmable frequency threshold f1 at least between and including 50,2 Hz and 52 Hz with a programmable droop in a range of at least s=2 % to s=12 %. The droop reference is P ref. Unless defined differently by the responsible party		P
	<ul style="list-style-type: none"> • $P_{ref} = P_{max}$, in the case of synchronous generating technology and electrical energy storage systems 		P
	<ul style="list-style-type: none"> • $P_{ref} = P_M$, the actual AC output power at the instant when the frequency reaches the threshold f1, in the case of all other non-synchronous generating technology 		P
	The power value calculated according to the droop is a maximum power limit. If e.g. the available primary power decreases during a high frequency period below the power defined by the droop function, lower power values are permitted.		P
	<p>The maximum power limit is:</p> $P_{max-limit} = P_M + \Delta P$ $\text{with } \Delta P = \frac{1}{s} \cdot \frac{(f_1 - f)}{f_n} \cdot P_{ref}$ <p>with f the actual frequency</p>		P
	NOTE 1 In other documents power response to overfrequency can also be described as frequency control or Limited Frequency Sensitive Mode - Overfrequency (LFSM-O).		Info.


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	<p>NOTE 2 The active power droop relative to the reference power might also be defined as an active power gradient relative to the reference power. A droop in the range of 2 % to 12 % represents a gradient of 100 % to 16,7 % P_{ref} /Hz so with g defined by</p> $g \left[\frac{P}{P_{ref}} / \text{Hz} \right] = \frac{1}{s \cdot f_n} \text{ we get } \Delta P = g \cdot P_{ref} \cdot (f_1 - f)$		P
	<p>The generating plant shall be capable of activating active power response to over-frequency as fast as technically feasible with an intrinsic dead time that shall be as short as possible with a maximum of 2 s and with a step response time of maximum 30 s, unless another value is defined by the relevant party. An intentional delay shall be programmable to adjust the dead time to a value between the intrinsic dead time and 2 s.</p>		P
	<p>NOTE 3 The following response times are considered feasible, for PV and battery inverter below 1 s for P of 100% ΔP_{max} and for wind turbines 2 s for $\Delta P < 50\% P_{max}$</p>		P
	<p>After activation, the active power frequency response shall use the actual frequency at any time, reacting to any frequency increase or decrease according to the programmed droop with an accuracy of $\pm 10\%$ of the nominal power (see Figure 9). The resolution of the frequency measurement shall be ± 10 mHz or less. The accuracy is evaluated with a 1 min average value. At POC, loads if present in the producer's network might interfere with the response of the generating plant. The effect of loads is not considered for the evaluation of the accuracy, only the behaviour of the generating plant is relevant.</p> <p style="text-align: center;">Rate limited power increase after deactivation of response</p> <p style="text-align: center;">Active Power [% P_{ref} = % P_M]</p> <p style="text-align: center;">100% P_M</p> <p style="text-align: center;">60% P_M</p> <p style="text-align: center;">50,2 50,5 51,0 51,5 52,0</p> <p style="text-align: center;">Frequency [Hz]</p> <p style="text-align: center;"> $P_{ref} = P_M$ $f_1 = 50,2 \text{ Hz}$ $s = 5\%$ $f_{stop} = \text{deactivated}$ </p> <p style="text-align: center;">Figure 9 — Example of Active power frequency response to overfrequency</p>	(see appended table)	P
	<p>NOTE 4 With the provision above, the intentional delay is only active for the activation of the function, once the function is operating, the established control loop is not intentionally delayed.</p>		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	NOTE 5 The option of an intentional delay is required since a very fast and undelayed active power frequency response in case of loss of mains would correct any excess of generation leading to a generation-consumption balance. In these circumstances, an unintended islanding situation with stable frequency would take place, in which the correct behaviour of any loss of mains detection based on frequency might be hindered.		P
	NOTE 6 The intentional delay is considered relevant for power system stability. For that reason, legal regulations might require a mutual agreement on the setting between DSO, responsible party and TSO.		P
	Generating plants reaching their minimum regulating level shall, in the event of further frequency increase, maintain this power level constant unless the DSO and the responsible party requires to disconnect the complete plant or if the plant consists of multiple units by disconnecting individual units.		P
	The active power frequency response is only deactivated if the frequency falls below the frequency threshold f_1 .		P
	<p>If required by the DSO and the responsible party an additional deactivation threshold frequency f_{stop} shall be programmable in the range of at least 50 Hz to f_1. If f_{stop} is configured to a frequency below f_1 there shall be no response according to the droop in case of a frequency decrease (see Figure 10). The output power is kept constant until the frequency falls below f_{stop} for a configurable time t_{stop}.</p>  <p>Figure 10 — Example of active power frequency response to overfrequency with configured deactivation threshold</p>	(see appended table)	P
	If at the time of deactivation of the active power frequency response the momentary active power P_M is below the available active power P_A , the active power increase of the generating plant shall not exceed the gradient defined in 4.10.2.		P

EN 50549-1																					
Clause	Requirement - Test	Result - Remark	Verdict																		
	<p>Settings for the threshold frequency f_1, the droop and the intentional delay are provided by the DSO and the responsible party. If no settings are provided, the default settings in Table 2 should be applied.</p> <p>Table 2 — Standard settings for frequency response to overfrequency</p> <table border="1"> <thead> <tr> <th>Parameter</th> <th>Range</th> <th>Default setting</th> </tr> </thead> <tbody> <tr> <td>Threshold frequency f_1</td> <td>50,2 Hz to 52 Hz</td> <td>50,2 Hz</td> </tr> <tr> <td>Deactivation threshold f_{stop}</td> <td>50,0 Hz to f_1</td> <td>Deactivated</td> </tr> <tr> <td>Deactivation time t_{stop}</td> <td>0 to 600 s</td> <td>30s</td> </tr> <tr> <td>Droop</td> <td>2 % to 12 %</td> <td>5 %</td> </tr> <tr> <td>Intentional delay</td> <td>0 s to 2 s</td> <td>0 s</td> </tr> </tbody> </table>	Parameter	Range	Default setting	Threshold frequency f_1	50,2 Hz to 52 Hz	50,2 Hz	Deactivation threshold f_{stop}	50,0 Hz to f_1	Deactivated	Deactivation time t_{stop}	0 to 600 s	30s	Droop	2 % to 12 %	5 %	Intentional delay	0 s to 2 s	0 s		P
Parameter	Range	Default setting																			
Threshold frequency f_1	50,2 Hz to 52 Hz	50,2 Hz																			
Deactivation threshold f_{stop}	50,0 Hz to f_1	Deactivated																			
Deactivation time t_{stop}	0 to 600 s	30s																			
Droop	2 % to 12 %	5 %																			
Intentional delay	0 s to 2 s	0 s																			
	NOTE 7 When applying active power response to overfrequency, the frequency threshold f_1 should be set to a value from 50,2 Hz up to 50,5 Hz. Setting the frequency threshold f_1 to 52 Hz is considered as deactivating this function.		P																		
	The enabling and disabling of the function and its settings shall be field adjustable and means shall be provided to protect these from unpermitted interference (e.g. password or seal) if required by the DSO and the responsible party.		P																		
	NOTE 8 PV generating units are considered to have the ability to reduce power over the full droop range.		P																		
	NOTE 9 Protection setting overrules this behaviour.		P																		
	Alternatively for the droop function described above, the following procedure is allowed for generating modules if permitted by the DSO and the responsible party:		P																		
	<ul style="list-style-type: none"> the generating units shall disconnect at randomized frequencies, ideally uniformly distributed between the frequency threshold f_1 and 52 Hz; 		P																		
	NOTE 10 The usage of a disconnection limit above 51,5Hz does not necessarily imply the requirement to operate at this frequency. Operating range is defined in clause 4.4.4. If the randomized disconnection value is above the operating range and interface protection setting, the unit is disconnected according to chapter 4.9 at the value set by the interface protection.		P																		
	<ul style="list-style-type: none"> in case the frequency decreases again, the generating unit shall start its reconnection procedure once the frequency falls below the specific frequency that initiated the disconnection; for this procedure, the connection conditions described in 4.10 do not apply; 		P																		
	<ul style="list-style-type: none"> the randomization shall either be at unit level by changing the threshold over time, or on plant level by choosing different values for each unit within a plant, or on distribution system level if the DSO specifies a specific threshold for each plant or unit connected to its distribution system. 		P																		

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	NOTE 11 This procedure could be applied for generating modules for which it is technically not feasible to reduce power with the required accuracy in the required time or for reasons within the distribution network for example to prevent unintentional island operation.		P
	NOTE 12 The behaviour will, for a part of the network with many such units, result in a similar droop as specified above for controllable generating units and hence will provide for the necessary power system stability. Due to its fast reaction capability it contributes significantly to the avoidance of a frequency overshoot.		P
	EES units that are in charging mode at the time the frequency passes the threshold f_1 shall not reduce the charging power below P_M until frequency returns below f_1 . Storage units should increase the charging power according to the configured droop. In case the maximum charging capacity is reached or to prevent any other risk of injury or damage of equipment, a reduction of charging power is permitted.		P
4.6.2	Power response to under-frequency		P
	EES units shall be capable of activating active power response to under-frequency. Other generating units/plants should be capable of activating active power response to under-frequency. If active power to under-frequency is provided by a generating plant/unit, the function shall comply with the requirements below.		P
	NOTE 1: In other documents power response to under-frequency is also described as frequency control or Limited Frequency Sensitive Mode – Under-frequency (LFSM-U).		P
	Active power response to under-frequency shall be provided when all of the following conditions are met:		P
	<ul style="list-style-type: none"> when generating, the generating unit is operating at active power below its maximum active power P_{max}; 		P
	<ul style="list-style-type: none"> when generating, the generating unit is operating at active power below the available active power P_A; 		P
	NOTE 2 In case of EES units, the available power includes the state of charge of the storage.		P
	<ul style="list-style-type: none"> the voltages at the point of connection of the generating plant are within the continuous operating voltage range; and 		P
	<ul style="list-style-type: none"> when generating, the generating unit is operating with currents lower than its current limit. 		P
	NOTE 3 These conditions apply to each generating unit individually since the specified conditions need to be met by each generating unit individually to allow the unit to increase power.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	In the case of EES units, active power frequency response to under-frequency shall be provided in charging and generating mode.		P
	NOTE 4 In the case of EES units, the charging is regarded as a point of operation with negative active power. In charging mode the active power consumption is reduced according to the configured droop. Depending on the depth of the under-frequency event a change to generating mode will happen. In this case the state of charge of the storage is part of the conditions above.		P
	NOTE 5 This clause provides additional detail to the network code on emergency and restoration (Regulation (EU) 2017/2196) and more precisely on its Article 15.3 (a).		P
	<p>The active power response to under-frequency shall be delivered at a programmable frequency threshold f_1 at least between and including 49,8 Hz and 46,0 Hz with a programmable droop in a range of at least 2 % to 12 %.</p> <p>The droop reference P_{ref} is P_{max}. If the available primary power or a local set value increases during an under-frequency period above the power defined by the droop function, higher power values are permitted. The power value calculated according to the droop is therefore a minimum limit.</p> <p>The minimum power limit is,</p> $P_{min-limit} = P_M + \Delta P$ <p>with $\Delta P = \frac{1}{s} \times \frac{(f_1 - f)}{f_n} \times P_{ref}$</p> <p>with f the actual frequency</p>		P
	NOTE 6 In the case of active power response to under-frequency, P_{max} is used as P_{ref} to allow for system support even in case of low power output in the moment the event begins.		P
	<p>NOTE 7 The active power droop relative to the reference power might also be defined as an active power gradient relative to the reference power. A droop in the range of 2 % to 12 % represents a gradient of 100 % to 16,7 % P_{ref} /Hz so with g defined by</p> $g \left[\frac{P}{P_{ref}} / Hz \right] = \frac{1}{s \cdot f_n} \text{ we get } \Delta P = g \cdot P_{ref} \cdot (f_1 - f).$		P
	NOTE 8 In the case of an increase of active power generation, the hierarchy of requirements in clause 4.1 apply.		P


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	The generating unit shall be capable of activating active power response to under-frequency as fast as technically feasible with an intrinsic dead time that shall be as short as possible with a maximum of 2 s and with a step response time of maximum 30 s unless another value is defined by the relevant party.		P
	<p>An intentional initial delay shall be programmable to adjust the dead time to a value between the intrinsic dead time and 2 s.</p>  <p>Figure 11 — Example of active power frequency response to underfrequency in case of storage device with 20 % power charging at passing of threshold frequency f_1</p>		P
	After activation, the active power frequency response shall use the actual frequency at any time, reacting to any frequency increase or decrease according to the programmed droop with an accuracy of $\pm 10\%$ of the nominal power. The accuracy is evaluated with a 1 min average value. The resolution of the frequency measurement shall be ± 10 mHz or less. At POC loads, if present in the producer's network, might interfere with the response of the generating plant. The effect of loads is not considered for the evaluation of the accuracy, only the behaviour of the generating plant is relevant.		P
	NOTE 9 With the provision above, the intentional delay is only active for the activation of the function, once the function is operating, the established control loop is not intentionally delayed.		P
	NOTE 10 The option of an intentional delay is required since a very fast and undelayed active power frequency response in case of loss of mains would correct any shortage of generation leading to a generation-consumption balance. In these circumstances, an unintended islanding situation with stable frequency would take place, in which the correct behaviour of any loss of mains detection based on frequency might be hindered.		P
	NOTE 11 The intentional delay is considered relevant for power system stability. For that reason, legal regulations might require a mutual agreement on the setting between DSO, responsible party and TSO.		P



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Generating modules reaching any of the conditions above during the provision of active power frequency response shall, in the event of further frequency decrease, maintain this power level constant.		P
	The active power frequency response is only deactivated if the frequency increases above the frequency threshold f_1 .		P
	Settings for the threshold frequency f_1 , the droop and the intentional delay are defined by the DSO and the responsible party, if no settings are provided, the function shall be disabled.		P
	NOTE 12 When applying active power response to under-frequency, the frequency threshold f_1 should be set to a value from 49,8 Hz up to 49,5 Hz. Setting the frequency threshold f_1 to 46 Hz is considered as deactivating this function.		P
	The activation and deactivation of the function and its settings shall be field adjustable and means shall be provided to protect these from unpermitted interference (e.g. password or seal) if required by the DSO and the responsible party.		P
4.7	Power response to voltage changes		P
4.7.1	General		P
	When the contribution to voltage support is required by the DSO and the responsible party, the generating plant shall be designed to have the capability of managing reactive and/or active power generation according to the requirements of this clause.		P
4.7.2	Voltage support by reactive power		P
4.7.2.1	General		P
	Generating plants shall not lead to voltage changes out of acceptable limits. These limits should be defined by national regulation. Generating units and plants shall be able to contribute to meet this requirement during normal network operation.		P
	Throughout the continuous operating frequency (see 4.4.2) and voltage (see 4.4.4) range, the generating plant shall be capable to deliver the requirements stipulated below. Outside these ranges, the generating plant shall follow the requirements as good as technically feasible although there is no specified accuracy required.		P
4.7.2.2	Capabilities		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	<p style="text-align: center;">Figure 12 — Reactive power capability at nominal voltage</p>	(see appended table)	P
	Figure 12 gives a graphical representation of the minimum and optional capabilities at nominal voltage.		P
	Unless specified differently below, for specific generating technologies, generating plants shall be able to operate with active factors as defined by the DSO and the responsible party from active factor = 0,90 _{underexcited} to active factor= 0,90 _{overexcited} .		P
	The reactive power capability shall be evaluated at the terminals of the/each generating unit.		P
	CHP generating units with a capacity <150KVA shall be able to operate with active factors as defined by DSO from $\cos \varphi = 0,95_{\text{underexcited}}$ to $\cos \varphi = 0,95_{\text{overexcited}}$		P
	Generating units with an induction generator coupled directly to the grid and used in generating plants above micro generating level, shall be able to operate with active factors as defined by the DSO from $\cos \varphi = 0,95_{\text{underexcited}}$ to $\cos \varphi = 1$ at the terminals of the unit. Deviating from 4.7.2.3 point mode is required. Deviating from the accuracy requirements below, the accuracy is only required at active power P_D .		P
	Generating units with an induction generator coupled directly to the grid and used in micro generating plants shall operate with an active factor above 0,95 at the terminals of the generating unit. A controlled voltage support by reactive power is not required from this technology.		P
	Generating units with linear generators, coupled directly and synchronously to the grid shall operate with an active factor above 0,95 at the terminals of the generating unit, and therefore a controlled voltage support by reactive power is not required from this technology.		P
	In case of different generating technologies with different requirements in one generating plant, each unit shall provide voltage support by reactive power as required for its specific technology. A compensation of one technology to reach the general plant requirement is not expected.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	The DSO and the responsible party may relax the above requirements. This relaxation might be general or specific for a certain generating plant or generating technology.		P
	NOTE 1 The generating unit manufacturer has a certain freedom in the sizing of the output side of the generating unit considering the advantages and drawbacks in the practical use of the generating unit when evaluating the need to reduce active output power (e.g. due to voltage changes or reactive power exchange) in order to respond to the requirements of this European Standard. This is indicated by the Design freedom area in Figure 12.		P
	All involved parties can expect to have access to information documenting the actual choices regarding active power capabilities relative to reactive power requirements and related to the power rating in the operating voltage range (see further in this clause). A P-Q Diagram shall be included in the product documentation of a generating unit.		P
	NOTE 2 For additional network support an optional extended reactive power capability according to Figure 12 might be provided by the generating plant, if agreed on between the DSO and the producer and is generally required in some countries for some technologies by legal regulations.		P
	NOTE 3 Additional requirements (e.g. continuous Var compensation or continuous reactive power operation disregarding the availability of the primary energy) might be provided by the generating plant, if agreed between the DSO and the producer.		P
	NOTE 4 In case of overvoltage, additional reactive power might be exchanged up to the rated current (increasing the apparent power as a consequence), if agreed on between the DSO and the producer.		P
	When operating above the apparent power threshold S_{min} equal to 10 % of the maximum apparent power S_{max} or the minimum regulating level of the generating plant, whichever is the higher value, the reactive power capability shall be provided with an accuracy of $\pm 2 \% S_{max}$. Up to this apparent power threshold S_{min} , deviations above 2 % are permissible; nevertheless the accuracy shall always be as good as technically feasible and the exchange of uncontrolled reactive power in this low-power operation mode shall not exceed 10 % of the maximum apparent power S_{max} . At POC loads, if present in the producer's network might interfere with the response of the generating plant. The effect of loads is not considered for the evaluation of the accuracy, only the behaviour of the generating plant is relevant.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	<p>For generating units with a reactive power capability according Figure 12 the reactive power capability at active power P_D shall be at least according Figure 13. For generating units with a reduced reactive power capability Figure 13 is only applicable up to the maximum reactive power capability.</p> <p>Figure 13 — Reactive power capability at active power P_D in the voltage range (positive sequence component of the fundamental)</p>		P
	<p>NOTE 5 Depending on the P-Q characteristic of the generating plant/unit, the reactive power at active powers below P_D might be lower respecting the requirements above. If no or less than 0,484 Q/P_D reactive power is required, the active power might increase above P_D as indicated in Figure 12.</p>		P
	<p>For voltages below U_n it is allowed to reduce apparent power according to 4.4.4</p>		P
	<p>NOTE 6 Whether there is a priority given to P or Q or the active factor when reaching the maximum apparent power this is not defined in this European Standard. Risks and benefits of different priority approaches are under consideration.</p>		P
4.7.2.3	Control modes		P
4.7.2.3.1	General		P
	<p>The control shall refer to the terminals of the generating units The generating plant/unit shall be capable of operating in the control modes specified below within the limits specified in 4.7.2.2. The control modes are exclusive; only one mode may be active at a time.</p>		P
	<ul style="list-style-type: none"> • Q set-point mode 	(see appended table)	P
	<ul style="list-style-type: none"> • Q (U) 	(see appended table)	P
	<ul style="list-style-type: none"> • Cos φ set-point mode 	(see appended table)	P
	<ul style="list-style-type: none"> • Cos φ (P) 	(see appended table)	P
	<p>For mass market products, it is recommended to implement all control modes. In case of site specific generating plant design, only the control modes required by the DSO need to be implemented.</p>		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	The configuration, activation and deactivation of the control modes shall be field adjustable. For field adjustable configurations and activation of the active control mode, means shall be provided to protect the settings from unpermitted interference (e.g. password or seal) if required by the DSO. Which control modes are available in a product and how they are configured shall be stated in the product documentation.		P
4.7.2.3.2	Set-point control modes	(see appended table)	P
	Q set-point mode and $\cos \varphi$ set-point mode control the reactive power output and the $\cos \varphi$ of the output respectively, according to a set point set in the control of the generating plant/unit. In the case of change of the set point local or by remote control the settling time for the new set point shall be less than one minute.		P
4.7.2.3.3	Voltage related control mode	(see appended table)	P
	It is the responsibility of the generating plant designer to choose a method. One of the following methods should be used:		P
	<ul style="list-style-type: none"> the positive sequence component of the fundamental; 		P
	<ul style="list-style-type: none"> the average of the voltages measured independently for each phase to neutral or phase to phase; 		P
	<ul style="list-style-type: none"> phase independently the voltage of every phase to determine the reactive power for every phase. 		P
	For voltage related control modes, a characteristic with a minimum and maximum value and three connected lines according to Figure 16 shall be configurable. 		P
	Figure 16 — Example characteristics for Q respectively $\cos \varphi$ control mode		
	In addition to the characteristic, further parameters shall be configurable:		P
	<ul style="list-style-type: none"> The dynamics of the control shall correspond with a first order filter having a time constant that is configurable in the range of 3 s to 60 s 		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	NOTE 1 The time to perform 95 % of the changed set point due to a change in voltage will be 3 times the time constant.		P
	NOTE 2 The dynamic response of the generating units to voltage changes is not considered here. The response to disturbances as in 4.5 and short circuit current requirements as in 4.7.4 is not included in this clause.		P
	NOTE 3 An intentional delay is under consideration.		P
	To limit the reactive power at low active power two methods shall be configurable:		P
	<ul style="list-style-type: none"> a minimal cos shall be configurable in the range of 0-0.95; 		P
	<ul style="list-style-type: none"> two active power levels shall be configurable both at least in the range of 0 % to 100 % of P_D. The lock-in value turns the Q(U) mode on, the lock-out value turns Q(U) off. If lock-in is larger than lock-out a hysteresis is given. See also Figure 14.  <p>Figure 14 – Example of lock-in and lock-out values for Q(U) mode</p>		P
	<p>The static accuracy shall be in accordance with 4.7.2.2. The dynamic accuracy shall be in accordance with Figure 15 - 5% of P_D plus a time delay of up to 3 seconds deviating from an ideal first order filter response.</p>  <p>Figure 15 — Example of dynamic control response and tolerance band for a step from $Q=0$ to $Q=33\%P_D$ with $\tau=3,33s$</p>		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.7.2.3.4	Power related control mode	(see appended table)	P
	The power related control mode $\cos \varphi$ (P) controls the output as a function of the active power output.		P
	For power related control modes, a characteristic with a minimum and maximum value and three connected lines shall be configurable in accordance with Figure 16.		P
	Resulting from a change in active power output a new $\cos \varphi$ set point is defined according to the set characteristic. The response to a new $\cos \varphi$ set value shall be as fast as technically feasible to allow the change in reactive power, The new reactive power set value shall be reached at the latest within 10 s after the end value of the active power is reached, the static accuracy of each \cos set point shall be according to 4.7.2.2		P
4.7.3	Voltage related active power reduction		P
	In order to avoid disconnection due to overvoltage protection (see 4.9.3.3 and 4.9.3.4), generating plants/units are allowed to reduce active power output as a function of this rising voltage. The final implemented logic can be chosen by the manufacturer. Nevertheless, this logic shall not cause steps or oscillations in the output power. The power reduction caused by such a function may not be faster than an equivalent of a time constant $\tau = 3 \text{ s}$ (= 33%/s at a 100% change). The enabling and disabling of the function shall be field adjustable and means have to be provided to protect the setting from unpermitted interference (e.g. password or seal) if required by the DSO.	(see appended table)	P
4.7.4	Short circuit current requirements on generating plants		P
4.7.4.1	General		P
	The following clauses describe the required short circuit current contribution for generating plants taking into account the connection technology of the generating modules.		P
	Generating modules classified as type B modules according to COMMISSION REGULATION 2016/631 shall comply with the requirements of 4.7.4.2 and 4.7.4.3.	Type A generating modules	N/A
	Generating modules classified as type A according to COMMISSION REGULATION 2016/631 should comply with these requirements. The actual behaviour of type A modules shall be specified in the connection agreement.		P
	NOTE Based on the chosen banding threshold it is considered necessary to include generating modules classified as type A if connected to medium voltage distribution grids. Exemption is only acceptable for CHP and generating units based on rotating machinery below 50 kW as EN 50465 for gas appliance requests disconnection in case of under voltage.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.7.4.2	Generating plant with non-synchronous generating technology		P
4.7.4.2.1	Voltage support during faults and voltage steps		N/A
	In general no voltage support during faults and voltage steps is required from generating plants connected in LV distribution networks as the additional reactive current is expected to interfere with grid protection equipment. If the responsible party requires voltage support during faults and voltage steps for generating plants of type B connected to LV distribution grids, the clause 4.7.4 of EN 50549-2 applies		N/A
4.7.4.2.2	Zero current mode for converter connected generating technology		P
	If UVRT capability (see 4.5.3) is provided additional to the requirements of 4.5, generating units connected to the grid by a converter shall have the capability to reduce their current as fast as technically feasible down to or below 10 % of the rated current when the voltage is outside of a static voltage range. Generating units based on a doubly fed induction machine can only reduce the positive sequence current below 10 % of the rated current. Negative sequence current shall be tolerated during unbalanced faults. In case this current reduction is not sufficient, the DSO should choose suitable interface protection settings.		P
	The static voltage range shall be adjustable from 20 % to 100 % of U_n for the under-voltage boundary and from 100 % to 130 % of U_n for the overvoltage boundary. The default setting shall be 50% of U_n for the under-voltage boundary and 120% of U_n for the overvoltage boundary. Each phase to neutral voltage or if no neutral is present each phase to phase voltage shall be evaluated. At voltage re-entry into the voltage range, 90% of pre-fault power or available power, whichever is the smallest, shall be resumed as fast as possible, but at the latest according to 4.5.3 and 4.5.4.		P
	All described settings are defined by the DSO and the responsible party. If no settings are provided, the function shall be disabled. The enabling and disabling and the settings shall be field adjustable and means have to be provided to protect these from unpermitted interference (e.g. password or seal) if required by the DSO.		P
4.7.4.2.3	Induction generator based units	The unit was not induction generator.	N/A

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	In general no voltage support during faults and voltage steps is required from generating plants connected in LV distribution networks as the additional reactive current is expected to interfere with grid protection equipment. If the responsible party requires voltage support during faults and voltage steps for generating plants of type B connected to LV distribution grids, the clause 4.7.4 of EN50549-2 applies.		N/A
4.7.4.3	Generating plant with synchronous generating technology - Synchronous generator based units	The inverter is not synchronous generating technology.	N/A
	In general no voltage support during faults and voltage steps is required from generating plants connected in LV distribution networks as the additional reactive current is expected to interfere with grid protection equipment. If the responsible party requires voltage support during faults and voltage steps for generating plants of type B connected to LV distribution grids, the clause 4.7.4 of EN50549-2 applies.		N/A
4.8	EMC and power quality		P
	Similar to any other apparatus or fixed installation, generating units shall comply with the requirements on electromagnetic compatibility established in Directive 2014/30/EU or 2014/53/EU, whichever applies.		P
	EMC limits and tests, described in EN 61000 series, have been traditionally developed for loads, without taking into account the particularities of generating units, such as their capability to create overvoltages or high frequency disturbances due to the presence of power converters, which were either impossible or less frequent in case of loads.		Info.
	NOTE 1 Currently, IEC SC 77A are reviewing all their existing standards to include, where necessary, specific requirements for generating units/plants. For dispersed generating units in LV networks, the Technical Report IEC/TR 61000-3-15 is addressing gaps in the existing EMC standards making recommendations on the following aspects: <ul style="list-style-type: none"> • Harmonic emissions; • Flicker and voltage fluctuations; • DC injection; • Short and long duration overvoltages emission; • Switching frequency emission; • Immunity to voltage dips and short interruptions; • Immunity to frequency variation; • Immunity to harmonics and inter-harmonics; • Unbalance. 		Info.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	As long as specific tests for generating units are not available for immunity and/or emission, generic EMC standards and/or any relevant EU harmonized EMC standard should be applied.	See separate EMC test report No. 2070319R-PV-CE-P01V01 prepared by DEKRA	P
	NOTE 2 Besides the compliance with EN 61000 Series, in most countries power quality characteristic according to standards such as for example EN 61400-21 or VDE V 0124-100 are required as part of the connection agreement.		P
	Additional phenomena need to be addressed specifically to generating plants and their integration in the power system.		P
	<ul style="list-style-type: none"> • ROCOF: See 4.5.2 	(see appended table)	P
	<ul style="list-style-type: none"> • UVRT: See 4.5.3 		P
	<ul style="list-style-type: none"> • OVRT: See 4.5.4 		P
	<ul style="list-style-type: none"> • DC injection: Generating plants shall not inject direct currents. 	(see appended table)	P
	NOTE 3 The DC injection clause is considered to be passed when for all generating units within the generating plant the measured DC injection of a type-tested unit is below the testing threshold.		P
	Generating plants can also disturb mains signalling (ripple control or power line carrier systems). EMC requirements on inter-harmonics and on conducted disturbances in the frequency range between 2 kHz and 150 kHz are under development. In case of electromagnetic interferences to mains signalling systems due to the connection of a generating plant, mitigation measures should be taken and national requirements may apply.		P
	Generating units are also expected to be compatible with voltage characteristics at the point of connection, as described in EN 50160 or in national regulations; however no compliance test is required due to the scope of EN 50160.		P
4.9	Interface protection		P
4.9.1	General		P
	According to HD 60364-5-551:2010, 551.7.4, means of automatic switching shall be provided to disconnect the generating plant from the distribution network in the event of loss of that supply or deviation of the voltage or frequency at the supply terminals from values declared for normal supply.		P
	This automatic means of disconnection has following main objectives:		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	<ul style="list-style-type: none"> prevent the power production of the generating plant to cause an overvoltage situation in the distribution network it is connected to. Such over-voltages could result in damages to the equipment connected to the distribution network as well as the distribution network itself; 		P
	<ul style="list-style-type: none"> detect unintentional island situations and disconnect the generating plant in this case. This is contributing to prevent damage to other equipment, both in the producers' installations and the distribution network due to out of phase re-closing and to allow for maintenance work after an intentional disconnection of a section of the distribution network; 		P
	NOTE 1 It is pointed out that checking the absence of voltage on all the live conductors is anyway mandatory before accessing a site for (maintenance) work.		P
	<ul style="list-style-type: none"> assist in bringing the distribution network to a controlled state in case of voltage or frequency deviations beyond corresponding regulation values. 		P
	It is not the purpose of the interface protection system to:		P
	<ul style="list-style-type: none"> disconnect the generating plant from the distribution network in case of faults internal to the power generating plant. Protection against internal faults (short-circuits) shall be coordinated with network protection, according to DSO protection criteria. Protection against e.g. overload, electric shock and against fire hazards shall be implemented additionally according to HD 60364-1 and local requirements; 		P
	<ul style="list-style-type: none"> prevent damages to the generating unit due to incidents (e.g. short circuits) on the distribution network 		P
	Interface protections may contribute to preventing damage to the generating units due to out-of-phase reclosing of automatic reclosing which may happen after some hundreds of ms. However, in some countries some technologies of generating units are explicitly required to have an appropriate immunity level against the consequences of out-of-phase reclosing.		P
	The type of protection and the sensitivity and operating times depend upon the protection and the characteristics of the distribution network.		P
	A wide variety of approaches to achieve the above mentioned objectives is used throughout Europe. Besides the passive observation of voltage and frequency other active and passive methods are available and used to detect island situations. The requirements given in this clause are intended to provide the necessary functions for all known approaches as well as to give guidance in their use. Which functions are available in a product shall be stated in the product documentation.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	The interface protection system shall comply with the requirements of this European Standard, the available functions and configured settings shall comply with the requirements of the DSO and the responsible party. In any case, the settings defined shall be understood as the values for the interface protection system, i.e. where there is a wider technical capability of the generation module, it shall not be withheld by the settings of the protections (other than the interface protection).		P
	For micro generating plants, the interface protection system and the point of measurement might be integrated into the generating units. For generating plants with nominal current above 16 A the DSO may define a threshold above which the interface protection system shall be realized as a dedicated device and not integrated into the generating units.		P
	NOTE 2 Example thresholds are 11,08 kW per generating plant (Italy), 30 kVA per generating plant (Germany, Austria) and 50 kW per generating unit (GB)		Info.
	NOTE 3 Integrated interface protection systems might not be possible for two different reasons:		P
	<ul style="list-style-type: none"> to place the protection system as close to the point of connection as possible, to avoid tripping due to overvoltages resulting from the voltage rise within the producer's network; 		P
	<ul style="list-style-type: none"> to allow for periodic field tests. In some countries periodic field tests are not required if the protection system meets the requirements of single fault safety. 		P
	The interface protection relay acts on the interface switch. The DSO may require that the interface protection relay acts additionally on another switch with a proper delay in case the interface switch fails to operate.		P
	In case of failure of the power supply of the interface protection, the interface protection shall trigger the interface switch without delay. An uninterruptible power supply may be required by the DSO, for instance in case of UVRT capability, delay in protection etc.		P
	In case of field adjustable settings of threshold and operation time, means shall be provided to protect the settings from unpermitted interference (e.g. password or seal) if required by the DSO.		P
4.9.2	Void		N/A
4.9.3	Requirements on voltage and frequency protection		P
4.9.3.1	General		P
	Part or all of the following described functions may be required by the DSO and the responsible party.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	NOTE 1 In the following the headings of the clause sections contain ANSI device numbers according to IEEE/ANSI C37.2 in square brackets e.g. [27].		P
	The protection functions shall evaluate at least all phases where generating units, covered by this protection system, are connected to.		P
	In case of three phase generating units/plants and in all cases when the protection system is implemented as an external protection system in a three phase power supply system, all phase to phase voltages and, if a neutral conductor is present, all phase to neutral voltages shall be evaluated.		P
	NOTE 2 It is possible to calculate the phase to phase voltages based on phase-neutral measurements.		P
	The frequency shall be evaluated on at least one of the voltages.		P
	If multiple signals (e.g. 3 phase to phase voltages) are to be evaluated by one protection function, this function shall evaluate all of the signals separately. The output of each evaluation shall be OR connected, so that if one signal passes the threshold of a function, the function shall trip the protection in the specified time.		P
	The minimum required accuracy for protection is:		P
	<ul style="list-style-type: none"> for frequency measurement $\pm 0,05$ Hz; 		P
	<ul style="list-style-type: none"> for voltage measurement ± 1 % of U_n. 		P
	<ul style="list-style-type: none"> The reset time shall be ≤ 50 ms 		P
	<ul style="list-style-type: none"> The interface protection relay shall not conduct continuous starting and disengaging operations of the interface protection relay. Therefore a reasonable reset ratio shall be implemented which shall not be zero but be below 2% of nominal value for voltage and below 0,2Hz for frequency. 		P
	NOTE 3 If the interface protection system is external to the generating unit, it is preferably located as close as possible to the point of connection. The voltage rise between the point of connection and the measurement input of the interface protection system is then kept as small as possible to avoid nuisance tripping of the overvoltage protection.		P
4.9.3.2	Under-voltage protection [27]	(see appended table)	P
	The protection shall comply with EN 60255-127. The evaluation of the r.m.s. or the fundamental value is allowed.		P
	Under-voltage protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Under-voltage threshold stage 1 [27 <]:		P
	• Threshold (0,2 – 1) Un adjustable by steps of 0,01 Un		P
	• Operate time (0,1 – 100) s adjustable in steps of 0,1 s		P
	Under-voltage threshold stage 2 [27 < <]:		P
	• Threshold (0,2 – 1) Un adjustable by steps of 0,01 Un		P
	• Operate time (0,1 – 5) s adjustable in steps of 0,05 s		P
	The under-voltage threshold stage 2 is not applicable for micro-generating plants		P
4.9.3.3	Overvoltage protection	(see appended table)	P
	The protection shall comply with EN 60255-127. The evaluation of the r.m.s. or the fundamental value is allowed.		P
	Overvoltage protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.		P
	Overvoltage threshold stage 1 [59 >]:		P
	• Threshold (1,0 – 1,2) Un adjustable by steps of 0,01 Un		P
	• Operate time (0,1 – 100) s adjustable in steps of 0,1 s		P
	Overvoltage threshold stage 2 [59 > >]:		P
	• Threshold (1,0 – 1,30) Un adjustable by steps of 0,01 Un		P
	• Operate time (0,1 – 5) s adjustable in steps of 0,05 s		P
4.9.3.4	Overvoltage 10 min mean protection	(see appended table)	P
	The calculation of the 10 min value shall comply with the 10 min aggregation of EN 61000-4-30 Class S, but deviating from EN 61000-4-30 as a moving window is used. Therefore the function shall be based on the calculation of the square root of the arithmetic mean of the squared input values over 10 min. The calculation of a new 10 min value at least every 3 s is sufficient, which is then to be compared with the threshold value.		P
	• Threshold (1,0 – 1,15) Un adjustable by steps of 0,01 Un		P
	• Start time 3s not adjustable		P
	• Time delay setting = 0 ms		P
	NOTE 1 This function evaluates the r.m.s value.		P
	NOTE 2 More information can be found in EN 50160.		P
4.9.3.5	Under-frequency protection [81 <]	(see appended table)	P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Under frequency protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.		P
	Under-frequency threshold stage 1 [$81 < \cdot$]:		P
	<ul style="list-style-type: none"> Threshold (47,0 – 50,0) Hz adjustment by steps of 0,1 Hz 		P
	<ul style="list-style-type: none"> Operate time (0,1 – 100) s adjustable in steps of 0,1 s 		P
	Under-frequency threshold stage 2 [$81 < < \cdot$]:		P
	<ul style="list-style-type: none"> Threshold (47,0 – 50,0) Hz adjustment by steps of 0,1 Hz 		P
	<ul style="list-style-type: none"> Operate time (0,1 – 5) s adjustable in steps of 0,05 s 		P
	In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal.		P
	The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n . Under 0,2 U_n the frequency protection is inhibited. Disconnection may only happen based on under-voltage protection.		P
4.9.3.6	Over-frequency protection [$81 > \cdot$]	(see appended table)	P
	Over-frequency protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.		P
	Over-frequency threshold stage 1 [$81 > \cdot$]:		P
	<ul style="list-style-type: none"> Threshold (50,0 - 52,0) Hz adjustment by steps of 0,1 Hz 		P
	<ul style="list-style-type: none"> Operate time (0,1 – 100) s adjustable in steps of 0,1 s 		P
	Over-frequency threshold stage 2 [$81 > > \cdot$]:		P
	<ul style="list-style-type: none"> Threshold (50,0 - 52,0) Hz adjustment by steps of 0,1 Hz 		P
	<ul style="list-style-type: none"> Operate time (0,1 - 5) s adjustable in steps of 0,05 s 		P
	In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal.		P
	The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n .		P
4.9.4	Means to detect island situation		P
4.9.4.1	General		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Besides the passive observation of voltage and frequency further means to detect an island may be required by the DSO. Detecting islanding situations shall not be contradictory to the immunity requirements of 4.5.	ROCOF tripping	P
	Commonly used functions include: <ul style="list-style-type: none"> • Active methods tested with a resonant circuit; • ROCOF tripping; • Switch to narrow frequency band; • Vector shift • Transfer trip. 		P
	Only some of the methods above rely on standards. Namely for ROCOF tripping and for the detection of a vector shift, also called a vector jump, currently no European Standard is available.		P
4.9.4.2	Active methods tested with a resonant circuit		P
	These are methods which pass the resonant circuit test for PV inverters according to EN 62116.		P
4.9.4.3	Switch to narrow frequency band (see Annex E and Annex F)		P
	In case of local phenomena (e.g. a fault or the opening of circuit breaker along the line) the DSO in coordination with the responsible party may require a switch to a narrow frequency band to increase the interface protection relay sensitivity. In the event of a local fault it is possible to enable activation of the restrictive frequency window (using the two under-frequency/over-frequency thresholds described in 4.9.2.5 and 4.9.2.6) correlating its activation with another additional protection function.		P
	If required by the DSO, a digital input according to 4.9.4 shall be available to allow the DSO the activation of a restrictive frequency window by communication. NOTE An additional gateway to ensure communication with the DSO communication system might be required.		P
4.9.5	Digital input to the interface protection		P
	If required by the DSO, the interface protection shall have at least two configurable digital inputs. These inputs can for example be used to allow transfer trip or the switching to the narrow frequency band.		P
4.10	Connection and starting to generate electrical power		P
4.10.1	General		P
	Connection and starting to generate electrical power is only allowed after voltage and frequency are within the allowed voltage and frequency ranges for at least the specified observation time. It shall not be possible to overrule these conditions.		P

EN 50549-1																								
Clause	Requirement - Test	Result - Remark	Verdict																					
	Within these voltage and frequency ranges, the generating plant shall be capable of connecting and starting to generate electrical power.		P																					
	The setting of the conditions depends on whether the connection is due to a normal operational startup or an automatic reconnection after tripping of the interface protection. In case the settings for automatic reconnection after tripping and starting to generate power are not distinct in a generating plant, the tighter range and the start-up gradient shall be used.		P																					
	The frequency range, the voltage range, the observation time and the power gradient shall be field adjustable.		P																					
	For field adjustable settings, means shall be provided to protect the settings from unpermitted interference (e.g. password or seal) if required by the DSO.		P																					
4.10.2	Automatic reconnection after tripping		P																					
	<p>The frequency range, the voltage range, the observation time shall be adjustable in the range according to Table 3 column 2. If no settings are specified by the DSO and the responsible party, the default settings for the reconnection after tripping of the interface protection are according to Table 3 column 3.</p> <p style="text-align: center;">Table 3 — Automatic reconnection after tripping</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Parameter</th> <th>Range</th> <th>Default setting</th> </tr> </thead> <tbody> <tr> <td>Lower frequency</td> <td>47,0Hz – 50,0Hz</td> <td>49,5Hz</td> </tr> <tr> <td>Upper frequency</td> <td>50,0Hz – 52,0Hz</td> <td>50,2Hz</td> </tr> <tr> <td>Lower voltage</td> <td>50% – 100%U_n</td> <td>85 % U_n</td> </tr> <tr> <td>Upper voltage</td> <td>100% – 120% U_n</td> <td>110 % U_n</td> </tr> <tr> <td>Observation time</td> <td>10s – 600s</td> <td>60s</td> </tr> <tr> <td>Active power increase gradient</td> <td>6% – 3000%/min</td> <td>10%/min</td> </tr> </tbody> </table>	Parameter	Range	Default setting	Lower frequency	47,0Hz – 50,0Hz	49,5Hz	Upper frequency	50,0Hz – 52,0Hz	50,2Hz	Lower voltage	50% – 100%U _n	85 % U _n	Upper voltage	100% – 120% U _n	110 % U _n	Observation time	10s – 600s	60s	Active power increase gradient	6% – 3000%/min	10%/min	(see appended table)	P
Parameter	Range	Default setting																						
Lower frequency	47,0Hz – 50,0Hz	49,5Hz																						
Upper frequency	50,0Hz – 52,0Hz	50,2Hz																						
Lower voltage	50% – 100%U _n	85 % U _n																						
Upper voltage	100% – 120% U _n	110 % U _n																						
Observation time	10s – 600s	60s																						
Active power increase gradient	6% – 3000%/min	10%/min																						
	After reconnection, the active power generated by the generating plant shall not exceed a specified gradient expressed as a percentage of the active nominal power of the unit per minute. If no gradient is specified by the DSO and the responsible party, the default setting is 10 % P _n /min. Generating modules for which it is technically not feasible to increase the power respecting the specified gradient over the full power range may connect after 1 min to 10 min (randomized value, uniformly distributed) or later.		P																					
4.10.3	Starting to generate electrical power		P																					

EN 50549-1																								
Clause	Requirement - Test	Result - Remark	Verdict																					
	<p>The frequency range, the voltage range, the observation time shall be adjustable in the range according to Table 4 column 2. If no settings are specified by the DSO and the responsible party, the default settings for connection or starting to generate electrical power due to normal operational startup or activity are according to Table 4 column 3.</p> <p style="text-align: center;">Table 4 — Starting to generate electrical power</p> <table border="1"> <thead> <tr> <th>Parameter</th> <th>Range</th> <th>Default setting</th> </tr> </thead> <tbody> <tr> <td>Lower frequency</td> <td>47,0Hz – 50,0Hz</td> <td>49,5Hz</td> </tr> <tr> <td>Upper frequency</td> <td>50,0Hz – 52,0Hz</td> <td>50,1Hz</td> </tr> <tr> <td>Lower voltage</td> <td>50% – 100% U_n</td> <td>85 % U_n</td> </tr> <tr> <td>Upper voltage</td> <td>100% – 120% U_n</td> <td>110 % U_n</td> </tr> <tr> <td>Observation time</td> <td>10s – 600s</td> <td>60s</td> </tr> <tr> <td>Active power increase gradient</td> <td>6% – 3000%/min</td> <td>disabled</td> </tr> </tbody> </table>	Parameter	Range	Default setting	Lower frequency	47,0Hz – 50,0Hz	49,5Hz	Upper frequency	50,0Hz – 52,0Hz	50,1Hz	Lower voltage	50% – 100% U _n	85 % U _n	Upper voltage	100% – 120% U _n	110 % U _n	Observation time	10s – 600s	60s	Active power increase gradient	6% – 3000%/min	disabled	(see appended table)	P
Parameter	Range	Default setting																						
Lower frequency	47,0Hz – 50,0Hz	49,5Hz																						
Upper frequency	50,0Hz – 52,0Hz	50,1Hz																						
Lower voltage	50% – 100% U _n	85 % U _n																						
Upper voltage	100% – 120% U _n	110 % U _n																						
Observation time	10s – 600s	60s																						
Active power increase gradient	6% – 3000%/min	disabled																						
	If applicable, the power gradient shall not exceed the maximum gradient specified by the DSO and the responsible party. Heat driven CHP generating units do not need to keep a maximum gradient, since the start up is randomized by the nature of the heat demand.		P																					
	For manual operations performed on site (e.g. for the purpose of initial start-up or maintenance) it is permitted to deviate from the observation time and ramp rate.		P																					
4.10.4	Synchronization		P																					
	Synchronizing a generating plant/unit with the distribution network shall be fully automatic i.e. it shall not be possible to manually close the switch between the two systems to carry out synchronization.		P																					
4.11.1	Ceasing active power		P																					
	Generating plants with a maximum capacity of 0,8 kW or more shall be equipped with a logic interface (input port) in order to cease active power output within five seconds following an instruction being received at the input port. If required by the DSO and the responsible party, this includes remote operation.	(see appended table)	P																					
4.11.2	Reduction of active power on set point		P																					
	For generating modules of type B, a generating plant shall be capable of reducing its active power to a limit value provided remotely by the DSO. The limit value shall be adjustable in the complete operating range from the maximum active power to minimum regulating level.		P																					
	The adjustment of the limit value shall be possible with a maximum increment of 10% of nominal power.		P																					

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	A generation unit/plant shall be capable of carrying out the power output reduction to the respective limit within an envelope of not faster than 0,66 % P _n / s and not slower than 0,33 % P _n / s with an accuracy of 5 % of nominal power. Generating plants are permitted to disconnect from the network at a limit value below its minimum regulating level. If required by the DSO, this includes remote operation.	(see appended table)	P
	NOTE Besides the requirements of this clause there might be other systems in place to control active power for reasons of market participation or local optimisation.		P
4.12	Remote information exchange		P
	Generating plants whose power is above a threshold to be determined by the DSO and the responsible party shall have the capacity to be monitored by the DSO or TSO control centre or control centres as well as receive operation parameter settings for the functions specified in this European Standard from the DSO or TSO control centre or control centres.		P
	It should not interact directly with the power generation equipment and the switching devices of the generating plant. It should interact with the operation and control system of the generating plant.		P
	In principle, standardized communication should be used. It is recommended that in case of using protocols for signal transmission used between the DSO or TSO control centre or control centres and the generating plant, relevant technical standards (e.g. EN 60870-5-101, EN 60870-5-104, EN 61850 and in particular EN 61850-7-4, EN 61850-7-420, IEC/TR 61850-90-7, as well as EN 61400-25 for wind turbines and relevant parts of IEC 62351 for relevant security measures) are recognized.		P
	Alternative protocols can be agreed between the DSO and the producer. These protocols include hardwired digital input/output and analogue input/output provided locally by DSO. The information needed for remote monitoring and the setting of configurable parameters are specific to each distribution network and to the way it is operated.		N/A
4.13	Requirements regarding single fault tolerance of interface protection system and interface switch	(see appended table)	P
	If required in 4.3.2, the interface protection system and the interface switch shall meet the requirements of single fault tolerance.		P
	A single fault shall not lead to a loss of the safety functions.		P
	NOTE This requirement for the detection of individual faults does not mean that all faults are detected. Accumulation of undetected faults can therefore lead to an unintentional output signal and result in a hazardous condition.		P

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Series-connected switches shall each have a independent breaking capacity corresponding to the rated current of the generating unit and corresponding to the short circuit contribution of the generating unit.		P
	The short-time withstand current of the switching devices shall be coordinated with maximum short circuit power at the connection point.		P
	At least one of the switches shall be a switch-disconnector suitable for overvoltage category 2. For single-phase generating units, the switch shall have one contact of this overvoltage category for both the neutral conductor and the line conductor. For poly-phase generating units, it is required to have one contact of this overvoltage category for all active conductors. The second switch may be formed of electronic switching components from an inverter bridge or another circuit provided that the electronic switching components can be switched off by control signals and that it is ensured that a failure is detected and leads to prevention of the operation at the latest at the next reconnection.		P
	For PV-inverters without simple separation between the network and the PV generating unit (e.g. PV Inverter without transformer) both switches mentioned in the paragraph above shall be switch disconnectors with the requirements described therein, although one switching device is permitted to be located between PV array and PV inverter.		P

Annex A	Interconnection guidance		P
Annex B	Void		Info.
Annex C	Parameter Table		P
Annex D	List of national requirements applicable for generating plants		Info.
Annex E	Loss of Mains and overall power system security		P
Annex F	Examples of protection strategies		Info.
Annex G	Abbreviations		Info.
Annex H	Relationship between this European standard and the COMMISSION REGULATION (EU) 2016/631		P
	Generating plants compliant with the clauses of this European Standard are considered to be compliant with the relevant Article of COMMISSION REGULATION (EU) 2016/631, provided, that all settings as provided by the DSO and the responsible party are complied with.		P

EN 50549-1																																																					
Clause	Requirement - Test	Result - Remark	Verdict																																																		
	<p align="center">Table H.1 – Correspondence between this European standard and the COMMISSION REGULATION (EU) 2016/631</p> <table border="1"> <thead> <tr> <th>Article</th> <th>Clause(s) / subclause(s) of this EN</th> </tr> </thead> <tbody> <tr><td>13.1(a)</td><td>4.4.2 Operating frequency range</td></tr> <tr><td>13.1(b)</td><td>4.5.2 Rate of change of frequency (ROCOF) immunity</td></tr> <tr><td>13.2</td><td>4.6.1 Power response to overfrequency</td></tr> <tr><td>13.3</td><td>4.4.3 Minimal requirement for active power delivery at underfrequency</td></tr> <tr><td>13.4</td><td>4.4.3 Minimal requirement for active power delivery at underfrequency</td></tr> <tr><td>13.5</td><td>4.4.3 Minimal requirement for active power delivery at underfrequency</td></tr> <tr><td>13.6</td><td>4.11.1 Ceasing active power</td></tr> <tr><td>13.7</td><td>4.10 Connection and starting to generate electrical power</td></tr> <tr><td>14.1</td><td>4.4.2, 4.5.2, 4.6.1, 4.4.3, 4.11.1 and 4.10</td></tr> <tr><td>14.2(a)</td><td>4.11.2 Reduction of active power on set point</td></tr> <tr><td>14.2(b)</td><td>4.12 Remote information exchange</td></tr> <tr><td>14.3</td><td>4.5.3 Under-voltage ride through (UVRT)</td></tr> <tr><td>14.4</td><td>4.10 Connection and starting to generate electrical power</td></tr> <tr><td>14.5(a)</td><td>4.6, 4.7, 4.9, 4.10, 4.11, 4.12</td></tr> <tr><td>14.5(b)</td><td>4.9 Interface protection,</td></tr> <tr><td>14.5(c)</td><td>4.1 General</td></tr> <tr><td>14.5(d)</td><td>4.12 Remote information exchange</td></tr> <tr><td>17.1</td><td>4. as applicable above</td></tr> <tr><td>17.2</td><td>4.7.2 Voltage support by reactive power</td></tr> <tr><td>17.3</td><td>4.5.3 Under-voltage ride through (UVRT)</td></tr> <tr><td>20.1</td><td>4. as applicable above</td></tr> <tr><td>20.2 (a)</td><td>4.7.2 Voltage support by reactive power</td></tr> <tr><td>20.2 (b) (c)</td><td>4.7.4.2 Short circuit current requirements on generating plants</td></tr> <tr><td>20.3</td><td>4.5.3 Under-voltage ride through (UVRT)</td></tr> </tbody> </table>	Article	Clause(s) / subclause(s) of this EN	13.1(a)	4.4.2 Operating frequency range	13.1(b)	4.5.2 Rate of change of frequency (ROCOF) immunity	13.2	4.6.1 Power response to overfrequency	13.3	4.4.3 Minimal requirement for active power delivery at underfrequency	13.4	4.4.3 Minimal requirement for active power delivery at underfrequency	13.5	4.4.3 Minimal requirement for active power delivery at underfrequency	13.6	4.11.1 Ceasing active power	13.7	4.10 Connection and starting to generate electrical power	14.1	4.4.2, 4.5.2, 4.6.1, 4.4.3, 4.11.1 and 4.10	14.2(a)	4.11.2 Reduction of active power on set point	14.2(b)	4.12 Remote information exchange	14.3	4.5.3 Under-voltage ride through (UVRT)	14.4	4.10 Connection and starting to generate electrical power	14.5(a)	4.6, 4.7, 4.9, 4.10, 4.11, 4.12	14.5(b)	4.9 Interface protection,	14.5(c)	4.1 General	14.5(d)	4.12 Remote information exchange	17.1	4. as applicable above	17.2	4.7.2 Voltage support by reactive power	17.3	4.5.3 Under-voltage ride through (UVRT)	20.1	4. as applicable above	20.2 (a)	4.7.2 Voltage support by reactive power	20.2 (b) (c)	4.7.4.2 Short circuit current requirements on generating plants	20.3	4.5.3 Under-voltage ride through (UVRT)		P
Article	Clause(s) / subclause(s) of this EN																																																				
13.1(a)	4.4.2 Operating frequency range																																																				
13.1(b)	4.5.2 Rate of change of frequency (ROCOF) immunity																																																				
13.2	4.6.1 Power response to overfrequency																																																				
13.3	4.4.3 Minimal requirement for active power delivery at underfrequency																																																				
13.4	4.4.3 Minimal requirement for active power delivery at underfrequency																																																				
13.5	4.4.3 Minimal requirement for active power delivery at underfrequency																																																				
13.6	4.11.1 Ceasing active power																																																				
13.7	4.10 Connection and starting to generate electrical power																																																				
14.1	4.4.2, 4.5.2, 4.6.1, 4.4.3, 4.11.1 and 4.10																																																				
14.2(a)	4.11.2 Reduction of active power on set point																																																				
14.2(b)	4.12 Remote information exchange																																																				
14.3	4.5.3 Under-voltage ride through (UVRT)																																																				
14.4	4.10 Connection and starting to generate electrical power																																																				
14.5(a)	4.6, 4.7, 4.9, 4.10, 4.11, 4.12																																																				
14.5(b)	4.9 Interface protection,																																																				
14.5(c)	4.1 General																																																				
14.5(d)	4.12 Remote information exchange																																																				
17.1	4. as applicable above																																																				
17.2	4.7.2 Voltage support by reactive power																																																				
17.3	4.5.3 Under-voltage ride through (UVRT)																																																				
20.1	4. as applicable above																																																				
20.2 (a)	4.7.2 Voltage support by reactive power																																																				
20.2 (b) (c)	4.7.4.2 Short circuit current requirements on generating plants																																																				
20.3	4.5.3 Under-voltage ride through (UVRT)																																																				

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Test overview:**EN 50549-1:2019**

4.4.2	Operating frequency range		P
4.4.3	Minimal requirement for active power delivery at under-frequency		P
4.4.4	Continuous operating voltage range		P
4.5.2	Rate of change of frequency (ROCOF) immunity		P
4.5.3	Under-voltage ride through (UVRT)		P
4.5.4	Over-voltage ride through (OVRT)		P
4.6.1	Power response to under-frequency		P
4.6.2	Power response to over-frequency		P
4.7.2	Voltage support by reactive power		P
4.7.2.3.2	Setpoint control modes – Q setpoint mode		P
4.7.2.3.2	Setpoint control modes – Cos ϕ setpoint mode		P
4.7.2.3.3	Voltage related control mode – Q(U)		P
4.7.2.3.4	Power related control mode – cos ϕ (P)		P
4.7.3	Voltage related active power reduction		P
4.7.4	Short circuit current requirements on generating plants		N/A
4.8	EMC and power quality		P
4.9.3	Requirements on voltage and frequency protection		P
4.9.3.2	Under-voltage protection		P
4.9.3.3	Overvoltage protection		P
4.9.3.4	Overvoltage 10 min mean protection		P
4.9.3.5	Underfrequency protection		P
4.9.3.6	Overfrequency protection		P
4.9.4	Means to detect island situation		P
4.9.5	Digital input to the interface protection		P
4.10.2	Automatic reconnection after tripping		P
4.10.3	Starting to generate electrical power		P
4.11.1	Ceasing active power		P
4.11.2	Reduction of active power on set point		P
4.13	Requirements regarding single fault tolerance of interface protection system		P

EN 50549-1					
Clause	Requirement - Test			Result - Remark	Verdict
4.4.2	TABLE: Operating frequency range – B: Stringent requirement				P
Model	AIO2-INS-5000				
Test sequence	Frequency [Hz]	Voltage [V]	Output power [W]	Time period measured	Time period Required
Test 1	47.1Hz	223.68	5006.78	30 s	> 20 s
Test 2	47.6Hz	233.77	5007.26	100min	> 90 min
Test 3	48.6Hz	233.76	5006.33	106.4min	> 90 min
Test 4	49.1Hz	233.72	4950.44	125.8min	Unlimited
Test 5	50.9Hz	233.73	4946.18	134.93min	Unlimited
Test 6	51.4Hz	233.74	5011.44	102.47min	> 90 min
Test 7	51.9Hz	233.77	5007.63	20min	> 15 min
<p>Note:</p> <p>Respecting the legal framework, it is possible that longer time periods are required by the responsible party in some synchronous areas.</p>					

EN 50549-1				
Clause	Requirement - Test	Result - Remark	Verdict	
4.4.3	TABLE: Minimal requirement for active power delivery at under-frequency			P
Model	AIO2-INS-5000			
Voltage	230Vac			
Test sequence	Frequency [Hz]	Output power [W]	$\Delta P/P_M$ per 1 Hz	Reduction rate limits
Test a)	50.0Hz	4953.81	0%	0%
Test b)	49.6Hz	4956.76	0%	0%
Test c)	47.6Hz	4956.09	0%	10%
<p>Test:</p> <p>The test must be carried out at 100% P_n, Measurements are carried out at the following operating points: a) nominal frequency ± 0.01 Hz; b) a point between the nominal frequency -0.4 Hz to -0.5 Hz; c) a point between the nominal frequency -2.4 Hz to -2.5 Hz. The operating point b) and c) shall be maintained for at least 5 min, sample rate: 1 s.</p>				
<p>Assessment criterion:</p> <p>The test is regarded as passed if:</p> <ul style="list-style-type: none"> the inverter does not disconnect from the network at the operating Points a) to c) when the network frequency is changed and the inverter does not reduce output energy at Point b) and the power reduction in point c) is less or equal to the allowed power reduction according to 4.4.3. 				

EN 50549-1				
Clause	Requirement - Test		Result - Remark	Verdict
4.4.4	TABLE: Continuous operating voltage range			P
Model	AIO2-INS-5000			
Operation range	85% ~ 110%			
Frequency	50Hz			
Test 1	1.10Un			
Test sequence	Voltage(V)	Output power(W)	Time period measured	Time period Limited
Single Phase	253.16	4989.05	> 30 min	Operating continuously
Test 2	0.85Un			
Test sequence	Voltage(V)	Output power(W)	Time period measured	Time period Limited
Single Phase	195.47	4379.48	> 30 min	Operating continuously
Note: I In case of voltages below Un, it is allowed to reduce the active power due to the current limits of the generator.				

EN 50549-1					
Clause	Requirement - Test			Result - Remark	Verdict
4.5.2	TABLE: Rate of change of frequency (ROCOF) immunity				P
Model	AIO2-INS-5000				
Voltage(V)	230 Vac				
Primary Power(W)	5000				
	Frequency		Change time	Result (disconnect or not)	Requirement
	Begin	End			
a)	47.50 Hz	51.5 Hz	2.0 s	Not disconnect	Stay connected
b)	51.50 Hz	47.5 Hz	2.0 s	Not disconnect	Stay connected
Note: The ROCOF immunity is defined with a sliding measurement window of 500 ms.					


EN 50549-1							
Clause	Requirement - Test				Result - Remark		Verdict
4.5.3 & 4.5.4	TABLE: Under-voltage ride through (UVRT)& Over-voltage ride through (OVRT)-Refer to the testing guide line DIN VDE V 0124-100:2020-06						P
Test number	Type of the fault	Required fault depth /duration [p.u.], [ms]	Measured fault duration [ms]	Average remaining voltage [p.o.s]	Percent of current after fault 60 ms [%Ir]	Percent of current after fault 100 ms [%Ir]	Duration of restoring [ms]
1.1	three-phase SC	0.15 / 150	158.59	34.45	0.14	0.14	238.71
1.2	three-phase SC	0.15 / 150	150.15	34.60	0.14	0.14	501.98
1.3	two-phase SC	0.15 / 150	150.47	98.30	0.55	0.55	238.32
1.4	two-phase SC	0.15 / 150	153.19	98.26	0.55	0.55	518.74
1.5	two-phase SC	0.15 / 150	169.29	98.07	0.54	0.54	249.29
2.1	three-phase SC	0.50 / 1500	1574.66	115.81	0.44	0.44	274.25
2.2	three-phase SC	0.50 / 1500	1564.14	115.72	0.44	0.44	524.87
2.3	two-phase SC	0.50 / 1500	1500.50	153.08	0.67	0.67	243.94
2.4	two-phase SC	0.50 / 1500	1570.01	152.99	0.67	0.67	512.02
3.1	three-phase SC	0.50 / 1500	1569.28	114.91	0.44	0.44	264.42
3.2	three-phase SC	0.50 / 1500	1571.29	114.97	0.44	0.44	535.59
3.3	two-phase SC	0.50 / 1500	1501.62	152.19	0.67	0.67	244.44
3.4	two-phase SC	0.50 / 1500	1574.66	152.47	0.67	0.67	307.17
4.1	three-phase SC	0.85 / 60000	60075.64	195.54	--	--	--
4.2	three-phase SC	0.85 / 60000	60132.25	195.46	--	--	--
4.3	two-phase SC	0.85 / 60000	60107.53	207.57	--	--	--
4.4	two-phase SC	0.85 / 60000	60048.13	207.54	--	--	--
5.1	three-phase SC	1.25 / 100	100.01	286.74	1.09	1.13	252.43
5.2	three-phase SC	1.25 / 100	101.28	286.79	1.09	1.13	304.74
5.3	two-phase SC	1.25 / 100	100.59	258.93	--	--	--
5.4	two-phase SC	1.25 / 100	101.01	257.39	6.02	5.95	237.28
5.5	two-phase SC	1.25 / 100	100.85	258.95	--	--	--
6.1	three-phase SC	1.20 / 5000	5149.57	275.48	1.05	1.05	240.84
6.2	three-phase SC	1.20 / 5000	5162.39	274.48	1.05	1.05	500.25

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.5.3 & 4.5.4	TABLE: Under-voltage ride through (UVRT)& Over-voltage ride through (OVRT)-Refer to the testing guide line DIN VDE V 0124-100:2020-06						P
6.3	two-phase SC	1.20 / 5000	5162.06	253.12	--	--	--
6.4	two-phase SC	1.20 / 5000	5163.50	253.07	--	--	--
7.1	three-phase SC	1.15 / 60000	60112.81	264.34	--	--	--
7.2	three-phase SC	1.15 / 60000	60095.96	264.10	--	--	--
7.3	two-phase SC	1.15 / 60000	60118.02	247.40	--	--	--
7.4	two-phase SC	1.15 / 60000	60154.35	247.29	--	--	--

Note: The following conditions apply to all Type 2 power generation units and storage systems:

As long as the line-to-neutral voltages at the generator terminals applied to the power generation unit or the storage are within the limit curves shown in Figure 12 (red for the under-voltage limit curve and blue for the over-voltage limit curve), there must be no instability of the power generation unit and the storage system in the entire operating range of the power generation unit or the storage system and no disconnection from the network.



To assess the curves, the smallest of the line-to-neutral voltages applied to the power generation unit and/or the storage system must be used in case of a voltage drop, and the largest of the line-to-neutral voltages applied to the power generation unit or the storage must be used in case of a rise-in-voltage. If the setting values for NS protection according to Table 2 (column inverter) anticipate the requirements according to Figure 12 in certain working points, only the NS protection setting values at these working points need to be checked in the verification procedure.

If the voltage at the generator terminals falls below $0.8 U_n$ and if the voltage at the generator terminals exceeds $1.15 U_n$ (start of fault), Type 2 power generation units and storage systems must operate through voltage drops without feeding a current into the network of the network operator (limited dynamic network support).



This requirement is fulfilled if a voltage drop below $0.8 U_n$ and/or in the event of a rise-in-voltage above $1.15 U_n$ the fed in power by the power generation unit(s) and/or storage system(s) does not exceed 20% of the rated current I_r in any individual line 60 ms after the occurrence of this voltage drop and does not exceed 10% after 100 ms I_r in any individual line.

Performance after the end of the fault:

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.5.3 & 4.5.4	TABLE: Under-voltage ride through (UVRT)& Over-voltage ride through (OVRT)-Refer to the testing guide line DIN VDE V 0124-100:2020-06		P
<p>If the mains voltage after the end of the fault is again within the voltage range of $-15\% U_n$ to $+10\% U_n$ and the active current of the power generation unit and/or the storage system has been reduced during the network fault, it must be increased to the pre-fault value as soon as possible after the end of the fault. The response time must not exceed 1 s. The reactive power provision follows the time performance according to 5.7.2.5. For rotating machines, the response time must not exceed 6 s.</p> <p>Up to 60 s after the fault has started, the power generation units and storage systems must not disconnect from the network at voltages up to $1.15 U_n$. If tripping of the self-protection of the power generation units and/or the storage systems is imminent, then these power generation units and storage systems may adapt their reactive power performance to such an extent that a tripping of the self-protection is avoided.</p> <p>REMARK By controlling the transformer phase position on the upstream HS/MS transformer of the network operator, it can be assumed that the operating voltage of the low-voltage network after 60 s at the latest is within the voltage range of $-15\% U_n$ to $+10\% U_n$.</p> <p>Note: A change of the instantaneous voltage from 90% to 10% of the pre-fault voltage should be made with UVRT within a period of max. 4 ms.(DIN VDE V 0124-100:2020-06 Appendix A)</p>			



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1.2
Depth of fault phase:15% Un, three-phase SC(type A), 20% load





Test 1.2
Depth of fault phase:15%Un, three-phase SC(type A), 20% load, restoring time



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Test 1.3

Depth of fault phase:15%Un, two-phase SC(type D1), 100% load





Test 1.3

Depth of fault phase:15%Un, two-phase SC(type D1), 100% load, restoring time



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1.4
Depth of fault phase:15%Un, two-phase SC(type D1), 20% load





Test 1.4
Depth of fault phase:15%Un, two-phase SC(type D1), 20% load, restoring time



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1.5
Depth of fault phase:15%Un, two-phase SC(type D2), 100% load





Test 1.5
Depth of fault phase:15%Un, two-phase SC(type D2), 100% load, restoring time





EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2.1
Depth of fault phase:50%Un, three-phase SC(type A), 100% load, Current after fault 60ms, Q max




Test 2.1
Depth of fault phase:50%Un, three-phase SC(type A), 100% load, Current after fault 100ms, Q max




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2.2
Depth of fault phase:50%Un, three-phase SC(type A), 20% load, Q max





Test 2.2
Depth of fault phase:50%Un, three-phase SC(type A), 20% load, restoring time, Q max



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2.3
Depth of fault phase:50%Un, two-phase SC(type D1), 100% load, Q max



Test 2.3
Depth of fault phase:50%Un, two-phase SC(type D1), 100% load, restoring time, Q max




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Test 2.3

Depth of fault phase:50%Un, two-phase SC(type D1), 100% load, Current after fault 60ms, Q max



Test 2.3


Depth of fault phase:50%Un, two-phase SC(type D1), 100% load, Current after fault 100ms, Q max




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2.4
Depth of fault phase:50%Un, two-phase SC(type D1), 20% load, Q max




Test 2.4
Depth of fault phase:50%Un, two-phase SC(type D1), 20% load, restoring time, Q max




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2.4
Depth of fault phase:50%Un, two-phase SC(type D1), 20% load, Current after fault 60ms, Q max




Test 2.4
Depth of fault phase:50%Un, two-phase SC(type D1), 20% load, Current after fault 100ms, Q max




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3.1
Depth of fault phase: 50%Un, three-phase SC(type A), 100% load, Q min




Test 3.1
Depth of fault phase: 50%Un, three-phase SC(type A), 100% load, restoring time, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3.1
Depth of fault phase: 50%Un, three-phase SC(type A), 100% load, Current after fault 60ms, Q min



Test 3.1
Depth of fault phase: 50%Un, three-phase SC(type A), 100% load, Current after fault 100ms, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Test 3.2

Depth of fault phase: 50%Un, three-phase SC(type A), 20% load, Q min



Test 3.2


Depth of fault phase: 50%Un, three-phase SC(type A), 20% load, restoring time, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3.2
Depth of fault phase: 50%Un, three-phase SC(type A), 20% load, Current after fault 60ms, Q min




Test 3.2
Depth of fault phase: 50%Un, three-phase SC(type A), 20% load, Current after fault 100ms, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3.3
Depth of fault phase: 50%Un, two-phase SC(type D1), 100% load, Q min



Test 3.3
Depth of fault phase: 50%Un, two-phase SC(type D1), 100% load, restoring time, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Test 3.3

Depth of fault phase: 50%Un, two-phase SC(type D1), 100% load, Current after fault 60ms, Q min



Test 3.3


Depth of fault phase: 50%Un, two-phase SC(type D1), 100% load, Current after fault 100ms, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3.4
Depth of fault phase: 50%Un, two-phase SC(type D1), 20% load, Q min




Test 3.4
Depth of fault phase: 50%Un, two-phase SC(type D1), 20% load, restoring time, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3.4
Depth of fault phase: 50%Un, two-phase SC(type D1), 20% load, Current after fault 60ms, Q min




Test 3.4
Depth of fault phase: 50%Un, two-phase SC(type D1), 20% load, Current after fault 100ms, Q min




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4.1
Depth of fault phase:85%Un, three-phase SC(type A), 100% load




Test 4.1
Depth of fault phase: 85%Un, three-phase SC(type A), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4.2
Depth of fault phase: 85%Un, three-phase SC(type A), 20% load




Test 4.2
Depth of fault phase: 85%Un, three-phase SC(type A), 20% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4.3
Depth of fault phase: 85%Un, two-phase SC(type D1), 100% load




Test 4.3
Depth of fault phase: 85%Un, two-phase SC(type D1), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4.4
Depth of fault phase: 85%Un, two-phase SC(type D1), 20% load




Test 4.4
Depth of fault phase: 85%Un, two-phase SC(type D1), 20% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.1
Depth of fault phase:125%Un, three-phase SC(type A), 100% load




Test 5.1
Depth of fault phase:125%Un, three-phase SC(type A), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.1
Depth of fault phase:125%Un, three-phase SC(type A), 100% load, Current after fault 60ms




Test 5.1
Depth of fault phase:125%Un, three-phase SC(type A), 100% load, Current after fault 100ms




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.1
Depth of fault phase:125%Un, three-phase SC(type A), 100% load, Current after fault 60ms





Test 5.1
Depth of fault phase:125%Un, three-phase SC(type A), 100% load, Current after fault 100ms



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.2
Depth of fault phase:125%Un, three-phase SC(type A), 20% load, Current after fault 60ms




Test 5.2
Depth of fault phase:125%Un, three-phase SC(type A), 20% load, Current after fault 100ms




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.3
Depth of fault phase:125%Un, two-phase SC(type D1), 100% load




Test 5.3
Depth of fault phase:125%Un, two-phase SC(type D1), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.4
Depth of fault phase:125%Un, two-phase SC(type D), 20% load




Test 5.4
Depth of fault phase:125%Un, two-phase SC(type D), 20% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.4
Depth of fault phase:125%Un, two-phase SC(type D), 20% load, Current after fault 60ms




Test 5.4
Depth of fault phase:125%Un, two-phase SC(type D), 20% load, Current after fault 100ms




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5.5
Depth of fault phase:125%Un, two-phase SC(type D2), 100% load




Test 5.5
Depth of fault phase:125%Un, two-phase SC(type D2), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6.1
Depth of fault phase:120%Un, three-phase SC(type A), 100% load





Test 6.1
Depth of fault phase:120%Un, three-phase SC(type A), 100% load, restoring time



EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6.2
Depth of fault phase:120%Un, three-phase SC(type A), 20% load




Test 6.2
Depth of fault phase:120%Un, three-phase SC(type A), 20% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6.2
Depth of fault phase:120%Un, three-phase SC(type A), 20% load, Current after fault 60ms




Test 6.2
Depth of fault phase:120%Un, three-phase SC(type A), 20% load, Current after fault 100ms




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6.3
Depth of fault phase:120%Un, two-phase SC(type D1), 100% load



Test 6.3
Depth of fault phase:120%Un, two-phase SC(type D1), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Test 6.4

Depth of fault phase:120%Un, two-phase SC(type D1), 20% load



Test 6.4


Depth of fault phase:120%Un, two-phase SC(type D1), 20% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7.1
Depth of fault phase:115%Un, three-phase SC(type A), 100% load




Test 7.1
Depth of fault phase:115%Un, three -phase SC(type A), 100% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7.2
Depth of fault phase:115%Un, three-phase SC(type A), 20% load




Test 7.2
Depth of fault phase:115%Un, three -phase SC(type A), 20% load, restoring time




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7.2
Depth of fault phase:115%Un, three-phase SC(type A), 20% load, Current after fault 60ms




Test 7.2
Depth of fault phase:115%Un, three-phase SC(type A), 20% load, Current after fault 100ms




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7.3
Depth of fault phase:115%Un, two-phase SC(type D1), 100% load





Test 7.3
Depth of fault phase:115%Un, two-phase SC(type D1), 100% load, restoring time



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve A, f_{stop} = deactivated)				P
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode				
1. Starting active power = 100% $P_{E_{\text{max}}}$			P_M [W]	5000	
s = 5%	$f_1 = 50.2$ Hz		$P_{\text{ref}} = P_M$		
Frequency set point [Hz]	Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{\text{ref}}$ [%]	Target $\Delta P/P_{\text{ref}}$ [%]	
Frequency increase step	50.00	50.00	4927.99	-1.44	0
	50.20	50.20	4927.54	-1.45	0
	50.40	50.40	4600.73	-7.99	-8
	50.60	50.60	4213.11	-15.74	-16
	50.80	50.80	3832.86	-23.34	-24
	51.00	51.00	3443.64	-31.13	-32
	51.20	51.20	3049.79	-39.00	-40
	51.40	51.40	2658.86	-46.82	-48
Frequency restore step	51.40	51.40	2658.86	-46.82	-48
	51.20	51.20	3049.18	-39.02	-40
	51.00	51.00	3437.47	-31.25	-32
	50.80	50.80	3831.71	-23.37	-24
	50.60	50.60	4216.76	-15.66	-16
	50.40	50.40	4589.68	-8.21	-8
	50.20	50.20	4920.62	-1.59	0
	50.00	50.00	4927.12	-1.46	0


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve A, f_{stop} = deactivated)				P
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode				
2. Starting active power between 40% P_{Emax} and 60% P_{Emax}			P_{M} [W]	2500	
$s = 5\%$	$f_1 = 50.2$ Hz		$P_{\text{ref}} = P_{\text{M}}$		
Frequency set point [Hz]	Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{\text{ref}}$ [%]	Target $\Delta P/P_{\text{ref}}$ [%]	
Frequency increase step	50.00	50.00	2504.78	0.19	0
	50.20	50.20	2504.72	0.19	0
	50.40	50.40	2326.79	-6.93	-8
	50.60	50.60	2133.59	-14.66	-16
	50.80	50.80	1940.82	-22.37	-24
	51.00	51.00	1750.07	-30.00	-32
	51.20	51.20	1552.73	-37.89	-40
	51.40	51.40	1358.41	-45.66	-48
Frequency restore step	51.40	51.40	1358.41	-45.66	-48
	51.20	51.20	1553.72	-37.85	-40
	51.00	51.00	1754.48	-29.82	-32
	50.80	50.80	1941.71	-22.33	-24
	50.60	50.60	2131.28	-14.75	-16
	50.40	50.40	2323.55	-7.06	-8
	50.20	50.20	2496.48	-0.14	0
	50.00	50.00	2502.12	0.09	0


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Power response to over-frequency (curve A, f_{stop} = deactivated) -100% P_{Emax}



Power response to over-frequency (curve A, f_{stop} = deactivated) -50% P_{Emax}





EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve A, f_{stop} = deactivated)				P
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode				
3. Starting active power = 100% $P_{E_{max}}$			P_M [W]	4379.89	
s = 5%		$f_1 = 50.2$ Hz		$P_{ref} = P_M$	
Frequency set point [Hz]		Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{ref}$ [%]	Target $\Delta P/P_{ref}$ [%]
Frequency increase step	50.00	50.00	4379.89	0	0
	50.20	50.20	4373.60	-0.14	0
	50.40	50.40	4049.24	-7.55	-8
	50.60	50.60	3701.20	-15.50	-16
	50.80	50.80	3353.34	-23.44	-24
	51.00	51.00	3000.66	-31.49	-32
	51.20	51.20	2655.16	-39.38	-40
	51.40	51.40	2307.35	-47.32	-48
Frequency restore step	51.40	51.40	2307.35	-47.32	-48
	51.20	51.20	2655.48	-39.37	-40
	51.00	51.00	3003.23	-31.43	-32
	50.80	50.80	3353.01	-23.45	-24
	50.60	50.60	3701.11	-15.50	-16
	50.40	50.40	4050.37	-7.52	-8
	50.20	50.20	4314.64	-1.49	0
	50.00	50.00	4314.85	-1.48	0

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve A, f_{stop} = deactivated)				P
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode				
4. Starting active power between 40% $P_{E_{max}}$ and 60% $P_{E_{max}}$			P_M [W]	2493.85	
$s = 5\%$	$f_1 = 50.2$ Hz		$P_{ref} = P_M$		
Frequency set point [Hz]	Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{ref}$ [%]	Target $\Delta P/P_{ref}$ [%]	
Frequency increase step	50.00	50.00	2493.85	0	0
	50.20	50.20	2492.05	-0.07	0
	50.40	50.40	2304.07	-7.61	-8
	50.60	50.60	2107.87	-15.48	-16
	50.80	50.80	1909.80	-23.42	-24
	51.00	51.00	1713.40	-31.30	-32
	51.20	51.20	1515.59	-39.23	-40
	51.40	51.40	1319.46	-47.09	-48
Frequency restore step	51.40	51.40	1319.46	-47.09	-48
	51.20	51.20	1516.37	-39.20	-40
	51.00	51.00	1713.53	-31.29	-32
	50.80	50.80	1910.00	-23.41	-24
	50.60	50.60	2106.74	-15.52	-16
	50.40	50.40	2304.54	-7.59	-8
	50.20	50.20	2482.12	-0.47	0
	50.00	50.00	2481.04	-0.51	0

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve B, $f_{\text{stop}} = 50.1\text{Hz}$)				P
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode				
5. Starting active power = 100% $P_{E_{\text{max}}}$			P_M [W]	5000	
$s = 5\%$		$f_1 = 50.2\text{ Hz}$		$t_{\text{stop}} = 30\text{ s}$	
Frequency set point [Hz]	Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{\text{ref}}$ [%]	Target $\Delta P/P_{\text{ref}}$ [%]	
Frequency increase step	50.00	50.00	5031.31	0.63	0
	50.20	50.20	5030.45	0.61	0
	50.40	50.40	4677.59	-6.45	-8
	50.60	50.60	4286.96	-14.26	-16
	50.80	50.80	3896.15	-22.08	-24
	51.00	51.00	3499.10	-30.02	-32
	51.20	51.20	3096.20	-38.08	-40
	51.40	51.40	2699.94	-46.00	-48
Frequency restore step	51.40	51.40	2699.94	-46.00	-48
	51.20	51.20	2702.39	-45.95	-48
	51.00	51.00	2697.08	-46.06	-48
	50.80	50.80	2703.52	-45.99	-48
	50.60	50.60	2696.74	-46.07	-48
	50.40	50.40	2701.59	-45.97	-48
	50.20	50.20	2701.54	-45.97	-48
	50.00	50.00	5029.34	0.59	-48% -> 0


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve B, $f_{\text{stop}} = 50.1\text{Hz}$)				P
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode				
6. Starting active power = 100% $P_{E_{\text{max}}}$			P_M [W]	5000	
$s = 5\%$		$f_1 = 50.2\text{ Hz}$		$t_{\text{stop}} = 30\text{ s}$	
	Frequency set point [Hz]	Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{\text{ref}}$ [%]	Target $\Delta P/P_{\text{ref}}$ [%]
Frequency increase step	50.00	50.00	5030.16	0.60	0
	50.10	50.10	5026.88	0.54	0
	50.20	50.20	5028.55	0.57	0
	50.30	50.30	4843.12	-3.14	-4
	50.40	50.40	4654.60	-6.91	-8
	50.50	50.50	4453.43	-10.93	-12
	50.60	50.60	4259.45	-14.81	-16
	50.70	50.70	4070.56	-18.56	-20
Frequency restore step	50.70	50.70	4070.56	-18.56	-20
	50.60	50.60	4067.65	-18.65	-20
	50.50	50.50	4068.74	-18.63	-20
	50.40	50.40	4070.65	-18.59	-20
	50.30	50.30	4068.21	-18.64	-20
	50.20	50.20	4069.52	-18.61	-20
	50.10	50.10	5025.96	0.52	-20*
	50.00	50.00	5027.59	0.55	-20 -> 0
Note: *value for first 30 s					


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Power response to over-frequency (curve B, $f_{stop} = 50.1\text{Hz}$)-100% P_{Emax}



Power response to over-frequency (curve B, $f_{stop} = 50.1\text{Hz}$)-100% P_{Emax}





EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve B, $f_{\text{stop}} = 50.1\text{Hz}$)				P
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode				
7. Starting active power = 100% $P_{E_{\text{max}}}$			P_M [W]	4326.26	
$s = 5\%$		$f_1 = 50.2$ Hz		$t_{\text{stop}} = 30$ s	
Frequency set point [Hz]		Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{\text{ref}}$ [%]	Target $\Delta P/P_{\text{ref}}$ [%]
Frequency increase step	50.00	50.00	4326.26	0	0
	50.20	50.20	4310.04	-0.38	0
	50.40	50.40	4000.68	-7.53	-8
	50.60	50.60	3652.98	-15.56	-16
	50.80	50.80	3309.64	-23.50	-24
	51.00	51.00	2970.03	-31.35	-32
	51.20	51.20	2626.58	-39.29	-40
	51.40	51.40	2285.97	-47.16	-48
Frequency restore step	51.40	51.40	2285.97	-47.16	-48
	51.20	51.20	2262.85	-47.70	-48
	51.00	51.00	2260.37	-47.75	-48
	50.80	50.80	2261.83	-47.72	-48
	50.60	50.60	2261.45	-47.73	-48
	50.40	50.40	2262.65	-47.70	-48
	50.20	50.20	2262.72	-47.70	-48
	50.00	50.00	4267.09	-1.37	-48% -> 0

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.6.1	TABLE: Power response to over-frequency (curve B, $f_{\text{stop}} = 50.1\text{Hz}$)				P
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode				
8. Starting active power = 100% $P_{E_{\text{max}}}$			P_M [W]	4363.02	
s = 5%		$f_1 = 50.2$ Hz		$t_{\text{stop}} = 30$ s	
Frequency set point [Hz]		Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{\text{ref}}$ [%]	Target $\Delta P/P_{\text{ref}}$ [%]
Frequency increase step	50.00	50.00	4363.02	0	0
	50.10	50.10	4349.49	-0.31	0
	50.20	50.20	4345.28	-0.41	0
	50.30	50.30	4182.91	-4.13	-4
	50.40	50.40	4008.65	-8.12	-8
	50.50	50.50	3831.64	-12.18	-12
	50.60	50.60	3662.64	-16.05	-16
	50.70	50.70	3490.83	-19.99	-20
Frequency restore step	50.70	50.70	3490.83	-19.99	-20
	50.60	50.60	3489.92	-20.01	-20
	50.50	50.50	3490.89	-19.99	-20
	50.40	50.40	3491.38	-19.98	-20
	50.30	50.30	3491.78	-19.97	-20
	50.20	50.20	3491.49	-19.98	-20
	50.10	50.10	4272.84	-2.07	-20*
	50.00	50.00	4266.22	-2.98	-20 -> 0
Note: *value for first 30 s					

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict


4.6.2	TABLE: Power response to under-frequency					P
Model	AIO2-INS-5000@Working in battery discharge and PV mode					
Measurement: Starting active power output = 10% P _{max} for inverter						
s = 5 %		f ₁ = 49.8 Hz		P _{ref} [W]: 500		
Frequency set point [Hz]		Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{ref}$ [%]	Target $\Delta P/P_{ref}$ [%]	Disconnect or not
Frequency decrease step	50.00	50.00	499.55	0	-0.01	No
	49.80	49.80	499.36	0	-0.01	No
	49.60	49.60	860.26	-8	-7.21	No
	49.40	49.40	1270.53	-16	-15.41	No
	49.20	49.20	1662.49	-24	-23.25	No
	49.00	49.00	2077.67	-32	-31.55	No
	48.80	48.80	2490.06	-40	39.80	No
	48.60	48.60	2893.31	-48	-47.87	No
	48.40	48.40	3305.29	-56	-56.11	No
	48.20	48.20	3701.54	-64	-64.03	No
	48.00	48.00	4123.42	-72	-72.47	No
	47.80	47.80	4523.96	-80	-80.48	No
Frequency restore step	47.60	47.60	4935.40	-88	-88.71	No
	47.80	47.80	4528.60	-80	-80.57	No
	48.00	48.00	4118.97	-72	-72.38	No
	48.20	48.20	3712.41	-64	-64.25	No
	48.40	48.40	3302.71	-56	-56.05	No
	48.60	48.60	2896.54	-48	-47.93	No
	48.80	48.80	2488.01	-40	-39..76	No
	49.00	49.00	2085.50	-32	-31.71	No
	49.20	49.20	1676.36	-24	-23.53	No
	49.40	49.40	1273.86	-16	-15.48	No
	49.60	49.60	844.07	-8	-6.88	No
	49.80	49.80	465.50	0	-0.69	No
50.00	50.00	482.68	0	-0.35	No	
Limit $\Delta P_{E60}/P_{ref}$:		± 10% of P _{ref}				

EN 50549-1						
Clause	Requirement - Test			Result - Remark		Verdict
4.6.2	TABLE: Power response to under-frequency					P
Model	AIO2-INS-5000@Work from the grid charge the battery mode to battery discharge mode					
Measurement: Starting active power output = 50% P _A of charging state for EESS.						
s = 5 %		f ₁ = 49.8 Hz		P _{ref} [W]: 2560.56		
Frequency set point [Hz]		Measured frequency [Hz]	Power output [W]	Measured $\Delta P/P_{ref}$ [%]	Target $\Delta P/P_{ref}$ [%]	Disconnect or not
Frequency decrease step	50.00	50.00	-2555.90	0	0	No
	49.80	49.80	-2558.34	0	0.05	No
	49.60	49.60	-2203.15	-8	-7.06	No
	49.40	49.40	-1801.52	-16	-15.09	No
	49.20	49.20	-1403.28	-24	-23.05	No
	49.00	49.00	-1000.75	-32	-31.10	No
	48.80	48.80	-615.77	-40	-38.80	No
	48.60	48.60	-233.75	-48	-46.44	No
	48.40	48.40	170.32	-56	-54.52	No
	48.20	48.20	549.25	-64	-62.10	No
	48.00	48.00	962.95	-72	-70.38	No
	47.80	47.80	1369.54	-80	-78.51	No
Frequency restore step	47.60	47.60	1763.93	-88	-86.40	No
	47.80	47.80	1365.20	-80	-78.42	No
	48.00	48.00	976.42	-72	-70.65	No
	48.20	48.20	578.71	-64	-62.69	No
	48.40	48.40	170.70	-56	-54.53	No
	48.60	48.60	-242.35	-48	-46.27	No
	48.80	48.80	-622.15	-40	-38.68	No
	49.00	49.00	-1006.68	-32	-30.98	No
	49.20	49.20	-1412.41	-24	-22.87	No
	49.40	49.40	-1814.10	-16	-14.84	No
	49.60	49.60	-2199.74	-8	-7.12	No
	49.80	49.80	-2604.81	0	0.98	No
50.00	50.00	-2562.35	0	0.13	No	
Limit $\Delta P_{E60}/P_{ref}$:		$\pm 10\%$ of P _{ref}				


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Starting active power output = 10% P_{max} for inverter



Inverter or 50% P_A of charging state for EESS



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.7.2.2 4.7.2.3.2	TABLE: Setpoint control modes – Q setpoint mode					P
Model	AIO2-INS-5000					
Inductive supply reactive power						
Rating power [%]	Active power [W]	Reactive Power [Var]	Setpoint-Q/P _D [%]	Power factor [cos φ]	Voltage [V]	
0% - 10%	524.83	2165.06	48.11	0.52	230.40	
10% - 20%	996.32	2162.78	48.06	0.51	230.55	
20% - 30%	1498.72	2111.57	46.92	0.58	230.55	
30% - 40%	1999.46	2122.23	47.16	0.69	230.53	
40% - 50%	2506.79	2122.77	47.17	0.76	230.44	
50% - 60%	3003.61	2125.22	47.23	0.82	230.31	
60% - 70%	3500.60	2124.09	47.20	0.85	230.36	
70% - 80%	3994.37	2122.41	47.16	0.88	230.49	
80% - 90%	4494.25	2120.01	47.11	0.90	230.79	
90% - 100%	4581.87	2140.39	47.56	0.91	230.30	

EN 50549-1					
Clause	Requirement - Test			Result - Remark	Verdict
Capacitive supply reactive power					
Rating power [%]	Active power [W]	Reactive Power [Var]	Setpoint-Q/P _D [%]	Power factor [cos φ]	Voltage [V]
0% - 10%	522.49	-2178.29	-48.41	0.51	230.12
10% - 20%	993.45	-2149.82	-47.77	0.50	230.38
20% - 30%	1496.18	-2137.39	-47.50	0.57	230.14
30% - 40%	1997.86	-2150.41	-47.79	0.68	230.47
40% - 50%	2506.71	-2157.70	-47.95	0.76	230.48
50% - 60%	3002.99	-2169.30	-48.21	0.81	230.22
60% - 70%	3501.78	-2182.73	-48.51	0.85	230.31
70% - 80%	3997.56	-2196.86	-48.82	0.88	230.47
80% - 90%	4494.06	-2202.91	-48.95	0.90	230.18
90% - 100%	4583.19	-2206.34	-49.03	0.90	230.14

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Cos phi = 1 no reactive power supply					
Rating power [%]	Active power [W]	Reactive Power [Var]	Setpoint-Q/P _D [%]	Power factor [cos φ]	Voltage [V]
0% - 10%	529.39	82.73	1.84	0.99	230.30
10% - 20%	1012.25	81.10	1.80	1.00	230.45
20% - 30%	1515.13	83.96	1.87	1.00	230.35
30% - 40%	2019.40	88.71	1.97	1.00	229.57
40% - 50%	2525.59	86.20	1.92	1.00	230.30
50% - 60%	3022.12	85.17	1.89	1.00	230.47
60% - 70%	3520.93	85.50	1.90	1.00	232.56
70% - 80%	4014.39	86.38	1.92	1.00	230.47
80% - 90%	4508.57	89.08	1.98	1.00	230.38
90% - 100%	4994.23	88.98	1.98	1.00	230.51


Note:

When operating above the apparent power threshold S_{min} equal to 10 % of the maximum apparent power S_{max} or the minimum regulating level of the generating plant, whichever is the higher value, the reactive power capability shall be provided with an accuracy of $\pm 2 \% S_{max}$. Up to this apparent power threshold S_{min} , deviations above 2 % are permissible.

EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Setpoint control modes – Q setpoint mode




EN 50549-1										
Clause	Requirement - Test							Result - Remark		Verdict

4.7.2.2 4.7.2.3.2	TABLE: Setpoint control modes – Cos ϕ setpoint mode										P
Model	AIO2-INS-5000										
Setting values	cos ϕ over-excited:					+0.90					
	cos ϕ under-excited:					-0.90					
P/P _n [%]	10	20	30	40	50	60	70	80	90	100	
30 s mean value	cos ϕ over-excited (c) @ U _n										
U [V]:	230.4	230.3	230.4	230.3	230.4	230.3	230.4	230.4	230.4	230.1	
P _{E30} [W]:	506.2	1011.5	1515.8	2012.7	2518.4	3011.5	3508.0	4000.3	4494.5	4574.8	
Q _{E30} [VAr]:	242.5	474.6	715.3	945.4	1187.7	1417.9	1654.3	1888.1	2120.4	2145.4	
cos ϕ _{E30-over-excited} :	0.902	0.905	0.904	0.905	0.904	0.905	0.905	0.904	0.904	0.905	
30 s mean value	cos ϕ over-excited (c) @ 1.09 U _n										
U [V]:	250.7	250.6	250.6	250.7	250.7	250.8	250.9	250.9	250.7	250.4	
P _{E30} [W]:	524.3	1012.8	1520.8	2021.0	2524.7	3021.3	3517.4	4014.4	4509.4	4552.9	
Q _{E30} [VAr]:	268.1	501.6	739.7	974.5	1215.1	1446.9	1684.7	1918.9	2151.3	2157.0	
cos ϕ _{E30-over-excited} :	0.890	0.896	0.899	0.901	0.901	0.902	0.902	0.902	0.903	0.904	
30 s mean value	cos ϕ under-excited (i) @ U _n										
U [V]:	230.2	230.2	230.2	230.1	230.1	230.0	230.1	230.1	230.2	230.0	
P _{E30} [W]:	494.6	1009.2	1515.5	2013.5	2516.7	3010.3	3503.7	3996.8	4489.2	4540.3	
Q _{E30} [VAr]:	243.2	499.2	747.3	994.4	1245.6	1492.8	1741.3	1989.4	2238.7	2250.3	
cos ϕ _{E30-under-excited} :	0.897	0.896	0.897	0.897	0.896	0.896	0.896	0.895	0.895	0.896	
30 s mean value	cos ϕ under-excited (i) @ 1.09 U _n										
U [V]:	250.7	250.6	250.6	250.7	250.7	250.6	250.6	250.7	250.7	250.6	
P _{E30} [W]:	526.9	1009.9	1516.7	2017.1	2523.0	3018.0	3509.7	4007.9	4493.4	4530.8	
Q _{E30} [VAr]:	262.9	497.0	750.0	994.2	1247.0	1495.5	1743.7	1990.8	2232.8	2238.8	
cos ϕ _{E30-under-excited} :	0.895	0.897	0.896	0.897	0.896	0.896	0.896	0.896	0.896	0.897	
Limit cos ϕ _{E30} :	cos ϕ = 0.89 to 0.91 (c) and cos ϕ = 0.89 to 0.91 (i)										
<p>Note:</p> <p>When operating above the apparent power threshold S_{min} equal to 10 % of the maximum apparent power S_{max} or the minimum regulating level of the generating plant, whichever is the higher value, the reactive power capability shall be provided with an accuracy of $\pm 2\%$ S_{max}. Up to this apparent power threshold S_{min}, deviations above 2 % are permissible.</p> <p>The tests were performed on model AIO2-INS-5000 also applicable for all other models stated in this report.</p>											


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

cos φ over-excited (c) @ U_n




cos φ over-excited (c) @ 1.09 U_n




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

cos φ under-excited (i) @ U_n



cos φ under-excited (i) @ 1.09 U_n



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.7.2.2 4.7.2.3.3	TABLE: Voltage related control mode – Q(U)						P
Model	AIO2-INS-5000						
Setting of the PCE							
Time constant range	3 s ~ 60 s						
Lock-in value setting	20% P _D						
Lock-out value setting	5% P _D						
Test result:							
Capacitive reactive power supply							
P/P _n Set-point	Vac [V] Set point	P/P _n [%] measured	Vac [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [Var] [±2% P _n]	
< 20%	1,07 V _n	10.62	246.11	90.65	≈0(<±2%P _n)	90.65	
< 20%	1,09 V _n	10.62	250.58	93.43	≈0(<±2%P _n)	93.43	
<20% ->30%	1,09 V _n	25.28	250.76	-1167.03	-0.5 Q _{max} (within 10s)	102.97	
40%	1,09 V _n	40.41	250.69	-1109.60	-0.5 Q _{max}	100.4	
50%	1,09 V _n	50.56	250.74	-1110.01	-0.5 Q _{max}	99.99	
60%	1,09 V _n	60.49	250.70	-1113.77	-0.5 Q _{max}	96.23	
70%	1,09 V _n	70.49	250.66	-1116.81	-0.5 Q _{max}	93.19	
80%	1,09 V _n	80.48	250.63	-1133.73	-0.5 Q _{max}	76.27	
90%	1,09 V _n	90.48	250.71	-1140.83	-0.5 Q _{max}	69.17	
100%	1,09 V _n	97.75	250.71	-1124.85	-0.5 Q _{max}	85.15	
100%	1,1 V _n	90.52	253.02	-2360.45	- Q _{max}	59.55	
100% ->10%	1,1 V _n	50.28	252.95	-2345.37	- Q _{max}	74.63	
10% -> ≤5%	1,1 V _n	8.21	252.89	93.82	≈0(<±2%P _n)	93.82	
Inductive reactive power absorption/							
P/P _n Set-point	Vac [V] Set point	P/P _n [%] measured	Vac [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [Var] [±2% P _n]	
< 20%	0,93 V _n	10.61	213.83	75.43	≈0 (<±2%P _n)	75.43	
< 20%	0,91 V _n	10.59	209.33	73.75	≈0 (<±2%P _n)	73.75	
< 20% ->30%	0,91 V _n	25.05	209.44	1112.19	0.5 Q _{max} (within 10s)	-97.81	
40%	0,91 V _n	40.26	209.27	1109.69	0.5 Q _{max}	-100.31	
50%	0,91 V _n	50.33	209.37	1121.48	0.5 Q _{max}	-88.52	
60%	0,91 V _n	60.26	209.20	1123.02	0.5 Q _{max}	-86.98	
70%	0,91 V _n	70.158	209.22	1127.89	0.5 Q _{max}	-82.11	
80%	0,91 V _n	80.02	209.25	1109.83	0.5 Q _{max}	-100.17	

EN 50549-1						
Clause	Requirement - Test			Result - Remark		Verdict
90%	0,91 V _n	89.92	209.33	1133.38	0.5 Q _{max}	-76.62
100%	0,91 V _n	92.05	209.27	1124.20	0.5 Q _{max}	-85.8
100%	0,90 V _n	83.03	206.92	2321.18	Q _{max}	-98.82
100%-> 10%	0,90 V _n	49.82	206.92	2324.16	Q _{max}	-95.84
10% ->5%	0,90 V _n	8.17	206.99	71.43	≈0(<±2%P _n)	71.43

Note:

The test method reference CEI 0-21:2019-04, Annex B1.2.6 as below:

The parameters V_{1i}, V_{2i}, V_{1s} and V_{2s} should be set in the range between 0.9 V_n and 1.1 V_n with 0.01 V_n steps. In order to facilitate execution of the type tests, the characterizing parameters are conventionally set as follows:

$$V_{1s} = 1,08 V_n; V_{2s} = 1,1 V_n$$

$$V_{1i} = 0,92 V_n; V_{2i} = 0,9 V_n$$

and the active power lock-in value (default value P = 0.2 P_n).





Figure 5 – Standard characteristic curve $Q = f(V)$

When operating above the apparent power threshold S_{min} equal to 10 % of the maximum apparent power S_{max} or the minimum regulating level of the generating plant, whichever is the higher value, the reactive power capability shall be provided with an accuracy of $\pm 2 \% S_{max}$. Up to this apparent power threshold S_{min} , deviations above 2 % are permissible.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.7.2.2 4.7.2.3.4	TABLE: Power related control mode – cos ϕ (P)										P
Model	AIO2-INS-5000										
Test a): displacement factor active power characteristic curve cos ϕ (P)											
30 s mean value	10% \rightarrow 100% P _{E_{max}}										
P/P _n [%]	10	20	30	40	50	60	70	80	90	100	
U [V]:	230.28	230.69	231.03	231.45	231.78	232.12	232.41	232.74	233.05	233.17	
P _{E30} [W]:	515.03	1024.2 1	1533.4 9	2035.0 7	2543.9 3	3040.4 3	3531.9 2	4025.8 7	4527.5 8	4651.1 3	
P _{E30} of P _{E_{max}} [%]:	10.30	20.48	30.66	40.70	50.87	60.80	70.63	80.51	90.55	93.02	
Q _{E30} [VAr]:	82.07	80.52	82.25	87.94	160.10	671.79	1082.6 3	1515.6 8	1993.2 9	2248.2 5	
cos ϕ _{E30} :	0.991	0.997	0.999	0.999	0.998	0.976	0.956	0.936	0.91	0.901	
cos ϕ _{setpoint} :	1.0	1.0	1.0	1.0	1.0	0.98	0.96	0.94	0.92	0.90	
30 s mean value	100% \rightarrow 10% P _{E_{max}}										
P/P _n [%]	100	90	80	70	60	50	40	30	20	10	
U [V]:	233.17	233.09	232.75	232.45	232.11	231.81	231.45	231.08	230.69	230.27	
P _{E30} [kW]:	4649.5 2	4523.6 6	4031.0 4	3536.0 4	3039.7 0	2543.6 4	2036.2 3	1531.7 0	1021.2 5	512.69	
P _{E30} of P _{E_{max}} [%]:	92.99	90.47	80.62	70.72	60.79	50.87	40.72	30.63	20.42	10.25	
Q _{E30} [kVAr]:	2258.4 9	1990.2 1	1522.8 6	1085.9 4	655.66	177.54	87.56	81.60	79.25	81.43	
cos ϕ _{E30} :	0.899	0.915	0.935	0.955	0.976	0.997	0.999	0.998	0.996	0.991	
cos ϕ _{setpoint} :	0.90	0.92	0.94	0.96	0.98	1.0	1.0	1.0	1.0	1.0	
Limit cos ϕ _{E30} :	cos ϕ _{setpoint} \pm 0.01										
Note:											


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Test b): Response time			
30 s mean value	10% → 50% → 100% P _{E_{max}}		
P/P _n [%]	10	50	100
U [V]:	230.27	231.78	233.14
P _{E30} [kW]:	512.82	2542.59	4648.75
P _{E30} of P _{E_{max}} [%]	10.25	50.85	92.97
Q _{E30} [kVAr]:	81.56	170.54	2261.25
cos φ _{E30} :	0.987	0.997	0.899
cos φ _{setpoint} :	1.0	1.0	0.90
ΔT [s]:	10% → 50% P _{E_{max}} :	8	
	50% → 100% P _{E_{max}} :	9	
30 s mean value	100% → 50% → 10% P _{E_{max}}		
P/P _n [%]	100	50	10
U [V]:	233.17	231.78	230.27
P _{E30} [kW]:	4646.15	2504.68	513.48
P _{E30} of P _{E_{max}} [%]:	92.92	50.09	10.26
Q _{E30} [kVAr]:	2249.75	155.59	82.28
cos φ _{E30} :	0.900	0.982	0.987
cos φ _{setpoint} :	0.90	1.0	1.0
ΔT [s]:	100% → 50% P _{E_{max}} :	7	
	50% → 10% P _{E_{max}} :	8	
Limit T ₀ [s]:	10		
Limit cos φ _{E30} :	cos φ _{setpoint} ± 0.02		
Note:			
When cos φ noise is superimposed due to island grid detection, and the cos φ tolerance band ±0.02 is violated for the nominal value after transient due to this noise, then this parasitic induction caused by island grid detection can be neglected.			


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Graph of cos φ (P):




Graph of cos φ (P):



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.7.3	Voltage related active power reduction (Optional)			P	
Model	AIO2-INS-5000				
Setting of the PCE					
Threshold of reduction	115.28%U _n				
Reduction method	$\Delta P\% / \Delta U$:	5.18%			
Primary power	100% Available power				
Fault (Threshold + 10%U _n)					
Test condition	Voltage level (V)	Measured voltage (V)	Measured active power (W)	Measured time [s]	Limit / a time constant Tau
1	207	207.19	4686.75	0	> 3 s
2	220	220.18	4940.06	9	> 3 s
3	250	250.10	4946.55	10	> 3 s
4	265	265.05	1073.21	6	> 3 s



EN 50549-1										
Clause	Requirement - Test							Result - Remark		Verdict
8.2.4	TABLE: Harmonic and inter-harmonics									P
The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A. The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.										
Current harmonics										
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.017	0.016	0.015	0.010	0.009	0.010	0.010	0.009	0.009	0.012
3rd	0.267	0.268	0.267	0.268	0.272	0.278	0.285	0.287	0.284	0.283
4th	0.021	0.021	0.020	0.022	0.024	0.023	0.022	0.023	0.024	0.024
5th	0.028	0.029	0.027	0.022	0.018	0.014	0.014	0.015	0.014	0.013
6th	0.009	0.008	0.010	0.009	0.009	0.008	0.009	0.008	0.007	0.008
7th	0.015	0.012	0.011	0.008	0.007	0.007	0.006	0.007	0.006	0.005
8th	0.005	0.007	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.005
9th	0.010	0.008	0.008	0.007	0.007	0.006	0.006	0.005	0.005	0.006
10th	0.008	0.008	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.007
11th	0.012	0.012	0.012	0.011	0.011	0.011	0.011	0.011	0.011	0.011
12th	0.008	0.006	0.007	0.007	0.007	0.007	0.007	0.006	0.006	0.007
13th	0.006	0.005	0.005	0.005	0.005	0.005	0.004	0.004	0.004	0.004
14th	0.005	0.005	0.006	0.005	0.005	0.005	0.005	0.004	0.004	0.004
15th	0.002	0.004	0.004	0.003	0.003	0.003	0.003	0.004	0.004	0.003
16th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004
17th	0.008	0.008	0.007	0.007	0.007	0.006	0.005	0.004	0.003	0.004
18th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.004
19th	0.007	0.006	0.006	0.006	0.006	0.005	0.005	0.004	0.004	0.004
20th	0.005	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
21th	0.007	0.007	0.007	0.007	0.006	0.006	0.005	0.005	0.004	0.004
22th	0.003	0.002	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002
23th	0.005	0.005	0.005	0.006	0.005	0.005	0.005	0.004	0.004	0.004
24th	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
25th	0.005	0.005	0.005	0.005	0.005	0.005	0.004	0.004	0.004	0.004
26th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
27th	0.005	0.005	0.005	0.006	0.006	0.006	0.005	0.005	0.005	0.005
28th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
29th	0.005	0.005	0.006	0.006	0.006	0.006	0.006	0.006	0.005	0.005
30th	0.001	0.001	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003
31th	0.002	0.003	0.003	0.003	0.004	0.004	0.004	0.005	0.005	0.006
32th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.002	0.002	0.002
33th	0.004	0.004	0.004	0.004	0.004	0.005	0.005	0.006	0.006	0.006
34th	0.002	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.002
35th	0.003	0.003	0.003	0.003	0.004	0.004	0.005	0.005	0.006	0.006
36th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003
37th	0.003	0.003	0.003	0.003	0.003	0.004	0.005	0.005	0.006	0.006
38th	0.002	0.002	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002
39th	0.003	0.003	0.003	0.003	0.004	0.004	0.005	0.005	0.006	0.006
40th	0.003	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002	0.002

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.342	0.611	0.535	0.360	0.376	0.303	0.283	0.260	0.243	0.150
2nd	125	0.414	0.658	0.571	0.380	0.381	0.312	0.290	0.263	0.246	0.152
3rd	175	0.416	0.265	0.904	0.705	0.586	0.510	0.454	0.415	0.389	0.356
4th	225	0.044	0.165	0.840	0.665	0.555	0.491	0.439	0.404	0.382	0.355
5th	275	0.680	0.997	0.565	0.497	0.327	0.305	0.255	0.232	0.215	0.269
6th	325	0.068	0.100	0.628	0.548	0.365	0.339	0.285	0.261	0.243	0.320
7th	375	0.136	0.120	0.795	0.591	0.489	0.405	0.350	0.307	0.274	0.244
8th	425	0.348	0.257	0.890	0.690	0.569	0.485	0.423	0.375	0.341	0.294
9th	475	0.821	0.366	0.280	0.200	0.177	0.145	0.128	0.114	0.104	0.086
10th	525	0.758	0.424	0.331	0.231	0.208	0.162	0.140	0.117	0.100	0.072
11th	575	0.299	0.141	0.099	0.079	0.066	0.054	0.044	0.036	0.030	0.024
12th	625	0.146	0.078	0.054	0.035	0.028	0.023	0.019	0.018	0.016	0.018
13th	675	0.180	0.081	0.054	0.038	0.030	0.023	0.019	0.018	0.017	0.018
14th	725	0.139	0.072	0.048	0.039	0.033	0.027	0.023	0.020	0.017	0.018
15th	775	0.134	0.068	0.044	0.033	0.027	0.023	0.019	0.016	0.014	0.022
16th	825	0.137	0.073	0.047	0.038	0.030	0.025	0.021	0.018	0.016	0.038
17th	875	0.124	0.064	0.043	0.034	0.027	0.023	0.020	0.019	0.016	0.112
18th	925	0.146	0.072	0.048	0.037	0.031	0.024	0.020	0.017	0.016	0.129
19th	975	0.131	0.069	0.048	0.036	0.030	0.025	0.021	0.019	0.017	0.131
20th	1025	0.138	0.076	0.051	0.041	0.033	0.027	0.023	0.021	0.020	0.031
21th	1075	0.131	0.070	0.048	0.036	0.029	0.025	0.022	0.019	0.018	0.021
22th	1125	0.135	0.074	0.050	0.043	0.035	0.030	0.026	0.024	0.020	0.022
23th	1175	0.138	0.074	0.050	0.038	0.031	0.026	0.023	0.020	0.018	0.020
24th	1225	0.141	0.076	0.051	0.041	0.034	0.029	0.025	0.022	0.021	0.022
25th	1275	0.160	0.081	0.052	0.039	0.030	0.026	0.023	0.021	0.019	0.019
26th	1325	0.145	0.077	0.058	0.043	0.033	0.029	0.025	0.023	0.021	0.021
27th	1375	0.143	0.077	0.053	0.041	0.033	0.030	0.024	0.022	0.019	0.019
28th	1425	0.143	0.078	0.052	0.042	0.032	0.030	0.026	0.022	0.020	0.020
29th	1475	0.145	0.081	0.053	0.042	0.033	0.029	0.025	0.022	0.021	0.021
30th	1525	0.152	0.082	0.057	0.045	0.036	0.030	0.026	0.023	0.022	0.022
31th	1575	0.150	0.081	0.057	0.043	0.035	0.030	0.026	0.023	0.021	0.022
32th	1625	0.167	0.089	0.060	0.050	0.038	0.034	0.029	0.027	0.024	0.024
33th	1675	0.152	0.082	0.057	0.043	0.036	0.031	0.027	0.024	0.022	0.023
34th	1725	0.179	0.092	0.064	0.048	0.041	0.035	0.029	0.027	0.024	0.028
35th	1775	0.163	0.085	0.057	0.046	0.035	0.032	0.027	0.025	0.022	0.047
36th	1825	0.163	0.087	0.059	0.048	0.039	0.034	0.030	0.028	0.025	0.031
37th	1875	0.162	0.090	0.056	0.045	0.035	0.030	0.026	0.023	0.021	0.023
38th	1925	0.212	0.094	0.063	0.053	0.042	0.038	0.031	0.030	0.028	0.028
39th	1975	0.166	0.086	0.060	0.049	0.038	0.035	0.030	0.027	0.024	0.023
40th	2025	0.220	0.129	0.083	0.066	0.050	0.043	0.036	0.030	0.026	0.028

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.112	0.101	0.054	0.067	0.048	0.029	0.036	0.031	0.042	0.028
2.3	0.418	0.193	0.136	0.095	0.075	0.064	0.050	0.044	0.044	0.044
2.5	0.252	0.134	0.059	0.033	0.026	0.022	0.019	0.034	0.036	0.036
2.7	0.435	0.291	0.167	0.130	0.137	0.082	0.080	0.077	0.073	0.092
2.9	0.146	0.113	0.051	0.037	0.032	0.021	0.022	0.015	0.015	0.017
3.1	0.072	0.062	0.031	0.024	0.023	0.017	0.020	0.020	0.020	0.015
3.3	0.104	0.056	0.035	0.027	0.024	0.018	0.021	0.016	0.013	0.018
3.5	0.084	0.041	0.030	0.022	0.019	0.016	0.017	0.014	0.015	0.011
3.7	0.114	0.062	0.043	0.034	0.025	0.021	0.018	0.017	0.014	0.013
3.9	0.217	0.190	0.115	0.087	0.072	0.063	0.058	0.051	0.046	0.042
4.1	0.222	0.156	0.088	0.068	0.058	0.050	0.047	0.042	0.038	0.036
4.3	0.167	0.088	0.063	0.050	0.042	0.036	0.029	0.025	0.022	0.021
4.5	0.091	0.049	0.033	0.027	0.024	0.022	0.019	0.016	0.014	0.014
4.7	0.080	0.043	0.028	0.022	0.019	0.017	0.015	0.013	0.011	0.011
4.9	0.061	0.031	0.021	0.016	0.015	0.014	0.011	0.010	0.009	0.009
5.1	0.052	0.028	0.018	0.014	0.012	0.011	0.010	0.008	0.007	0.007
5.3	0.052	0.028	0.018	0.014	0.012	0.010	0.009	0.008	0.007	0.007
5.5	0.044	0.022	0.015	0.011	0.010	0.009	0.007	0.007	0.006	0.006
5.7	0.044	0.021	0.014	0.011	0.009	0.008	0.007	0.007	0.006	0.006
5.9	0.047	0.021	0.014	0.012	0.010	0.009	0.007	0.007	0.006	0.006
6.1	0.055	0.028	0.018	0.014	0.011	0.009	0.007	0.007	0.005	0.005
6.3	0.045	0.022	0.015	0.012	0.009	0.007	0.006	0.006	0.005	0.004
6.5	0.034	0.018	0.012	0.008	0.007	0.006	0.005	0.004	0.004	0.004
6.7	0.030	0.015	0.009	0.007	0.006	0.005	0.004	0.004	0.003	0.004
6.9	0.029	0.016	0.010	0.007	0.006	0.005	0.004	0.004	0.003	0.003
7.1	0.037	0.019	0.012	0.009	0.007	0.006	0.005	0.004	0.004	0.004
7.3	0.032	0.016	0.010	0.008	0.006	0.005	0.004	0.004	0.004	0.003
7.5	0.028	0.014	0.010	0.007	0.006	0.005	0.004	0.004	0.003	0.003
7.7	0.028	0.015	0.010	0.007	0.006	0.005	0.004	0.004	0.003	0.003
7.9	0.029	0.022	0.017	0.009	0.007	0.006	0.005	0.004	0.004	0.004
8.1	0.030	0.022	0.018	0.010	0.007	0.006	0.005	0.004	0.005	0.004
8.3	0.032	0.016	0.010	0.008	0.006	0.005	0.004	0.004	0.004	0.003
8.5	0.033	0.016	0.011	0.008	0.007	0.006	0.005	0.004	0.004	0.004
8.7	0.030	0.015	0.010	0.007	0.006	0.005	0.004	0.004	0.003	0.003
8.9	0.030	0.016	0.010	0.008	0.006	0.005	0.004	0.004	0.004	0.003

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-5000@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.017	0.016	0.015	0.010	0.009	0.010	0.010	0.009	0.009	0.012
3rd	0.267	0.268	0.267	0.268	0.272	0.278	0.285	0.287	0.284	0.283
4th	0.021	0.021	0.020	0.022	0.024	0.023	0.022	0.023	0.024	0.024
5th	0.028	0.029	0.027	0.022	0.018	0.014	0.014	0.015	0.014	0.013
6th	0.009	0.008	0.010	0.009	0.009	0.008	0.009	0.008	0.007	0.008
7th	0.015	0.012	0.011	0.008	0.007	0.007	0.006	0.007	0.006	0.005
8th	0.005	0.007	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.005
9th	0.010	0.008	0.008	0.007	0.007	0.006	0.006	0.005	0.005	0.006
10th	0.008	0.008	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.007
11th	0.012	0.012	0.012	0.011	0.011	0.011	0.011	0.011	0.011	0.011
12th	0.008	0.006	0.007	0.007	0.007	0.007	0.007	0.006	0.006	0.007
13th	0.006	0.005	0.005	0.005	0.005	0.005	0.004	0.004	0.004	0.004
14th	0.005	0.005	0.006	0.005	0.005	0.005	0.005	0.004	0.004	0.004
15th	0.002	0.004	0.004	0.003	0.003	0.003	0.003	0.004	0.004	0.003
16th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004
17th	0.008	0.008	0.007	0.007	0.007	0.006	0.005	0.004	0.003	0.004
18th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.004
19th	0.007	0.006	0.006	0.006	0.006	0.005	0.005	0.004	0.004	0.004
20th	0.005	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
21th	0.007	0.007	0.007	0.007	0.006	0.006	0.005	0.005	0.004	0.004
22th	0.003	0.002	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002
23th	0.005	0.005	0.005	0.006	0.005	0.005	0.005	0.004	0.004	0.004
24th	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
25th	0.005	0.005	0.005	0.005	0.005	0.005	0.004	0.004	0.004	0.004
26th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
27th	0.005	0.005	0.005	0.006	0.006	0.006	0.005	0.005	0.005	0.005
28th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
29th	0.005	0.005	0.006	0.006	0.006	0.006	0.006	0.006	0.005	0.005
30th	0.001	0.001	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003
31th	0.002	0.003	0.003	0.003	0.004	0.004	0.004	0.005	0.005	0.006
32th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.002	0.002	0.002
33th	0.004	0.004	0.004	0.004	0.004	0.005	0.005	0.006	0.006	0.006
34th	0.002	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.002
35th	0.003	0.003	0.003	0.003	0.004	0.004	0.005	0.005	0.006	0.006
36th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003
37th	0.003	0.003	0.003	0.003	0.003	0.004	0.005	0.005	0.006	0.006
38th	0.002	0.002	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002
39th	0.003	0.003	0.003	0.003	0.004	0.004	0.005	0.005	0.006	0.006

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-5000@Work in the grid to charge the battery mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.360	0.702	0.450	0.340	0.266	0.221	0.192	0.168	0.146	0.138
2nd	125	0.430	0.673	0.460	0.353	0.276	0.226	0.194	0.167	0.142	0.128
3rd	175	0.401	0.232	0.864	0.697	0.578	0.500	0.447	0.402	0.360	0.326
4th	225	0.287	0.156	0.799	0.636	0.523	0.451	0.404	0.366	0.328	0.296
5th	275	0.863	0.958	0.675	0.535	0.441	0.384	0.347	0.316	0.285	0.257
6th	325	0.051	0.051	0.750	0.612	0.516	0.452	0.409	0.373	0.338	0.301
7th	375	0.304	0.121	0.768	0.594	0.471	0.387	0.331	0.287	0.258	0.234
8th	425	0.418	0.231	0.851	0.673	0.536	0.439	0.373	0.318	0.281	0.255
9th	475	0.736	0.357	0.238	0.183	0.142	0.117	0.104	0.096	0.085	0.074
10th	525	0.877	0.407	0.250	0.174	0.123	0.097	0.089	0.088	0.082	0.070
11th	575	0.185	0.113	0.083	0.067	0.049	0.037	0.030	0.023	0.020	0.016
12th	625	0.195	0.084	0.044	0.039	0.035	0.030	0.023	0.016	0.017	0.019
13th	675	0.151	0.073	0.046	0.036	0.029	0.025	0.023	0.021	0.018	0.015
14th	725	0.112	0.065	0.047	0.036	0.030	0.030	0.030	0.028	0.022	0.021
15th	775	0.110	0.064	0.043	0.034	0.029	0.024	0.020	0.018	0.016	0.015
16th	825	0.121	0.071	0.050	0.043	0.037	0.030	0.023	0.020	0.021	0.019
17th	875	0.112	0.065	0.043	0.033	0.026	0.021	0.018	0.017	0.015	0.014
18th	925	0.125	0.069	0.044	0.033	0.026	0.022	0.021	0.019	0.016	0.015
19th	975	0.117	0.065	0.044	0.034	0.028	0.023	0.019	0.017	0.016	0.015
20th	1025	0.123	0.069	0.044	0.035	0.028	0.024	0.019	0.017	0.016	0.014
21th	1075	0.116	0.064	0.044	0.035	0.028	0.023	0.020	0.018	0.016	0.015
22th	1125	0.124	0.068	0.046	0.036	0.028	0.024	0.020	0.018	0.016	0.015
23th	1175	0.122	0.068	0.046	0.036	0.029	0.025	0.021	0.019	0.017	0.015
24th	1225	0.125	0.067	0.047	0.037	0.030	0.025	0.021	0.019	0.017	0.016
25th	1275	0.122	0.067	0.048	0.038	0.030	0.025	0.021	0.019	0.017	0.015
26th	1325	0.127	0.072	0.049	0.039	0.032	0.026	0.024	0.021	0.019	0.017
27th	1375	0.128	0.071	0.050	0.039	0.031	0.028	0.023	0.021	0.019	0.017
28th	1425	0.131	0.071	0.050	0.040	0.032	0.027	0.023	0.021	0.020	0.018
29th	1475	0.130	0.075	0.052	0.041	0.034	0.027	0.024	0.021	0.020	0.018
30th	1525	0.139	0.076	0.052	0.041	0.033	0.029	0.026	0.022	0.020	0.019
31th	1575	0.137	0.076	0.054	0.043	0.035	0.030	0.026	0.024	0.021	0.018
32th	1625	0.138	0.081	0.058	0.045	0.039	0.033	0.029	0.025	0.024	0.021
33th	1675	0.137	0.077	0.054	0.042	0.035	0.032	0.028	0.024	0.022	0.020
34th	1725	0.169	0.085	0.060	0.047	0.040	0.033	0.029	0.026	0.024	0.021
35th	1775	0.157	0.089	0.059	0.045	0.037	0.031	0.027	0.025	0.023	0.021
36th	1825	0.157	0.092	0.062	0.049	0.041	0.034	0.030	0.027	0.024	0.023
37th	1875	0.150	0.080	0.054	0.042	0.036	0.032	0.027	0.025	0.022	0.021
38th	1925	0.148	0.094	0.064	0.051	0.042	0.037	0.033	0.030	0.028	0.026
39th	1975	0.151	0.084	0.056	0.045	0.038	0.033	0.029	0.026	0.024	0.024
40th	2025	0.178	0.125	0.083	0.067	0.057	0.050	0.046	0.040	0.037	0.035

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-5000@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.170	0.083	0.074	0.053	0.068	0.048	0.037	0.027	0.034	0.029
2.3	0.109	0.069	0.055	0.053	0.027	0.020	0.036	0.041	0.027	0.028
2.5	0.192	0.119	0.059	0.037	0.023	0.030	0.030	0.021	0.019	0.026
2.7	0.125	0.053	0.028	0.028	0.025	0.037	0.026	0.019	0.023	0.030
2.9	0.086	0.039	0.026	0.025	0.025	0.028	0.024	0.014	0.022	0.021
3.1	0.059	0.033	0.025	0.022	0.024	0.025	0.017	0.013	0.012	0.017
3.3	0.083	0.048	0.031	0.020	0.018	0.018	0.012	0.011	0.011	0.013
3.5	0.063	0.034	0.021	0.015	0.012	0.012	0.011	0.011	0.009	0.008
3.7	0.055	0.030	0.021	0.017	0.014	0.012	0.010	0.009	0.008	0.007
3.9	0.055	0.029	0.021	0.017	0.013	0.010	0.009	0.008	0.007	0.007
4.1	0.049	0.025	0.018	0.014	0.011	0.010	0.009	0.008	0.007	0.007
4.3	0.051	0.028	0.019	0.014	0.012	0.010	0.009	0.007	0.006	0.006
4.5	0.049	0.026	0.019	0.015	0.012	0.010	0.009	0.007	0.007	0.006
4.7	0.051	0.027	0.019	0.015	0.012	0.011	0.008	0.007	0.006	0.006
4.9	0.052	0.028	0.020	0.016	0.013	0.011	0.010	0.007	0.006	0.006
5.1	0.050	0.026	0.018	0.015	0.012	0.010	0.009	0.007	0.006	0.006
5.3	0.051	0.027	0.019	0.014	0.012	0.011	0.009	0.007	0.006	0.006
5.5	0.055	0.030	0.021	0.017	0.014	0.012	0.009	0.008	0.007	0.006
5.7	0.066	0.032	0.021	0.017	0.013	0.010	0.009	0.007	0.006	0.006
5.9	0.047	0.025	0.018	0.015	0.013	0.011	0.009	0.007	0.007	0.006
6.1	0.045	0.025	0.018	0.014	0.011	0.010	0.008	0.007	0.006	0.006
6.3	0.046	0.023	0.016	0.013	0.010	0.009	0.008	0.006	0.006	0.005
6.5	0.045	0.024	0.016	0.013	0.010	0.009	0.007	0.006	0.005	0.005
6.7	0.040	0.021	0.014	0.012	0.010	0.008	0.007	0.006	0.006	0.005
6.9	0.043	0.021	0.015	0.012	0.010	0.008	0.007	0.006	0.006	0.005
7.1	0.043	0.021	0.015	0.012	0.009	0.008	0.007	0.006	0.005	0.005
7.3	0.039	0.019	0.014	0.011	0.009	0.007	0.006	0.006	0.005	0.004
7.5	0.039	0.019	0.014	0.011	0.008	0.007	0.006	0.005	0.005	0.004
7.7	0.038	0.019	0.014	0.011	0.009	0.007	0.006	0.005	0.005	0.004
7.9	0.041	0.020	0.014	0.011	0.008	0.007	0.006	0.005	0.005	0.004
8.1	0.038	0.020	0.014	0.011	0.008	0.007	0.006	0.005	0.005	0.004
8.3	0.038	0.019	0.013	0.010	0.008	0.007	0.006	0.005	0.004	0.004
8.5	0.037	0.018	0.013	0.010	0.008	0.007	0.006	0.005	0.004	0.004
8.7	0.039	0.020	0.014	0.011	0.008	0.007	0.006	0.005	0.005	0.004
8.9	0.038	0.019	0.013	0.010	0.008	0.007	0.006	0.005	0.005	0.004

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.012	0.012	0.012	0.011	0.010	0.011	0.011	0.010	0.009	-*
3rd	0.299	0.288	0.287	0.291	0.289	0.276	0.283	0.288	0.287	-*
4th	0.022	0.023	0.022	0.023	0.024	0.024	0.024	0.025	0.026	-*
5th	0.008	0.012	0.013	0.015	0.014	0.014	0.012	0.014	0.014	-*
6th	0.008	0.009	0.009	0.009	0.009	0.009	0.010	0.009	0.009	-*
7th	0.006	0.008	0.008	0.007	0.007	0.007	0.006	0.007	0.007	-*
8th	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	-*
9th	0.005	0.005	0.006	0.006	0.006	0.007	0.006	0.005	0.005	-*
10th	0.010	0.012	0.011	0.011	0.011	0.011	0.011	0.011	0.010	-*
11th	0.007	0.008	0.008	0.008	0.008	0.008	0.008	0.008	0.008	-*
12th	0.002	0.003	0.005	0.004	0.004	0.006	0.005	0.005	0.004	-*
13th	0.006	0.005	0.006	0.006	0.006	0.006	0.006	0.005	0.005	-*
14th	0.004	0.004	0.003	0.003	0.003	0.003	0.003	0.004	0.003	-*
15th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.003	-*
16th	0.003	0.003	0.005	0.004	0.003	0.005	0.005	0.004	0.004	-*
17th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	-*
18th	0.003	0.002	0.004	0.004	0.004	0.005	0.005	0.005	0.005	-*
19th	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	-*
20th	0.002	0.002	0.003	0.003	0.003	0.005	0.006	0.005	0.005	-*
21th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	-*
22th	0.002	0.002	0.003	0.003	0.004	0.005	0.006	0.006	0.006	-*
23th	0.003	0.003	0.004	0.004	0.004	0.004	0.004	0.004	0.004	-*
24th	0.002	0.002	0.002	0.002	0.002	0.004	0.004	0.004	0.005	-*
25th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	-*
26th	0.003	0.003	0.002	0.003	0.003	0.003	0.004	0.005	0.005	-*
27th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	-*
28th	0.002	0.002	0.003	0.003	0.003	0.005	0.005	0.006	0.006	-*
29th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	-*
30th	0.002	0.002	0.002	0.002	0.003	0.003	0.004	0.005	0.006	-*
31th	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.002	-*
32th	0.002	0.002	0.002	0.002	0.003	0.004	0.005	0.005	0.006	-*
33th	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003	-*
34th	0.010	0.012	0.011	0.011	0.011	0.011	0.011	0.011	0.010	-*
35th	0.002	0.002	0.002	0.002	0.002	0.003	0.004	0.005	0.005	-*
36th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	-*
37th	0.002	0.002	0.002	0.002	0.003	0.003	0.004	0.005	0.006	-*
38th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003	-*
39th	0.002	0.002	0.002	0.002	0.003	0.003	0.004	0.005	0.005	-*
40th	0.003	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.620	0.836	0.577	0.455	0.385	0.328	0.300	0.280	0.267	-*
2nd	125	0.676	0.855	0.594	0.461	0.385	0.329	0.300	0.278	0.266	-*
3rd	175	0.663	0.328	0.938	0.720	0.599	0.522	0.469	0.427	0.402	-*
4th	225	0.324	0.236	0.881	0.686	0.574	0.509	0.460	0.423	0.401	-*
5th	275	0.581	0.834	0.583	0.436	0.350	0.301	0.263	0.233	0.214	-*
6th	325	0.032	0.953	0.655	0.491	0.396	0.340	0.297	0.264	0.245	-*
7th	375	0.360	0.195	0.826	0.624	0.505	0.420	0.364	0.319	0.291	-*
8th	425	0.667	0.331	0.936	0.715	0.586	0.503	0.441	0.392	0.361	-*
9th	475	0.944	0.435	0.291	0.219	0.177	0.149	0.131	0.116	0.107	-*
10th	525	0.906	0.488	0.342	0.258	0.206	0.168	0.143	0.122	0.108	-*
11th	575	0.289	0.122	0.091	0.072	0.060	0.053	0.044	0.037	0.033	-*
12th	625	0.124	0.084	0.051	0.036	0.027	0.024	0.021	0.019	0.019	-*
13th	675	0.172	0.076	0.049	0.038	0.030	0.022	0.020	0.018	0.017	-*
14th	725	0.125	0.063	0.044	0.036	0.030	0.027	0.023	0.020	0.017	-*
15th	775	0.113	0.059	0.041	0.031	0.025	0.022	0.019	0.019	0.016	-*
16th	825	0.113	0.058	0.042	0.032	0.026	0.022	0.019	0.017	0.017	-*
17th	875	0.116	0.058	0.040	0.031	0.025	0.022	0.020	0.019	0.017	-*
18th	925	0.131	0.062	0.043	0.033	0.027	0.022	0.020	0.018	0.017	-*
19th	975	0.115	0.071	0.043	0.033	0.027	0.023	0.022	0.019	0.018	-*
20th	1025	0.125	0.066	0.051	0.036	0.030	0.026	0.022	0.019	0.019	-*
21th	1075	0.117	0.063	0.045	0.041	0.030	0.025	0.022	0.019	0.018	-*
22th	1125	0.130	0.067	0.047	0.038	0.034	0.028	0.023	0.021	0.021	-*
23th	1175	0.128	0.067	0.047	0.036	0.030	0.026	0.024	0.020	0.019	-*
24th	1225	0.128	0.067	0.050	0.040	0.033	0.028	0.025	0.024	0.022	-*
25th	1275	0.130	0.069	0.049	0.037	0.030	0.026	0.023	0.020	0.021	-*
26th	1325	0.131	0.068	0.049	0.037	0.032	0.029	0.026	0.023	0.023	-*
27th	1375	0.132	0.070	0.050	0.037	0.031	0.027	0.025	0.021	0.020	-*
28th	1425	0.133	0.071	0.049	0.038	0.032	0.028	0.025	0.023	0.021	-*
29th	1475	0.136	0.071	0.052	0.039	0.032	0.028	0.025	0.022	0.020	-*
30th	1525	0.142	0.075	0.055	0.042	0.035	0.029	0.026	0.025	0.022	-*
31th	1575	0.147	0.076	0.055	0.042	0.034	0.029	0.026	0.024	0.022	-*
32th	1625	0.165	0.081	0.058	0.045	0.037	0.032	0.029	0.027	0.025	-*
33th	1675	0.147	0.075	0.054	0.041	0.034	0.031	0.027	0.024	0.023	-*
34th	1725	0.171	0.087	0.063	0.047	0.038	0.033	0.030	0.025	0.024	-*
35th	1775	0.151	0.080	0.056	0.044	0.037	0.032	0.028	0.026	0.025	-*
36th	1825	0.154	0.081	0.057	0.045	0.038	0.033	0.029	0.026	0.025	-*
37th	1875	0.150	0.074	0.054	0.042	0.035	0.030	0.027	0.025	0.023	-*
38th	1925	0.178	0.082	0.062	0.050	0.042	0.038	0.034	0.030	0.028	-*
39th	1975	0.153	0.077	0.057	0.044	0.037	0.033	0.028	0.025	0.024	-*
40th	2025	0.252	0.126	0.089	0.068	0.055	0.048	0.041	0.034	0.031	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.198	0.078	0.050	0.047	0.046	0.041	0.035	0.028	0.029	-*
2.3	0.213	0.104	0.077	0.062	0.050	0.033	0.027	0.019	0.018	-*
2.5	0.108	0.075	0.047	0.035	0.025	0.020	0.018	0.027	0.027	-*
2.7	0.123	0.059	0.035	0.024	0.023	0.024	0.031	0.029	0.027	-*
2.9	0.100	0.050	0.031	0.024	0.021	0.021	0.021	0.019	0.019	-*
3.1	0.066	0.038	0.023	0.016	0.013	0.016	0.018	0.019	0.017	-*
3.3	0.081	0.043	0.028	0.019	0.016	0.019	0.020	0.018	0.014	-*
3.5	0.061	0.032	0.022	0.017	0.014	0.011	0.010	0.009	0.009	-*
3.7	0.066	0.035	0.021	0.015	0.012	0.011	0.010	0.008	0.007	-*
3.9	0.060	0.028	0.020	0.016	0.014	0.011	0.009	0.009	0.008	-*
4.1	0.054	0.028	0.017	0.012	0.010	0.009	0.008	0.007	0.007	-*
4.3	0.057	0.026	0.017	0.014	0.011	0.009	0.007	0.007	0.006	-*
4.5	0.052	0.027	0.018	0.013	0.010	0.009	0.007	0.007	0.006	-*
4.7	0.055	0.027	0.018	0.013	0.011	0.009	0.008	0.007	0.006	-*
4.9	0.057	0.029	0.020	0.014	0.010	0.010	0.008	0.007	0.006	-*
5.1	0.050	0.028	0.019	0.013	0.010	0.009	0.008	0.006	0.006	-*
5.3	0.051	0.028	0.018	0.012	0.010	0.009	0.008	0.007	0.006	-*
5.5	0.058	0.031	0.021	0.014	0.011	0.010	0.008	0.007	0.006	-*
5.7	0.065	0.030	0.021	0.016	0.013	0.010	0.009	0.008	0.007	-*
5.9	0.051	0.029	0.019	0.013	0.010	0.010	0.008	0.007	0.006	-*
6.1	0.047	0.026	0.018	0.012	0.010	0.008	0.007	0.006	0.005	-*
6.3	0.049	0.025	0.017	0.012	0.009	0.008	0.007	0.006	0.006	-*
6.5	0.048	0.025	0.016	0.012	0.010	0.008	0.007	0.006	0.006	-*
6.7	0.044	0.024	0.015	0.010	0.008	0.008	0.006	0.005	0.005	-*
6.9	0.046	0.024	0.015	0.011	0.008	0.008	0.006	0.005	0.005	-*
7.1	0.046	0.023	0.015	0.011	0.009	0.007	0.006	0.006	0.005	-*
7.3	0.041	0.021	0.014	0.010	0.008	0.007	0.006	0.005	0.005	-*
7.5	0.042	0.020	0.014	0.010	0.008	0.007	0.006	0.005	0.005	-*
7.7	0.042	0.021	0.013	0.010	0.008	0.007	0.006	0.005	0.004	-*
7.9	0.043	0.020	0.014	0.010	0.008	0.007	0.006	0.005	0.005	-*
8.1	0.041	0.022	0.014	0.011	0.008	0.007	0.006	0.005	0.005	-*
8.3	0.043	0.021	0.013	0.009	0.008	0.007	0.005	0.005	0.004	-*
8.5	0.040	0.021	0.013	0.009	0.007	0.006	0.005	0.005	0.004	-*
8.7	0.043	0.021	0.014	0.010	0.008	0.007	0.006	0.005	0.005	-*
8.9	0.041	0.020	0.013	0.010	0.008	0.007	0.006	0.005	0.004	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-4600@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.011	0.012	0.011	0.011	0.010	0.010	0.010	0.010	0.009	0.013
3rd	0.296	0.294	0.291	0.287	0.284	0.289	0.288	0.285	0.287	0.287
4th	0.020	0.021	0.022	0.022	0.022	0.022	0.023	0.024	0.025	0.025
5th	0.007	0.014	0.014	0.013	0.013	0.015	0.014	0.013	0.015	0.014
6th	0.008	0.008	0.008	0.008	0.008	0.009	0.009	0.008	0.009	0.009
7th	0.005	0.009	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.006
8th	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.005
9th	0.004	0.004	0.005	0.006	0.006	0.005	0.005	0.005	0.005	0.005
10th	0.006	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.007
11th	0.008	0.008	0.009	0.010	0.010	0.010	0.010	0.011	0.011	0.011
12th	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.006	0.007	0.007
13th	0.002	0.002	0.003	0.003	0.004	0.004	0.004	0.004	0.004	0.003
14th	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.004	0.005	0.004
15th	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.003
16th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004
17th	0.006	0.005	0.004	0.004	0.006	0.006	0.005	0.004	0.004	0.005
18th	0.002	0.003	0.003	0.003	0.002	0.003	0.003	0.003	0.003	0.004
19th	0.004	0.004	0.004	0.003	0.006	0.005	0.004	0.004	0.005	0.004
20th	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
21th	0.003	0.003	0.003	0.003	0.005	0.005	0.005	0.005	0.005	0.005
22th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
23th	0.003	0.003	0.003	0.003	0.005	0.005	0.005	0.005	0.005	0.005
24th	0.004	0.004	0.004	0.003	0.004	0.004	0.004	0.004	0.004	0.004
25th	0.002	0.002	0.002	0.003	0.004	0.004	0.004	0.004	0.004	0.005
26th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
27th	0.003	0.003	0.003	0.004	0.004	0.004	0.005	0.005	0.005	0.006
28th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
29th	0.002	0.002	0.002	0.003	0.004	0.004	0.005	0.005	0.006	0.006
30th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
31th	0.002	0.002	0.002	0.002	0.003	0.003	0.004	0.005	0.005	0.006
32th	0.002	0.002	0.002	0.002	0.003	0.002	0.002	0.002	0.002	0.003
33th	0.002	0.002	0.002	0.002	0.003	0.004	0.005	0.006	0.006	0.007
34th	0.002	0.003	0.002	0.002	0.003	0.003	0.003	0.002	0.003	0.003
35th	0.001	0.002	0.002	0.002	0.003	0.003	0.004	0.005	0.005	0.007
36th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003
37th	0.002	0.002	0.002	0.003	0.003	0.003	0.004	0.005	0.005	0.006
38th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
39th	0.002	0.002	0.002	0.003	0.003	0.003	0.005	0.005	0.005	0.006
40th	0.003	0.002	0.003	0.002	0.003	0.002	0.002	0.002	0.002	0.002

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-4600@Working in photovoltaic grid-connected mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.638	0.727	0.617	0.400	0.381	0.328	0.283	0.270	0.255	0.091
2nd	125	0.745	0.805	0.633	0.405	0.389	0.333	0.287	0.274	0.260	0.090
3rd	175	0.786	0.417	0.967	0.759	0.633	0.547	0.489	0.444	0.412	0.347
4th	225	0.378	0.271	0.878	0.696	0.596	0.520	0.470	0.433	0.409	0.345
5th	275	0.738	0.022	0.576	0.538	0.377	0.325	0.300	0.257	0.230	0.319
6th	325	0.138	0.143	0.674	0.608	0.424	0.367	0.340	0.293	0.265	0.388
7th	375	0.480	0.247	0.859	0.649	0.528	0.444	0.381	0.337	0.300	0.261
8th	425	0.720	0.379	0.950	0.733	0.612	0.520	0.455	0.408	0.371	0.301
9th	475	0.936	0.423	0.316	0.218	0.188	0.158	0.134	0.121	0.113	0.086
10th	525	0.921	0.479	0.347	0.241	0.216	0.176	0.142	0.126	0.110	0.080
11th	575	0.326	0.156	0.099	0.077	0.067	0.054	0.044	0.039	0.032	0.026
12th	625	0.147	0.082	0.063	0.036	0.028	0.023	0.021	0.020	0.019	0.018
13th	675	0.188	0.088	0.055	0.038	0.030	0.026	0.022	0.019	0.018	0.017
14th	725	0.138	0.078	0.051	0.037	0.033	0.029	0.025	0.022	0.020	0.020
15th	775	0.127	0.068	0.049	0.034	0.027	0.023	0.020	0.017	0.016	0.015
16th	825	0.134	0.071	0.049	0.040	0.030	0.025	0.023	0.021	0.020	0.023
17th	875	0.123	0.068	0.047	0.037	0.029	0.025	0.022	0.019	0.017	0.027
18th	925	0.146	0.076	0.054	0.040	0.032	0.027	0.021	0.019	0.017	0.029
19th	975	0.128	0.072	0.052	0.037	0.030	0.026	0.022	0.021	0.018	0.020
20th	1025	0.143	0.078	0.054	0.039	0.032	0.029	0.026	0.023	0.021	0.018
21th	1075	0.127	0.071	0.050	0.037	0.031	0.027	0.024	0.021	0.019	0.019
22th	1125	0.139	0.079	0.053	0.043	0.036	0.032	0.028	0.025	0.021	0.020
23th	1175	0.146	0.075	0.054	0.041	0.032	0.028	0.024	0.021	0.020	0.019
24th	1225	0.153	0.080	0.054	0.041	0.035	0.031	0.027	0.025	0.023	0.023
25th	1275	0.138	0.076	0.059	0.043	0.033	0.028	0.025	0.022	0.020	0.020
26th	1325	0.148	0.081	0.055	0.042	0.036	0.031	0.027	0.024	0.023	0.021
27th	1375	0.143	0.079	0.055	0.043	0.035	0.030	0.027	0.023	0.022	0.021
28th	1425	0.147	0.081	0.056	0.043	0.035	0.030	0.027	0.024	0.022	0.023
29th	1475	0.146	0.082	0.055	0.045	0.034	0.030	0.027	0.023	0.022	0.021
30th	1525	0.152	0.087	0.060	0.046	0.038	0.033	0.027	0.025	0.022	0.023
31th	1575	0.151	0.085	0.061	0.046	0.038	0.032	0.028	0.024	0.023	0.024
32th	1625	0.168	0.092	0.062	0.051	0.041	0.035	0.032	0.028	0.026	0.028
33th	1675	0.156	0.085	0.058	0.045	0.038	0.032	0.028	0.025	0.023	0.026
34th	1725	0.189	0.093	0.069	0.051	0.042	0.037	0.032	0.028	0.025	0.042
35th	1775	0.161	0.088	0.058	0.047	0.038	0.033	0.030	0.026	0.024	0.030
36th	1825	0.165	0.095	0.062	0.051	0.040	0.036	0.032	0.029	0.026	0.029
37th	1875	0.160	0.091	0.057	0.047	0.037	0.033	0.028	0.024	0.023	0.025
38th	1925	0.208	0.099	0.064	0.053	0.044	0.039	0.036	0.031	0.029	0.032
39th	1975	0.167	0.092	0.061	0.051	0.041	0.036	0.033	0.029	0.026	0.027
40th	2025	0.242	0.128	0.087	0.069	0.055	0.047	0.040	0.035	0.030	0.034

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-4600@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.172	0.088	0.083	0.050	0.052	0.033	0.030	0.035	0.040	0.026
2.3	0.471	0.218	0.144	0.103	0.077	0.068	0.061	0.049	0.042	0.051
2.5	0.318	0.190	0.082	0.041	0.037	0.037	0.019	0.023	0.024	0.035
2.7	0.654	0.320	0.183	0.130	0.146	0.095	0.079	0.081	0.072	0.086
2.9	0.180	0.111	0.072	0.039	0.035	0.027	0.025	0.017	0.021	0.016
3.1	0.090	0.066	0.043	0.022	0.027	0.022	0.015	0.021	0.020	0.013
3.3	0.113	0.060	0.043	0.029	0.027	0.022	0.019	0.020	0.017	0.020
3.5	0.088	0.043	0.036	0.025	0.023	0.021	0.017	0.016	0.016	0.013
3.7	0.119	0.060	0.046	0.036	0.028	0.023	0.020	0.018	0.015	0.014
3.9	0.192	0.192	0.122	0.093	0.077	0.066	0.062	0.055	0.049	0.046
4.1	0.221	0.163	0.095	0.075	0.061	0.055	0.049	0.045	0.041	0.037
4.3	0.181	0.095	0.069	0.055	0.044	0.037	0.032	0.027	0.024	0.022
4.5	0.102	0.052	0.038	0.030	0.025	0.022	0.020	0.017	0.015	0.015
4.7	0.080	0.045	0.030	0.024	0.020	0.018	0.016	0.013	0.013	0.012
4.9	0.068	0.034	0.023	0.018	0.015	0.014	0.013	0.010	0.009	0.009
5.1	0.057	0.030	0.019	0.015	0.012	0.011	0.010	0.009	0.008	0.008
5.3	0.057	0.030	0.019	0.014	0.012	0.011	0.010	0.008	0.008	0.008
5.5	0.047	0.025	0.016	0.013	0.010	0.009	0.008	0.007	0.007	0.006
5.7	0.046	0.025	0.016	0.013	0.009	0.009	0.008	0.007	0.007	0.006
5.9	0.048	0.028	0.018	0.015	0.010	0.009	0.009	0.008	0.007	0.007
6.1	0.045	0.022	0.015	0.011	0.009	0.007	0.007	0.008	0.007	0.007
6.3	0.042	0.021	0.014	0.010	0.008	0.007	0.006	0.006	0.006	0.006
6.5	0.033	0.016	0.011	0.008	0.007	0.005	0.005	0.005	0.004	0.004
6.7	0.033	0.016	0.011	0.008	0.007	0.005	0.005	0.004	0.004	0.004
6.9	0.031	0.016	0.010	0.008	0.006	0.005	0.004	0.004	0.004	0.004
7.1	0.035	0.020	0.014	0.010	0.008	0.006	0.005	0.005	0.004	0.004
7.3	0.036	0.018	0.012	0.008	0.007	0.006	0.005	0.004	0.004	0.004
7.5	0.032	0.015	0.010	0.008	0.006	0.005	0.004	0.004	0.003	0.003
7.7	0.032	0.015	0.011	0.008	0.006	0.005	0.005	0.004	0.004	0.004
7.9	0.033	0.022	0.022	0.011	0.008	0.006	0.005	0.004	0.004	0.004
8.1	0.032	0.021	0.022	0.011	0.008	0.006	0.005	0.005	0.005	0.004
8.3	0.035	0.017	0.011	0.009	0.007	0.006	0.005	0.004	0.004	0.004
8.5	0.036	0.018	0.011	0.008	0.007	0.006	0.005	0.005	0.004	0.004
8.7	0.033	0.017	0.010	0.008	0.007	0.005	0.005	0.004	0.004	0.004
8.9	0.034	0.017	0.011	0.008	0.007	0.006	0.005	0.004	0.004	0.004

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-4600@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.012	0.013	0.013	0.013	0.014	0.014	0.018	0.019	0.017	0.023
3rd	0.307	0.313	0.313	0.306	0.299	0.294	0.290	0.289	0.284	0.281
4th	0.021	0.022	0.021	0.022	0.023	0.023	0.021	0.024	0.027	0.023
5th	0.010	0.011	0.008	0.009	0.011	0.015	0.018	0.021	0.023	0.024
6th	0.008	0.008	0.009	0.009	0.009	0.010	0.012	0.010	0.010	0.013
7th	0.009	0.011	0.012	0.012	0.013	0.013	0.013	0.012	0.011	0.012
8th	0.005	0.006	0.006	0.005	0.005	0.005	0.004	0.005	0.004	0.004
9th	0.003	0.004	0.004	0.004	0.005	0.005	0.006	0.007	0.009	0.010
10th	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.007	0.007	0.005
11th	0.009	0.009	0.008	0.007	0.007	0.007	0.007	0.007	0.008	0.009
12th	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.006	0.008	0.009
13th	0.003	0.002	0.003	0.003	0.003	0.003	0.004	0.005	0.005	0.007
14th	0.006	0.005	0.005	0.006	0.006	0.006	0.005	0.005	0.004	0.005
15th	0.004	0.005	0.004	0.004	0.005	0.004	0.005	0.005	0.004	0.005
16th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
17th	0.004	0.004	0.005	0.006	0.007	0.007	0.008	0.008	0.008	0.008
18th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
19th	0.002	0.002	0.002	0.003	0.004	0.004	0.004	0.004	0.005	0.005
20th	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
21th	0.002	0.002	0.002	0.003	0.004	0.005	0.005	0.005	0.006	0.006
22th	0.002	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003
23th	0.002	0.003	0.002	0.002	0.002	0.003	0.003	0.003	0.003	0.003
24th	0.003	0.003	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
25th	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003	0.003
26th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
27th	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003	0.003
28th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
29th	0.002	0.002	0.002	0.002	0.003	0.004	0.005	0.005	0.006	0.006
30th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
31th	0.002	0.002	0.002	0.003	0.002	0.002	0.002	0.002	0.002	0.002
32th	0.002	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
33th	0.002	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.004	0.005
34th	0.002	0.002	0.003	0.003	0.003	0.003	0.003	0.003	0.002	0.003
35th	0.002	0.002	0.001	0.002	0.002	0.002	0.002	0.002	0.002	0.002
36th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
37th	0.002	0.002	0.002	0.001	0.002	0.002	0.002	0.002	0.003	0.003
38th	0.003	0.003	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
39th	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
40th	0.002	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-4600@Work in the grid to charge the battery mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.352	0.748	0.511	0.373	0.290	0.241	0.205	0.182	0.158	0.142
2nd	125	0.452	0.717	0.494	0.376	0.299	0.247	0.210	0.185	0.158	0.137
3rd	175	0.489	0.338	0.952	0.753	0.620	0.537	0.470	0.429	0.384	0.349
4th	225	0.373	0.256	0.875	0.684	0.566	0.490	0.433	0.395	0.356	0.324
5th	275	0.971	0.029	0.726	0.572	0.473	0.409	0.363	0.334	0.303	0.276
6th	325	0.049	0.141	0.828	0.660	0.555	0.487	0.437	0.402	0.367	0.334
7th	375	0.346	0.214	0.848	0.646	0.516	0.429	0.363	0.319	0.279	0.257
8th	425	0.520	0.345	0.937	0.725	0.584	0.484	0.405	0.351	0.300	0.273
9th	475	0.723	0.389	0.269	0.200	0.156	0.129	0.110	0.099	0.091	0.080
10th	525	0.925	0.436	0.267	0.188	0.137	0.107	0.092	0.089	0.087	0.081
11th	575	0.189	0.124	0.082	0.066	0.052	0.041	0.034	0.027	0.023	0.020
12th	625	0.183	0.077	0.048	0.038	0.036	0.034	0.028	0.021	0.017	0.019
13th	675	0.152	0.075	0.048	0.037	0.031	0.028	0.024	0.022	0.020	0.017
14th	725	0.117	0.069	0.047	0.037	0.031	0.031	0.032	0.033	0.028	0.023
15th	775	0.111	0.068	0.045	0.035	0.030	0.025	0.022	0.020	0.018	0.016
16th	825	0.119	0.078	0.057	0.045	0.041	0.034	0.026	0.021	0.020	0.020
17th	875	0.115	0.068	0.046	0.033	0.027	0.024	0.020	0.018	0.017	0.015
18th	925	0.123	0.071	0.049	0.035	0.028	0.025	0.022	0.021	0.019	0.017
19th	975	0.117	0.070	0.048	0.036	0.029	0.025	0.021	0.019	0.017	0.016
20th	1025	0.130	0.073	0.048	0.037	0.032	0.026	0.022	0.019	0.017	0.016
21th	1075	0.116	0.068	0.046	0.036	0.030	0.026	0.021	0.019	0.017	0.016
22th	1125	0.130	0.072	0.051	0.038	0.030	0.026	0.023	0.020	0.018	0.016
23th	1175	0.122	0.073	0.050	0.038	0.032	0.027	0.022	0.020	0.018	0.017
24th	1225	0.127	0.072	0.051	0.040	0.033	0.028	0.023	0.021	0.019	0.017
25th	1275	0.125	0.074	0.052	0.041	0.033	0.027	0.024	0.022	0.019	0.017
26th	1325	0.130	0.075	0.052	0.040	0.033	0.029	0.025	0.023	0.020	0.019
27th	1375	0.128	0.075	0.053	0.041	0.033	0.029	0.025	0.023	0.020	0.018
28th	1425	0.129	0.076	0.054	0.042	0.034	0.030	0.025	0.023	0.021	0.019
29th	1475	0.130	0.077	0.054	0.043	0.035	0.030	0.025	0.023	0.020	0.019
30th	1525	0.137	0.079	0.056	0.044	0.037	0.031	0.028	0.024	0.022	0.020
31th	1575	0.139	0.083	0.058	0.045	0.036	0.032	0.028	0.025	0.022	0.020
32th	1625	0.140	0.085	0.060	0.047	0.039	0.035	0.031	0.027	0.025	0.023
33th	1675	0.138	0.084	0.059	0.044	0.037	0.033	0.029	0.026	0.023	0.021
34th	1725	0.173	0.093	0.064	0.049	0.041	0.036	0.032	0.028	0.025	0.023
35th	1775	0.154	0.092	0.064	0.048	0.039	0.034	0.029	0.026	0.025	0.023
36th	1825	0.156	0.099	0.067	0.053	0.044	0.037	0.032	0.029	0.026	0.024
37th	1875	0.154	0.087	0.060	0.046	0.038	0.033	0.029	0.026	0.024	0.023
38th	1925	0.155	0.102	0.071	0.055	0.045	0.039	0.034	0.031	0.030	0.027
39th	1975	0.153	0.091	0.061	0.048	0.042	0.037	0.032	0.028	0.026	0.025
40th	2025	0.187	0.135	0.091	0.070	0.059	0.054	0.048	0.045	0.038	0.036

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-4600@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.141	0.126	0.119	0.082	0.062	0.070	0.049	0.029	0.030	0.033
2.3	0.101	0.129	0.065	0.049	0.047	0.039	0.029	0.050	0.038	0.025
2.5	0.186	0.171	0.108	0.082	0.050	0.026	0.035	0.029	0.020	0.022
2.7	0.120	0.127	0.055	0.033	0.026	0.030	0.033	0.020	0.018	0.024
2.9	0.085	0.117	0.045	0.028	0.024	0.027	0.027	0.018	0.015	0.022
3.1	0.061	0.079	0.036	0.023	0.019	0.022	0.021	0.012	0.012	0.014
3.3	0.071	0.082	0.045	0.026	0.020	0.018	0.014	0.013	0.011	0.010
3.5	0.064	0.075	0.034	0.024	0.016	0.013	0.011	0.011	0.010	0.010
3.7	0.051	0.058	0.030	0.023	0.016	0.013	0.010	0.010	0.009	0.008
3.9	0.053	0.058	0.029	0.020	0.015	0.013	0.009	0.008	0.007	0.007
4.1	0.046	0.052	0.027	0.017	0.014	0.011	0.009	0.008	0.008	0.007
4.3	0.048	0.055	0.028	0.019	0.014	0.011	0.009	0.007	0.007	0.006
4.5	0.048	0.058	0.028	0.018	0.014	0.012	0.009	0.008	0.007	0.007
4.7	0.047	0.055	0.029	0.020	0.015	0.013	0.009	0.007	0.007	0.007
4.9	0.046	0.052	0.028	0.020	0.016	0.012	0.009	0.008	0.007	0.006
5.1	0.045	0.050	0.026	0.018	0.015	0.012	0.009	0.008	0.007	0.006
5.3	0.047	0.053	0.027	0.018	0.014	0.013	0.009	0.008	0.007	0.007
5.5	0.048	0.053	0.029	0.020	0.017	0.013	0.009	0.008	0.008	0.007
5.7	0.059	0.067	0.033	0.021	0.016	0.013	0.009	0.008	0.007	0.006
5.9	0.047	0.051	0.027	0.019	0.015	0.012	0.009	0.008	0.007	0.007
6.1	0.046	0.052	0.027	0.018	0.014	0.012	0.008	0.007	0.007	0.006
6.3	0.043	0.051	0.026	0.017	0.013	0.011	0.008	0.007	0.006	0.006
6.5	0.042	0.047	0.025	0.016	0.012	0.010	0.007	0.006	0.006	0.005
6.7	0.038	0.043	0.021	0.014	0.012	0.010	0.007	0.007	0.006	0.006
6.9	0.037	0.042	0.023	0.015	0.012	0.010	0.007	0.007	0.006	0.005
7.1	0.039	0.044	0.023	0.015	0.012	0.010	0.007	0.006	0.006	0.005
7.3	0.037	0.042	0.022	0.014	0.010	0.009	0.007	0.006	0.006	0.005
7.5	0.036	0.041	0.021	0.013	0.010	0.009	0.006	0.006	0.005	0.005
7.7	0.036	0.039	0.020	0.014	0.011	0.009	0.006	0.006	0.005	0.005
7.9	0.040	0.043	0.022	0.015	0.011	0.009	0.006	0.006	0.005	0.005
8.1	0.035	0.040	0.021	0.013	0.010	0.008	0.006	0.005	0.005	0.004
8.3	0.036	0.040	0.021	0.013	0.010	0.008	0.006	0.005	0.005	0.004
8.5	0.034	0.038	0.019	0.013	0.010	0.008	0.006	0.005	0.005	0.005
8.7	0.034	0.040	0.021	0.014	0.010	0.008	0.006	0.006	0.005	0.004
8.9	0.035	0.039	0.021	0.013	0.010	0.008	0.006	0.006	0.005	0.005

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-4600@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.142	0.012	0.012	0.011	0.011	0.010	0.011	0.010	0.010	0.010
3rd	0.290	0.280	0.286	0.291	0.290	0.273	0.280	0.287	0.288	0.287
4th	0.055	0.023	0.022	0.022	0.024	0.024	0.024	0.024	0.025	0.026
5th	0.042	0.013	0.012	0.015	0.014	0.016	0.013	0.014	0.014	0.014
6th	0.033	0.009	0.009	0.009	0.009	0.009	0.009	0.010	0.009	0.009
7th	0.028	0.009	0.007	0.007	0.007	0.006	0.006	0.007	0.007	0.007
8th	0.024	0.006	0.006	0.006	0.005	0.005	0.006	0.005	0.005	0.005
9th	0.021	0.006	0.006	0.006	0.006	0.007	0.006	0.005	0.005	0.005
10th	0.020	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.007	0.007
11th	0.019	0.009	0.009	0.010	0.011	0.011	0.011	0.011	0.011	0.011
12th	0.017	0.008	0.008	0.008	0.008	0.008	0.008	0.008	0.008	0.008
13th	0.014	0.003	0.004	0.003	0.003	0.006	0.005	0.004	0.004	0.003
14th	0.014	0.006	0.006	0.006	0.005	0.006	0.006	0.005	0.005	0.005
15th	0.013	0.004	0.004	0.004	0.004	0.003	0.003	0.003	0.004	0.004
16th	0.012	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
17th	0.013	0.006	0.006	0.005	0.004	0.006	0.005	0.005	0.004	0.004
18th	0.010	0.002	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
19th	0.011	0.005	0.005	0.004	0.004	0.006	0.005	0.005	0.004	0.004
20th	0.010	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
21th	0.010	0.005	0.004	0.004	0.003	0.006	0.006	0.005	0.005	0.005
22th	0.009	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
23th	0.008	0.003	0.003	0.003	0.003	0.005	0.005	0.005	0.005	0.005
24th	0.008	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004
25th	0.008	0.003	0.003	0.003	0.003	0.004	0.004	0.004	0.004	0.004
26th	0.007	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
27th	0.007	0.003	0.003	0.003	0.004	0.004	0.004	0.004	0.005	0.005
28th	0.007	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003
29th	0.007	0.004	0.004	0.004	0.004	0.006	0.005	0.006	0.006	0.006
30th	0.006	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
31th	0.006	0.002	0.002	0.002	0.003	0.003	0.004	0.005	0.005	0.005
32th	0.006	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.002	0.002
33th	0.006	0.002	0.002	0.003	0.003	0.004	0.005	0.005	0.005	0.006
34th	0.006	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003	0.003
35th	0.005	0.002	0.002	0.002	0.003	0.004	0.004	0.005	0.005	0.006
36th	0.005	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
37th	0.005	0.002	0.002	0.003	0.003	0.004	0.004	0.005	0.006	0.006
38th	0.005	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003
39th	0.005	0.002	0.002	0.003	0.003	0.003	0.004	0.005	0.005	0.005
40th	0.005	0.003	0.003	0.003	0.002	0.003	0.003	0.002	0.002	0.002

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-4600@Working in battery discharge and grid connection mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.848	0.871	0.617	0.480	0.401	0.339	0.304	0.283	0.267	0.285
2nd	125	0.817	0.904	0.619	0.485	0.407	0.351	0.315	0.291	0.276	0.289
3rd	175	0.513	0.449	0.985	0.762	0.633	0.553	0.489	0.445	0.415	0.402
4th	225	0.686	0.327	0.914	0.719	0.603	0.538	0.482	0.441	0.415	0.404
5th	275	0.155	0.881	0.596	0.457	0.375	0.326	0.284	0.251	0.230	0.222
6th	325	0.701	0.053	0.691	0.518	0.417	0.356	0.308	0.272	0.250	0.240
7th	375	0.854	0.296	0.871	0.663	0.540	0.455	0.389	0.341	0.308	0.291
8th	425	0.515	0.450	0.984	0.756	0.618	0.535	0.464	0.413	0.378	0.361
9th	475	0.006	0.487	0.316	0.233	0.186	0.155	0.132	0.118	0.107	0.103
10th	525	0.993	0.516	0.356	0.275	0.223	0.185	0.157	0.136	0.121	0.112
11th	575	0.203	0.138	0.099	0.076	0.061	0.055	0.047	0.040	0.035	0.033
12th	625	0.331	0.078	0.050	0.040	0.031	0.026	0.022	0.021	0.020	0.021
13th	675	0.188	0.085	0.053	0.042	0.033	0.025	0.021	0.019	0.017	0.019
14th	725	0.207	0.075	0.047	0.040	0.033	0.029	0.025	0.022	0.019	0.019
15th	775	0.157	0.068	0.044	0.034	0.027	0.023	0.021	0.018	0.017	0.017
16th	825	0.155	0.067	0.046	0.037	0.029	0.024	0.021	0.019	0.018	0.018
17th	875	0.164	0.067	0.045	0.035	0.028	0.024	0.022	0.019	0.017	0.018
18th	925	0.153	0.069	0.047	0.038	0.030	0.024	0.021	0.019	0.018	0.018
19th	975	0.168	0.070	0.048	0.037	0.030	0.026	0.023	0.020	0.018	0.018
20th	1025	0.158	0.074	0.052	0.040	0.033	0.028	0.024	0.022	0.020	0.019
21th	1075	0.166	0.073	0.048	0.038	0.031	0.026	0.023	0.020	0.019	0.018
22th	1125	0.165	0.080	0.051	0.041	0.034	0.030	0.027	0.023	0.022	0.021
23th	1175	0.167	0.076	0.050	0.040	0.032	0.028	0.024	0.022	0.020	0.020
24th	1225	0.165	0.081	0.054	0.043	0.034	0.031	0.027	0.024	0.022	0.022
25th	1275	0.187	0.086	0.053	0.041	0.033	0.028	0.025	0.022	0.020	0.019
26th	1325	0.168	0.081	0.057	0.044	0.037	0.034	0.029	0.026	0.024	0.023
27th	1375	0.162	0.080	0.054	0.042	0.034	0.030	0.026	0.024	0.022	0.021
28th	1425	0.166	0.083	0.056	0.042	0.034	0.031	0.027	0.024	0.022	0.022
29th	1475	0.180	0.082	0.056	0.043	0.035	0.030	0.026	0.024	0.022	0.021
30th	1525	0.186	0.085	0.061	0.046	0.039	0.033	0.029	0.026	0.024	0.024
31th	1575	0.185	0.084	0.059	0.046	0.037	0.032	0.028	0.025	0.023	0.022
32th	1625	0.195	0.089	0.063	0.049	0.040	0.036	0.032	0.029	0.027	0.027
33th	1675	0.185	0.089	0.058	0.046	0.038	0.033	0.029	0.026	0.024	0.024
34th	1725	0.205	0.099	0.068	0.053	0.043	0.037	0.031	0.028	0.026	0.025
35th	1775	0.192	0.088	0.059	0.047	0.039	0.034	0.030	0.027	0.025	0.026
36th	1825	0.189	0.091	0.063	0.048	0.040	0.035	0.031	0.028	0.027	0.025
37th	1875	0.203	0.089	0.060	0.047	0.037	0.033	0.030	0.027	0.025	0.025
38th	1925	0.229	0.094	0.066	0.053	0.045	0.041	0.036	0.033	0.031	0.029
39th	1975	0.207	0.091	0.064	0.048	0.039	0.034	0.032	0.027	0.026	0.024
40th	2025	0.313	0.139	0.095	0.073	0.060	0.053	0.045	0.038	0.034	0.032

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-4600@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.237	0.093	0.063	0.040	0.041	0.048	0.037	0.037	0.027	0.029
2.3	0.284	0.104	0.087	0.064	0.059	0.035	0.032	0.026	0.024	0.023
2.5	0.125	0.089	0.056	0.037	0.033	0.025	0.021	0.021	0.025	0.027
2.7	0.141	0.071	0.042	0.029	0.021	0.022	0.029	0.031	0.026	0.028
2.9	0.114	0.061	0.041	0.028	0.020	0.019	0.025	0.017	0.018	0.019
3.1	0.074	0.042	0.028	0.019	0.014	0.016	0.016	0.019	0.020	0.017
3.3	0.089	0.040	0.033	0.023	0.017	0.018	0.018	0.020	0.018	0.014
3.5	0.069	0.032	0.026	0.019	0.015	0.013	0.011	0.010	0.009	0.009
3.7	0.070	0.032	0.023	0.016	0.013	0.012	0.011	0.009	0.008	0.007
3.9	0.067	0.030	0.021	0.016	0.014	0.012	0.011	0.008	0.007	0.007
4.1	0.063	0.026	0.018	0.015	0.011	0.009	0.008	0.007	0.007	0.007
4.3	0.062	0.028	0.019	0.015	0.012	0.009	0.008	0.007	0.007	0.006
4.5	0.056	0.027	0.021	0.015	0.012	0.010	0.009	0.007	0.006	0.006
4.7	0.059	0.027	0.021	0.015	0.012	0.010	0.009	0.008	0.007	0.007
4.9	0.064	0.030	0.020	0.015	0.011	0.011	0.009	0.008	0.006	0.006
5.1	0.054	0.027	0.020	0.014	0.010	0.010	0.009	0.007	0.006	0.006
5.3	0.055	0.027	0.020	0.014	0.010	0.010	0.008	0.007	0.006	0.006
5.5	0.064	0.029	0.022	0.016	0.011	0.010	0.009	0.007	0.006	0.006
5.7	0.072	0.033	0.023	0.017	0.014	0.011	0.009	0.008	0.007	0.007
5.9	0.054	0.025	0.020	0.014	0.010	0.011	0.009	0.008	0.006	0.006
6.1	0.053	0.025	0.019	0.013	0.010	0.009	0.008	0.007	0.006	0.006
6.3	0.053	0.025	0.018	0.013	0.010	0.009	0.008	0.007	0.006	0.006
6.5	0.049	0.024	0.018	0.013	0.010	0.009	0.007	0.006	0.006	0.006
6.7	0.049	0.024	0.017	0.012	0.009	0.008	0.007	0.006	0.005	0.005
6.9	0.047	0.023	0.017	0.013	0.009	0.009	0.007	0.006	0.005	0.005
7.1	0.047	0.021	0.016	0.012	0.009	0.008	0.007	0.006	0.005	0.005
7.3	0.043	0.020	0.015	0.011	0.008	0.008	0.006	0.006	0.005	0.005
7.5	0.044	0.020	0.015	0.011	0.009	0.008	0.006	0.006	0.005	0.005
7.7	0.042	0.020	0.015	0.011	0.008	0.008	0.006	0.005	0.005	0.005
7.9	0.042	0.020	0.016	0.012	0.009	0.008	0.007	0.006	0.005	0.005
8.1	0.044	0.020	0.015	0.011	0.008	0.007	0.006	0.005	0.005	0.005
8.3	0.042	0.020	0.014	0.010	0.008	0.007	0.006	0.005	0.005	0.004
8.5	0.039	0.020	0.015	0.011	0.008	0.007	0.006	0.005	0.005	0.005
8.7	0.041	0.019	0.015	0.011	0.008	0.008	0.006	0.005	0.005	0.005
8.9	0.042	0.021	0.015	0.011	0.008	0.007	0.006	0.005	0.005	0.004

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-3680@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.018	0.027	0.025	0.023	0.021	0.019	0.019	0.017	0.017	0.016
3rd	0.175	0.149	0.146	0.163	0.180	0.199	0.222	0.247	0.271	0.256
4th	0.012	0.009	0.008	0.009	0.007	0.006	0.004	0.005	0.006	0.006
5th	0.029	0.043	0.045	0.044	0.047	0.050	0.051	0.051	0.054	0.065
6th	0.005	0.011	0.006	0.008	0.006	0.004	0.006	0.004	0.004	0.005
7th	0.042	0.044	0.046	0.049	0.055	0.062	0.068	0.071	0.072	0.076
8th	0.006	0.003	0.009	0.012	0.006	0.003	0.002	0.008	0.003	0.003
9th	0.032	0.037	0.049	0.048	0.048	0.052	0.056	0.059	0.064	0.065
10th	0.003	0.005	0.007	0.007	0.005	0.004	0.003	0.003	0.003	0.002
11th	0.020	0.029	0.039	0.043	0.041	0.041	0.044	0.046	0.051	0.050
12th	0.003	0.003	0.004	0.009	0.006	0.005	0.004	0.005	0.005	0.003
13th	0.021	0.023	0.033	0.039	0.036	0.035	0.038	0.040	0.040	0.041
14th	0.002	0.003	0.003	0.005	0.005	0.003	0.003	0.007	0.003	0.002
15th	0.014	0.018	0.025	0.033	0.035	0.034	0.034	0.036	0.039	0.038
16th	0.001	0.002	0.003	0.002	0.005	0.005	0.005	0.005	0.007	0.003
17th	0.009	0.015	0.018	0.028	0.031	0.031	0.032	0.035	0.035	0.035
18th	0.002	0.002	0.002	0.003	0.004	0.004	0.002	0.005	0.004	0.003
19th	0.011	0.012	0.018	0.023	0.030	0.033	0.033	0.035	0.036	0.036
20th	0.003	0.002	0.003	0.006	0.004	0.004	0.005	0.004	0.003	0.004
21th	0.008	0.011	0.015	0.021	0.025	0.029	0.030	0.032	0.034	0.032
22th	0.002	0.003	0.002	0.004	0.003	0.006	0.004	0.004	0.004	0.002
23th	0.006	0.010	0.010	0.016	0.022	0.029	0.032	0.034	0.034	0.036
24th	0.002	0.003	0.004	0.003	0.004	0.002	0.004	0.003	0.003	0.004
25th	0.008	0.009	0.012	0.016	0.022	0.026	0.030	0.032	0.035	0.034
26th	0.004	0.003	0.006	0.003	0.005	0.005	0.008	0.006	0.006	0.006
27th	0.007	0.010	0.011	0.014	0.018	0.023	0.028	0.031	0.033	0.034
28th	0.004	0.004	0.003	0.004	0.004	0.006	0.003	0.003	0.003	0.003
29th	0.006	0.010	0.012	0.015	0.018	0.023	0.028	0.032	0.034	0.038
30th	0.003	0.003	0.002	0.004	0.003	0.003	0.006	0.003	0.004	0.005
31th	0.006	0.008	0.010	0.013	0.015	0.019	0.023	0.027	0.030	0.034
32th	0.003	0.004	0.004	0.004	0.005	0.004	0.003	0.005	0.006	0.006
33th	0.005	0.009	0.008	0.009	0.013	0.018	0.023	0.026	0.030	0.035
34th	0.004	0.004	0.005	0.003	0.007	0.004	0.005	0.007	0.005	0.003
35th	0.005	0.008	0.010	0.011	0.014	0.017	0.021	0.026	0.030	0.036
36th	0.004	0.003	0.003	0.003	0.004	0.006	0.007	0.005	0.006	0.008
37th	0.007	0.009	0.011	0.011	0.013	0.015	0.020	0.021	0.022	0.030
38th	0.003	0.004	0.003	0.006	0.004	0.006	0.007	0.008	0.005	0.005
39th	0.008	0.008	0.009	0.011	0.012	0.014	0.018	0.021	0.024	0.029
40th	0.004	0.004	0.006	0.006	0.006	0.005	0.003	0.006	0.006	0.004

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-3680@Working in photovoltaic grid-connected mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.715	0.301	0.163	0.131	0.113	0.097	0.085	0.076	0.066	0.067
2nd	125	0.219	0.166	0.087	0.072	0.061	0.052	0.048	0.044	0.041	0.040
3rd	175	0.138	0.077	0.163	0.114	0.088	0.073	0.062	0.054	0.050	0.044
4th	225	0.129	0.073	0.153	0.109	0.079	0.064	0.054	0.049	0.045	0.038
5th	275	0.114	0.066	0.075	0.053	0.048	0.043	0.038	0.033	0.030	0.044
6th	325	0.113	0.069	0.076	0.054	0.050	0.045	0.040	0.034	0.031	0.045
7th	375	0.122	0.066	0.121	0.085	0.070	0.058	0.051	0.046	0.042	0.037
8th	425	0.153	0.092	0.110	0.081	0.064	0.054	0.048	0.043	0.039	0.035
9th	475	0.130	0.065	0.074	0.045	0.037	0.030	0.025	0.022	0.020	0.017
10th	525	0.198	0.114	0.083	0.065	0.048	0.040	0.034	0.030	0.026	0.026
11th	575	0.125	0.068	0.052	0.036	0.029	0.022	0.019	0.017	0.015	0.014
12th	625	0.182	0.101	0.078	0.061	0.047	0.041	0.035	0.031	0.027	0.028
13th	675	0.150	0.074	0.049	0.037	0.029	0.024	0.021	0.018	0.016	0.017
14th	725	0.186	0.106	0.067	0.047	0.035	0.029	0.024	0.019	0.018	0.018
15th	775	0.126	0.076	0.052	0.040	0.030	0.025	0.021	0.018	0.016	0.021
16th	825	0.133	0.083	0.061	0.046	0.036	0.028	0.023	0.020	0.017	0.136
17th	875	0.125	0.079	0.055	0.041	0.031	0.026	0.022	0.019	0.017	0.165
18th	925	0.134	0.078	0.057	0.045	0.035	0.028	0.024	0.021	0.018	0.138
19th	975	0.139	0.078	0.055	0.042	0.032	0.026	0.023	0.020	0.018	0.021
20th	1025	0.138	0.080	0.056	0.045	0.034	0.028	0.024	0.021	0.018	0.019
21th	1075	0.157	0.092	0.058	0.042	0.033	0.028	0.025	0.022	0.019	0.019
22th	1125	0.191	0.104	0.068	0.050	0.037	0.029	0.025	0.022	0.020	0.019
23th	1175	0.250	0.098	0.062	0.046	0.036	0.030	0.026	0.023	0.020	0.021
24th	1225	0.307	0.129	0.079	0.055	0.039	0.030	0.026	0.024	0.021	0.021
25th	1275	0.409	0.185	0.125	0.098	0.076	0.061	0.052	0.046	0.041	0.038
26th	1325	0.383	0.191	0.086	0.056	0.046	0.038	0.034	0.030	0.026	0.026
27th	1375	0.911	0.449	0.277	0.191	0.157	0.126	0.108	0.095	0.083	0.080
28th	1425	0.283	0.159	0.079	0.059	0.047	0.040	0.034	0.031	0.027	0.028
29th	1475	0.502	0.293	0.163	0.114	0.087	0.070	0.060	0.053	0.047	0.045
30th	1525	0.516	0.202	0.098	0.064	0.048	0.038	0.034	0.029	0.026	0.026
31th	1575	0.242	0.173	0.094	0.066	0.051	0.042	0.036	0.031	0.027	0.028
32th	1625	0.362	0.204	0.115	0.074	0.056	0.043	0.036	0.031	0.027	0.027
33th	1675	0.207	0.129	0.088	0.061	0.050	0.042	0.036	0.032	0.028	0.030
34th	1725	0.259	0.152	0.103	0.076	0.056	0.044	0.037	0.031	0.028	0.036
35th	1775	0.226	0.129	0.088	0.061	0.050	0.043	0.038	0.033	0.028	0.032
36th	1825	0.262	0.144	0.100	0.078	0.063	0.053	0.045	0.039	0.035	0.037
37th	1875	0.230	0.141	0.086	0.063	0.053	0.046	0.040	0.035	0.032	0.035
38th	1925	0.301	0.174	0.101	0.080	0.063	0.053	0.045	0.040	0.036	0.040
39th	1975	0.247	0.134	0.089	0.065	0.055	0.046	0.040	0.036	0.032	0.037
40th	2025	0.253	0.156	0.095	0.068	0.056	0.046	0.039	0.035	0.031	0.036

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-3680@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.240	0.130	0.085	0.052	0.051	0.039	0.045	0.036	0.034	0.037
2.3	0.556	0.300	0.181	0.141	0.103	0.084	0.069	0.057	0.052	0.059
2.5	0.545	0.296	0.108	0.064	0.037	0.042	0.051	0.024	0.029	0.022
2.7	1.030	0.571	0.249	0.166	0.137	0.142	0.106	0.090	0.082	0.097
2.9	0.229	0.188	0.099	0.054	0.043	0.035	0.030	0.028	0.022	0.018
3.1	0.139	0.078	0.065	0.032	0.026	0.026	0.024	0.026	0.020	0.014
3.3	0.156	0.080	0.051	0.037	0.032	0.029	0.020	0.020	0.022	0.016
3.5	0.121	0.064	0.040	0.029	0.024	0.024	0.024	0.019	0.017	0.015
3.7	0.150	0.077	0.059	0.044	0.034	0.030	0.024	0.022	0.020	0.018
3.9	0.233	0.104	0.160	0.112	0.093	0.079	0.070	0.064	0.059	0.055
4.1	0.256	0.117	0.131	0.089	0.069	0.061	0.055	0.051	0.048	0.045
4.3	0.222	0.106	0.084	0.063	0.054	0.047	0.042	0.035	0.031	0.028
4.5	0.125	0.064	0.044	0.034	0.029	0.027	0.024	0.021	0.019	0.018
4.7	0.097	0.050	0.035	0.027	0.022	0.021	0.019	0.016	0.015	0.015
4.9	0.082	0.044	0.028	0.022	0.018	0.016	0.015	0.012	0.012	0.012
5.1	0.077	0.041	0.024	0.018	0.015	0.013	0.012	0.010	0.010	0.010
5.3	0.076	0.045	0.026	0.019	0.015	0.013	0.011	0.010	0.009	0.009
5.5	0.059	0.034	0.020	0.014	0.013	0.011	0.009	0.009	0.008	0.008
5.7	0.057	0.028	0.019	0.014	0.013	0.011	0.009	0.009	0.008	0.008
5.9	0.057	0.027	0.019	0.015	0.014	0.013	0.011	0.010	0.009	0.008
6.1	0.048	0.025	0.019	0.014	0.014	0.011	0.010	0.010	0.009	0.009
6.3	0.052	0.025	0.018	0.014	0.012	0.010	0.009	0.008	0.007	0.007
6.5	0.042	0.022	0.014	0.010	0.009	0.008	0.006	0.006	0.005	0.005
6.7	0.043	0.022	0.014	0.010	0.008	0.007	0.006	0.005	0.005	0.004
6.9	0.041	0.021	0.014	0.010	0.008	0.007	0.006	0.005	0.004	0.004
7.1	0.040	0.021	0.016	0.012	0.009	0.008	0.007	0.006	0.005	0.005
7.3	0.046	0.022	0.015	0.011	0.009	0.007	0.006	0.005	0.005	0.005
7.5	0.041	0.021	0.013	0.010	0.008	0.007	0.006	0.005	0.004	0.004
7.7	0.040	0.021	0.015	0.010	0.008	0.007	0.006	0.005	0.004	0.004
7.9	0.042	0.022	0.040	0.018	0.011	0.009	0.007	0.006	0.005	0.005
8.1	0.041	0.023	0.037	0.016	0.011	0.009	0.007	0.006	0.005	0.005
8.3	0.043	0.022	0.017	0.011	0.009	0.008	0.006	0.005	0.005	0.005
8.5	0.042	0.023	0.016	0.011	0.009	0.008	0.006	0.005	0.005	0.005
8.7	0.043	0.023	0.014	0.010	0.008	0.007	0.006	0.005	0.004	0.004
8.9	0.041	0.023	0.014	0.010	0.008	0.007	0.006	0.005	0.005	0.004

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-3680@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.011	0.009	0.005	0.008	0.009	0.007	0.006	0.006	0.005	0.005
3rd	0.121	0.225	0.266	0.261	0.286	0.304	0.324	0.348	0.371	0.385
4th	0.005	0.006	0.005	0.004	0.004	0.003	0.003	0.003	0.008	0.007
5th	0.025	0.061	0.094	0.117	0.132	0.140	0.147	0.152	0.162	0.169
6th	0.005	0.007	0.012	0.009	0.008	0.008	0.009	0.011	0.013	0.012
7th	0.052	0.024	0.061	0.085	0.101	0.108	0.111	0.113	0.109	0.105
8th	0.005	0.005	0.007	0.004	0.005	0.005	0.006	0.009	0.006	0.005
9th	0.039	0.009	0.024	0.037	0.044	0.048	0.051	0.052	0.057	0.058
10th	0.003	0.003	0.003	0.003	0.005	0.003	0.003	0.003	0.004	0.004
11th	0.011	0.008	0.003	0.009	0.019	0.025	0.030	0.036	0.038	0.041
12th	0.003	0.004	0.004	0.003	0.005	0.005	0.004	0.004	0.003	0.004
13th	0.006	0.006	0.008	0.008	0.012	0.015	0.020	0.023	0.028	0.029
14th	0.005	0.006	0.006	0.007	0.007	0.008	0.008	0.007	0.006	0.007
15th	0.011	0.014	0.004	0.009	0.016	0.020	0.022	0.026	0.025	0.025
16th	0.003	0.004	0.004	0.005	0.004	0.005	0.006	0.005	0.004	0.004
17th	0.007	0.013	0.005	0.010	0.017	0.018	0.018	0.018	0.021	0.023
18th	0.002	0.003	0.003	0.003	0.004	0.004	0.003	0.003	0.003	0.004
19th	0.005	0.009	0.008	0.009	0.015	0.016	0.017	0.018	0.018	0.018
20th	0.004	0.004	0.004	0.004	0.005	0.004	0.005	0.006	0.007	0.007
21th	0.006	0.005	0.009	0.006	0.012	0.015	0.015	0.014	0.011	0.011
22th	0.003	0.005	0.005	0.004	0.005	0.004	0.003	0.003	0.003	0.003
23th	0.008	0.008	0.010	0.006	0.011	0.012	0.011	0.011	0.010	0.010
24th	0.003	0.004	0.006	0.004	0.004	0.004	0.005	0.004	0.004	0.004
25th	0.006	0.010	0.010	0.004	0.009	0.010	0.011	0.012	0.011	0.009
26th	0.003	0.002	0.003	0.004	0.003	0.005	0.003	0.004	0.003	0.003
27th	0.008	0.009	0.008	0.005	0.007	0.011	0.014	0.016	0.015	0.014
28th	0.005	0.005	0.005	0.005	0.004	0.005	0.004	0.004	0.005	0.005
29th	0.010	0.007	0.008	0.008	0.007	0.011	0.015	0.015	0.016	0.016
30th	0.002	0.003	0.003	0.004	0.004	0.005	0.008	0.006	0.005	0.004
31th	0.009	0.005	0.005	0.007	0.005	0.009	0.012	0.013	0.013	0.013
32th	0.004	0.003	0.004	0.003	0.003	0.004	0.004	0.003	0.006	0.006
33th	0.008	0.006	0.003	0.006	0.003	0.007	0.009	0.010	0.009	0.009
34th	0.002	0.005	0.005	0.007	0.006	0.007	0.004	0.003	0.004	0.004
35th	0.011	0.009	0.006	0.007	0.004	0.007	0.011	0.011	0.011	0.009
36th	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.005	0.004	0.004
37th	0.012	0.009	0.009	0.009	0.004	0.008	0.012	0.012	0.011	0.011
38th	0.004	0.004	0.004	0.004	0.004	0.003	0.004	0.005	0.005	0.005
39th	0.012	0.006	0.009	0.007	0.005	0.008	0.011	0.012	0.011	0.011
40th	0.002	0.004	0.004	0.004	0.004	0.003	0.004	0.004	0.006	0.007

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-3680@Work in the grid to charge the battery mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.806	0.978	0.631	0.467	0.354	0.291	0.250	0.219	0.195	0.183
2nd	125	0.931	0.466	0.619	0.467	0.366	0.306	0.263	0.228	0.201	0.187
3rd	175	0.821	0.282	0.078	0.902	0.733	0.638	0.567	0.510	0.466	0.441
4th	225	0.539	0.422	0.991	0.819	0.664	0.578	0.515	0.465	0.425	0.403
5th	275	0.367	0.492	0.851	0.686	0.556	0.482	0.429	0.389	0.358	0.341
6th	325	0.576	0.601	0.953	0.780	0.641	0.564	0.508	0.464	0.430	0.410
7th	375	0.727	0.495	0.989	0.801	0.631	0.534	0.462	0.404	0.357	0.331
8th	425	0.987	0.546	0.067	0.879	0.707	0.603	0.521	0.454	0.398	0.366
9th	475	0.956	0.123	0.322	0.253	0.197	0.163	0.137	0.119	0.106	0.100
10th	525	0.059	0.141	0.346	0.257	0.187	0.145	0.116	0.098	0.089	0.087
11th	575	0.273	0.090	0.100	0.081	0.068	0.057	0.048	0.040	0.034	0.031
12th	625	0.218	0.093	0.082	0.052	0.040	0.037	0.036	0.034	0.030	0.026
13th	675	0.208	0.082	0.063	0.046	0.037	0.032	0.029	0.026	0.024	0.023
14th	725	0.165	0.089	0.064	0.048	0.038	0.031	0.030	0.030	0.032	0.033
15th	775	0.155	0.084	0.058	0.045	0.035	0.031	0.028	0.026	0.023	0.022
16th	825	0.158	0.093	0.063	0.051	0.044	0.044	0.040	0.034	0.027	0.023
17th	875	0.150	0.083	0.059	0.044	0.034	0.029	0.025	0.022	0.020	0.019
18th	925	0.160	0.088	0.063	0.048	0.036	0.030	0.027	0.023	0.022	0.022
19th	975	0.149	0.086	0.058	0.045	0.036	0.030	0.027	0.023	0.022	0.021
20th	1025	0.155	0.090	0.060	0.047	0.039	0.035	0.030	0.027	0.022	0.020
21th	1075	0.144	0.091	0.058	0.047	0.037	0.032	0.028	0.025	0.021	0.020
22th	1125	0.156	0.097	0.061	0.047	0.038	0.033	0.028	0.025	0.024	0.022
23th	1175	0.157	0.090	0.068	0.053	0.041	0.035	0.031	0.026	0.024	0.022
24th	1225	0.163	0.093	0.061	0.049	0.039	0.034	0.031	0.027	0.023	0.021
25th	1275	0.150	0.097	0.063	0.049	0.042	0.035	0.030	0.027	0.024	0.022
26th	1325	0.153	0.096	0.064	0.051	0.041	0.035	0.031	0.028	0.026	0.024
27th	1375	0.157	0.097	0.067	0.053	0.041	0.036	0.032	0.028	0.025	0.023
28th	1425	0.156	0.102	0.065	0.052	0.042	0.037	0.032	0.029	0.026	0.024
29th	1475	0.156	0.105	0.068	0.053	0.043	0.037	0.032	0.029	0.025	0.024
30th	1525	0.168	0.106	0.069	0.055	0.045	0.039	0.034	0.031	0.027	0.026
31th	1575	0.170	0.102	0.071	0.058	0.046	0.040	0.035	0.030	0.028	0.026
32th	1625	0.170	0.104	0.071	0.059	0.045	0.039	0.034	0.031	0.028	0.026
33th	1675	0.166	0.113	0.073	0.059	0.046	0.040	0.036	0.032	0.030	0.028
34th	1725	0.168	0.118	0.072	0.059	0.046	0.040	0.038	0.033	0.031	0.028
35th	1775	0.182	0.113	0.079	0.063	0.048	0.041	0.036	0.033	0.029	0.027
36th	1825	0.197	0.115	0.082	0.067	0.051	0.044	0.040	0.037	0.032	0.030
37th	1875	0.181	0.108	0.073	0.059	0.046	0.040	0.036	0.031	0.029	0.027
38th	1925	0.192	0.129	0.077	0.063	0.051	0.045	0.039	0.035	0.031	0.029
39th	1975	0.207	0.978	0.074	0.059	0.046	0.040	0.035	0.033	0.030	0.028
40th	2025	0.206	1.466	0.093	0.073	0.059	0.051	0.048	0.041	0.039	0.038

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-3680@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.129	0.125	0.087	0.067	0.057	0.062	0.055	0.049	0.041	0.035
2.3	0.128	0.074	0.054	0.047	0.048	0.042	0.027	0.025	0.031	0.042
2.5	0.138	0.117	0.094	0.075	0.050	0.027	0.023	0.033	0.029	0.029
2.7	0.163	0.066	0.040	0.031	0.025	0.026	0.031	0.037	0.028	0.026
2.9	0.130	0.051	0.034	0.029	0.022	0.026	0.027	0.027	0.025	0.024
3.1	0.097	0.045	0.031	0.022	0.020	0.021	0.023	0.022	0.023	0.017
3.3	0.100	0.061	0.036	0.028	0.020	0.018	0.018	0.018	0.014	0.012
3.5	0.078	0.047	0.027	0.022	0.015	0.014	0.012	0.011	0.011	0.010
3.7	0.071	0.038	0.026	0.020	0.016	0.015	0.014	0.011	0.010	0.009
3.9	0.074	0.036	0.025	0.019	0.016	0.013	0.011	0.010	0.009	0.009
4.1	0.063	0.031	0.021	0.017	0.013	0.011	0.010	0.009	0.008	0.008
4.3	0.064	0.034	0.023	0.019	0.014	0.012	0.010	0.009	0.008	0.008
4.5	0.065	0.034	0.023	0.018	0.015	0.012	0.010	0.010	0.009	0.008
4.7	0.065	0.035	0.024	0.019	0.015	0.013	0.011	0.009	0.009	0.008
4.9	0.065	0.034	0.023	0.018	0.016	0.014	0.011	0.010	0.009	0.008
5.1	0.062	0.031	0.022	0.018	0.015	0.012	0.011	0.010	0.009	0.008
5.3	0.063	0.033	0.022	0.018	0.014	0.013	0.011	0.010	0.009	0.009
5.5	0.064	0.033	0.024	0.020	0.016	0.014	0.012	0.010	0.009	0.008
5.7	0.078	0.040	0.026	0.020	0.016	0.013	0.011	0.010	0.009	0.008
5.9	0.063	0.032	0.023	0.018	0.015	0.013	0.012	0.010	0.009	0.009
6.1	0.062	0.030	0.022	0.018	0.014	0.012	0.010	0.009	0.008	0.007
6.3	0.061	0.030	0.021	0.017	0.014	0.012	0.010	0.009	0.008	0.007
6.5	0.057	0.028	0.020	0.016	0.012	0.010	0.009	0.007	0.007	0.006
6.7	0.053	0.026	0.018	0.014	0.012	0.010	0.009	0.008	0.007	0.007
6.9	0.052	0.027	0.019	0.015	0.012	0.010	0.009	0.008	0.007	0.007
7.1	0.054	0.028	0.018	0.015	0.012	0.010	0.008	0.008	0.007	0.007
7.3	0.050	0.026	0.018	0.014	0.011	0.009	0.008	0.007	0.006	0.006
7.5	0.052	0.025	0.017	0.013	0.010	0.009	0.008	0.007	0.006	0.006
7.7	0.050	0.024	0.017	0.013	0.011	0.009	0.008	0.007	0.006	0.006
7.9	0.055	0.028	0.019	0.014	0.011	0.009	0.008	0.007	0.006	0.006
8.1	0.051	0.025	0.017	0.014	0.010	0.008	0.007	0.006	0.006	0.006
8.3	0.051	0.024	0.017	0.013	0.010	0.008	0.007	0.006	0.006	0.005
8.5	0.051	0.024	0.017	0.013	0.010	0.008	0.007	0.006	0.006	0.005
8.7	0.051	0.024	0.017	0.013	0.011	0.009	0.007	0.006	0.006	0.005
8.9	0.052	0.025	0.016	0.013	0.010	0.008	0.007	0.006	0.006	0.005

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-3680@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.019	0.022	0.024	0.022	0.023	0.023	0.025	-*	-*	-*
3rd	0.063	0.116	0.152	0.173	0.182	0.198	0.219	-*	-*	-*
4th	0.006	0.003	0.005	0.005	0.004	0.003	0.004	-*	-*	-*
5th	0.013	0.046	0.082	0.099	0.102	0.104	0.103	-*	-*	-*
6th	0.007	0.007	0.012	0.007	0.007	0.008	0.006	-*	-*	-*
7th	0.049	0.036	0.060	0.077	0.085	0.088	0.092	-*	-*	-*
8th	0.006	0.002	0.003	0.004	0.004	0.006	0.005	-*	-*	-*
9th	0.032	0.021	0.042	0.053	0.061	0.066	0.069	-*	-*	-*
10th	0.004	0.002	0.003	0.006	0.004	0.003	0.002	-*	-*	-*
11th	0.015	0.026	0.027	0.039	0.045	0.049	0.053	-*	-*	-*
12th	0.003	0.002	0.003	0.003	0.004	0.004	0.003	-*	-*	-*
13th	0.015	0.020	0.020	0.030	0.033	0.037	0.040	-*	-*	-*
14th	0.004	0.007	0.007	0.005	0.007	0.008	0.008	-*	-*	-*
15th	0.010	0.014	0.015	0.023	0.029	0.031	0.033	-*	-*	-*
16th	0.003	0.003	0.004	0.004	0.004	0.005	0.005	-*	-*	-*
17th	0.008	0.012	0.013	0.021	0.026	0.029	0.030	-*	-*	-*
18th	0.003	0.004	0.004	0.003	0.006	0.005	0.003	-*	-*	-*
19th	0.009	0.010	0.015	0.019	0.025	0.028	0.030	-*	-*	-*
20th	0.005	0.004	0.004	0.006	0.003	0.003	0.005	-*	-*	-*
21th	0.007	0.010	0.015	0.016	0.021	0.024	0.027	-*	-*	-*
22th	0.004	0.003	0.002	0.003	0.002	0.004	0.003	-*	-*	-*
23th	0.004	0.009	0.010	0.014	0.017	0.022	0.024	-*	-*	-*
24th	0.002	0.003	0.004	0.003	0.005	0.004	0.004	-*	-*	-*
25th	0.005	0.006	0.010	0.012	0.018	0.020	0.023	-*	-*	-*
26th	0.003	0.002	0.004	0.004	0.004	0.004	0.007	-*	-*	-*
27th	0.005	0.007	0.010	0.011	0.016	0.019	0.021	-*	-*	-*
28th	0.003	0.003	0.004	0.005	0.004	0.006	0.005	-*	-*	-*
29th	0.005	0.008	0.010	0.014	0.017	0.020	0.023	-*	-*	-*
30th	0.006	0.005	0.005	0.005	0.003	0.006	0.005	-*	-*	-*
31th	0.005	0.006	0.008	0.011	0.014	0.017	0.021	-*	-*	-*
32th	0.004	0.005	0.004	0.005	0.006	0.005	0.004	-*	-*	-*
33th	0.004	0.006	0.007	0.009	0.011	0.015	0.017	-*	-*	-*
34th	0.002	0.003	0.003	0.003	0.004	0.003	0.004	-*	-*	-*
35th	0.007	0.007	0.007	0.009	0.011	0.014	0.018	-*	-*	-*
36th	0.004	0.004	0.004	0.003	0.003	0.004	0.004	-*	-*	-*
37th	0.010	0.008	0.011	0.012	0.013	0.014	0.019	-*	-*	-*
38th	0.003	0.003	0.003	0.004	0.003	0.003	0.003	-*	-*	-*
39th	0.009	0.007	0.010	0.011	0.013	0.013	0.015	-*	-*	-*
40th	0.007	0.006	0.007	0.006	0.007	0.008	0.006	-*	-*	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-3680@Working in battery discharge and grid connection mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.093	0.550	0.379	0.286	0.237	0.207	0.176	-*	-*	-*
2nd	125	0.702	0.361	0.237	0.181	0.150	0.131	0.112	-*	-*	-*
3rd	175	0.715	0.852	0.558	0.407	0.329	0.281	0.243	-*	-*	-*
4th	225	0.679	0.353	0.244	0.187	0.158	0.136	0.121	-*	-*	-*
5th	275	0.637	0.336	0.215	0.159	0.132	0.112	0.097	-*	-*	-*
6th	325	0.789	0.381	0.255	0.186	0.150	0.126	0.109	-*	-*	-*
7th	375	0.915	0.454	0.308	0.228	0.190	0.161	0.140	-*	-*	-*
8th	425	0.750	0.374	0.250	0.186	0.154	0.130	0.113	-*	-*	-*
9th	475	0.402	0.189	0.125	0.090	0.072	0.060	0.051	-*	-*	-*
10th	525	0.261	0.144	0.095	0.071	0.060	0.050	0.044	-*	-*	-*
11th	575	0.163	0.085	0.056	0.042	0.035	0.029	0.027	-*	-*	-*
12th	625	0.142	0.078	0.053	0.040	0.035	0.029	0.026	-*	-*	-*
13th	675	0.144	0.080	0.054	0.041	0.033	0.031	0.027	-*	-*	-*
14th	725	0.142	0.076	0.053	0.040	0.033	0.030	0.025	-*	-*	-*
15th	775	0.148	0.078	0.052	0.039	0.035	0.033	0.027	-*	-*	-*
16th	825	0.141	0.077	0.053	0.041	0.033	0.029	0.025	-*	-*	-*
17th	875	0.149	0.077	0.054	0.040	0.035	0.031	0.031	-*	-*	-*
18th	925	0.146	0.079	0.055	0.041	0.034	0.030	0.027	-*	-*	-*
19th	975	0.154	0.081	0.055	0.041	0.036	0.030	0.031	-*	-*	-*
20th	1025	0.151	0.082	0.057	0.043	0.035	0.032	0.029	-*	-*	-*
21th	1075	0.155	0.085	0.058	0.043	0.037	0.031	0.029	-*	-*	-*
22th	1125	0.169	0.089	0.061	0.046	0.039	0.034	0.031	-*	-*	-*
23th	1175	0.163	0.090	0.063	0.047	0.040	0.032	0.029	-*	-*	-*
24th	1225	0.165	0.089	0.062	0.046	0.040	0.034	0.031	-*	-*	-*
25th	1275	0.169	0.093	0.063	0.048	0.040	0.035	0.030	-*	-*	-*
26th	1325	0.173	0.094	0.068	0.049	0.042	0.036	0.031	-*	-*	-*
27th	1375	0.174	0.097	0.068	0.050	0.041	0.036	0.032	-*	-*	-*
28th	1425	0.175	0.099	0.068	0.052	0.044	0.037	0.032	-*	-*	-*
29th	1475	0.179	0.098	0.068	0.051	0.043	0.037	0.033	-*	-*	-*
30th	1525	0.192	0.103	0.073	0.054	0.047	0.042	0.038	-*	-*	-*
31th	1575	0.190	0.101	0.072	0.055	0.046	0.039	0.035	-*	-*	-*
32th	1625	0.196	0.103	0.072	0.055	0.049	0.041	0.042	-*	-*	-*
33th	1675	0.192	0.105	0.073	0.057	0.048	0.041	0.037	-*	-*	-*
34th	1725	0.207	0.113	0.085	0.064	0.056	0.047	0.046	-*	-*	-*
35th	1775	0.202	0.105	0.074	0.057	0.049	0.043	0.039	-*	-*	-*
36th	1825	0.231	0.134	0.091	0.068	0.055	0.048	0.043	-*	-*	-*
37th	1875	0.204	0.139	0.091	0.064	0.055	0.047	0.044	-*	-*	-*
38th	1925	0.212	0.125	0.083	0.061	0.053	0.045	0.040	-*	-*	-*
39th	1975	0.236	0.121	0.082	0.062	0.054	0.047	0.046	-*	-*	-*
40th	2025	0.267	0.121	0.098	0.076	0.062	0.055	0.049	-*	-*	-*

Note:*The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-3680@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.334	0.104	0.079	0.054	0.047	0.042	0.049	-*	-*	-*
2.3	0.331	0.132	0.106	0.085	0.068	0.061	0.056	-*	-*	-*
2.5	0.145	0.094	0.062	0.049	0.038	0.029	0.024	-*	-*	-*
2.7	0.155	0.081	0.048	0.042	0.029	0.021	0.020	-*	-*	-*
2.9	0.132	0.083	0.048	0.037	0.025	0.020	0.017	-*	-*	-*
3.1	0.084	0.056	0.034	0.022	0.020	0.016	0.015	-*	-*	-*
3.3	0.104	0.057	0.039	0.028	0.024	0.022	0.020	-*	-*	-*
3.5	0.092	0.045	0.029	0.022	0.018	0.015	0.014	-*	-*	-*
3.7	0.078	0.042	0.030	0.020	0.017	0.014	0.012	-*	-*	-*
3.9	0.089	0.041	0.027	0.020	0.016	0.014	0.013	-*	-*	-*
4.1	0.071	0.033	0.023	0.017	0.014	0.013	0.011	-*	-*	-*
4.3	0.077	0.036	0.024	0.017	0.014	0.012	0.010	-*	-*	-*
4.5	0.079	0.034	0.024	0.017	0.015	0.012	0.010	-*	-*	-*
4.7	0.077	0.036	0.024	0.017	0.015	0.012	0.010	-*	-*	-*
4.9	0.072	0.035	0.026	0.019	0.015	0.014	0.011	-*	-*	-*
5.1	0.067	0.033	0.024	0.017	0.015	0.013	0.011	-*	-*	-*
5.3	0.064	0.032	0.024	0.017	0.014	0.012	0.011	-*	-*	-*
5.5	0.073	0.037	0.028	0.019	0.016	0.013	0.011	-*	-*	-*
5.7	0.088	0.043	0.028	0.020	0.015	0.013	0.011	-*	-*	-*
5.9	0.069	0.032	0.026	0.018	0.016	0.013	0.011	-*	-*	-*
6.1	0.066	0.033	0.023	0.017	0.014	0.011	0.010	-*	-*	-*
6.3	0.066	0.031	0.022	0.016	0.012	0.011	0.009	-*	-*	-*
6.5	0.064	0.033	0.022	0.015	0.013	0.011	0.009	-*	-*	-*
6.7	0.055	0.030	0.021	0.015	0.014	0.011	0.009	-*	-*	-*
6.9	0.061	0.030	0.021	0.014	0.013	0.011	0.009	-*	-*	-*
7.1	0.059	0.029	0.020	0.014	0.012	0.010	0.009	-*	-*	-*
7.3	0.056	0.028	0.019	0.014	0.012	0.010	0.009	-*	-*	-*
7.5	0.056	0.027	0.019	0.013	0.011	0.010	0.008	-*	-*	-*
7.7	0.056	0.026	0.019	0.013	0.011	0.010	0.008	-*	-*	-*
7.9	0.056	0.026	0.018	0.014	0.011	0.009	0.008	-*	-*	-*
8.1	0.053	0.026	0.019	0.014	0.012	0.009	0.008	-*	-*	-*
8.3	0.051	0.025	0.018	0.013	0.011	0.009	0.007	-*	-*	-*
8.5	0.050	0.025	0.018	0.013	0.010	0.009	0.008	-*	-*	-*
8.7	0.053	0.024	0.019	0.014	0.011	0.009	0.008	-*	-*	-*
8.9	0.051	0.026	0.018	0.013	0.011	0.009	0.008	-*	-*	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-3000@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.011	0.030	0.030	0.028	0.025	0.024	0.023	0.022	0.022	0.019
3rd	0.176	0.153	0.144	0.153	0.163	0.179	0.198	0.215	0.230	0.214
4th	0.015	0.017	0.006	0.007	0.008	0.008	0.007	0.005	0.005	0.003
5th	0.026	0.046	0.045	0.045	0.047	0.048	0.049	0.052	0.055	0.060
6th	0.006	0.005	0.008	0.004	0.004	0.006	0.007	0.005	0.004	0.003
7th	0.047	0.035	0.045	0.047	0.052	0.055	0.061	0.065	0.069	0.074
8th	0.004	0.002	0.006	0.004	0.004	0.006	0.007	0.005	0.003	0.004
9th	0.029	0.039	0.048	0.048	0.048	0.050	0.051	0.054	0.060	0.059
10th	0.003	0.004	0.002	0.005	0.003	0.005	0.004	0.003	0.004	0.003
11th	0.023	0.028	0.033	0.043	0.040	0.041	0.043	0.044	0.044	0.045
12th	0.002	0.002	0.003	0.006	0.006	0.005	0.007	0.006	0.003	0.003
13th	0.017	0.021	0.024	0.034	0.039	0.038	0.037	0.038	0.040	0.038
14th	0.001	0.002	0.002	0.002	0.005	0.004	0.004	0.003	0.003	0.003
15th	0.009	0.016	0.021	0.028	0.034	0.036	0.037	0.036	0.035	0.035
16th	0.002	0.001	0.002	0.003	0.004	0.004	0.004	0.004	0.003	0.003
17th	0.013	0.012	0.016	0.022	0.029	0.032	0.033	0.033	0.032	0.032
18th	0.003	0.002	0.003	0.004	0.003	0.003	0.003	0.002	0.002	0.002
19th	0.010	0.012	0.013	0.017	0.026	0.031	0.032	0.033	0.034	0.033
20th	0.002	0.002	0.002	0.003	0.003	0.003	0.002	0.002	0.002	0.003
21th	0.006	0.011	0.013	0.016	0.020	0.024	0.029	0.031	0.030	0.032
22th	0.002	0.003	0.002	0.002	0.003	0.003	0.003	0.004	0.003	0.002
23th	0.008	0.010	0.013	0.014	0.020	0.023	0.025	0.029	0.033	0.032
24th	0.002	0.003	0.002	0.003	0.003	0.004	0.005	0.004	0.004	0.005
25th	0.005	0.008	0.010	0.011	0.015	0.021	0.024	0.028	0.031	0.032
26th	0.002	0.004	0.004	0.003	0.004	0.004	0.003	0.004	0.005	0.004
27th	0.004	0.008	0.010	0.009	0.014	0.017	0.020	0.024	0.029	0.032
28th	0.003	0.003	0.006	0.002	0.006	0.004	0.007	0.006	0.003	0.004
29th	0.007	0.009	0.011	0.013	0.015	0.018	0.021	0.024	0.030	0.031
30th	0.003	0.003	0.002	0.003	0.003	0.004	0.004	0.005	0.004	0.005
31th	0.004	0.007	0.008	0.012	0.012	0.015	0.018	0.021	0.025	0.028
32th	0.003	0.003	0.002	0.004	0.003	0.003	0.005	0.003	0.003	0.004
33th	0.004	0.006	0.009	0.008	0.010	0.013	0.015	0.019	0.025	0.031
34th	0.002	0.005	0.003	0.004	0.004	0.006	0.005	0.007	0.005	0.003
35th	0.007	0.006	0.009	0.010	0.009	0.013	0.015	0.019	0.022	0.026
36th	0.004	0.003	0.004	0.003	0.005	0.005	0.005	0.005	0.005	0.005
37th	0.005	0.008	0.009	0.010	0.012	0.014	0.015	0.017	0.020	0.025
38th	0.004	0.003	0.005	0.004	0.005	0.005	0.003	0.004	0.007	0.008
39th	0.007	0.007	0.009	0.011	0.012	0.011	0.014	0.016	0.020	0.025
40th	0.004	0.006	0.003	0.007	0.003	0.003	0.006	0.004	0.004	0.005

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-3000@Working in photovoltaic grid-connected mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.841	0.366	0.232	0.164	0.144	0.122	0.108	0.094	0.086	0.085
2nd	125	0.715	0.249	0.115	0.084	0.065	0.057	0.052	0.049	0.044	0.048
3rd	175	0.572	0.362	0.206	0.146	0.113	0.089	0.074	0.065	0.059	0.048
4th	225	0.651	0.300	0.193	0.134	0.100	0.081	0.069	0.060	0.053	0.041
5th	275	0.435	0.147	0.098	0.063	0.060	0.050	0.042	0.038	0.037	0.055
6th	325	0.336	0.124	0.093	0.066	0.062	0.052	0.044	0.040	0.040	0.055
7th	375	0.519	0.220	0.161	0.112	0.086	0.069	0.061	0.055	0.049	0.042
8th	425	0.524	0.254	0.139	0.100	0.077	0.064	0.056	0.050	0.046	0.038
9th	475	0.330	0.151	0.092	0.068	0.049	0.036	0.030	0.027	0.023	0.019
10th	525	0.278	0.177	0.110	0.076	0.058	0.048	0.042	0.036	0.032	0.030
11th	575	0.172	0.100	0.058	0.048	0.036	0.027	0.023	0.020	0.018	0.017
12th	625	0.203	0.130	0.091	0.069	0.056	0.047	0.042	0.037	0.034	0.032
13th	675	0.169	0.091	0.056	0.043	0.035	0.028	0.024	0.021	0.020	0.019
14th	725	0.199	0.130	0.083	0.058	0.044	0.034	0.028	0.024	0.021	0.021
15th	775	0.147	0.081	0.059	0.046	0.036	0.029	0.025	0.022	0.020	0.019
16th	825	0.145	0.086	0.067	0.055	0.043	0.035	0.031	0.025	0.022	0.038
17th	875	0.136	0.077	0.060	0.046	0.037	0.032	0.026	0.023	0.021	0.040
18th	925	0.145	0.084	0.062	0.049	0.042	0.035	0.031	0.026	0.023	0.037
19th	975	0.161	0.085	0.063	0.047	0.038	0.033	0.027	0.023	0.021	0.021
20th	1025	0.146	0.085	0.063	0.048	0.040	0.035	0.030	0.026	0.023	0.022
21th	1075	0.170	0.106	0.071	0.055	0.040	0.033	0.028	0.025	0.023	0.022
22th	1125	0.192	0.111	0.078	0.057	0.045	0.039	0.032	0.028	0.023	0.023
23th	1175	0.311	0.150	0.077	0.056	0.043	0.036	0.031	0.027	0.024	0.024
24th	1225	0.398	0.197	0.099	0.065	0.049	0.041	0.034	0.030	0.027	0.025
25th	1275	0.455	0.237	0.160	0.114	0.088	0.074	0.063	0.054	0.048	0.043
26th	1325	0.288	0.283	0.129	0.073	0.055	0.046	0.038	0.034	0.030	0.031
27th	1375	1.070	0.620	0.375	0.253	0.195	0.159	0.134	0.117	0.104	0.101
28th	1425	0.329	0.246	0.109	0.066	0.053	0.048	0.041	0.039	0.033	0.034
29th	1475	0.477	0.415	0.229	0.140	0.106	0.088	0.075	0.064	0.056	0.053
30th	1525	0.591	0.298	0.140	0.085	0.060	0.050	0.040	0.037	0.032	0.031
31th	1575	0.270	0.170	0.119	0.082	0.064	0.051	0.043	0.037	0.033	0.033
32th	1625	0.414	0.244	0.151	0.100	0.074	0.058	0.045	0.038	0.033	0.033
33th	1675	0.224	0.141	0.110	0.076	0.061	0.050	0.042	0.037	0.033	0.034
34th	1725	0.286	0.172	0.124	0.089	0.070	0.057	0.046	0.039	0.035	0.034
35th	1775	0.257	0.149	0.101	0.075	0.061	0.050	0.043	0.038	0.035	0.036
36th	1825	0.303	0.174	0.121	0.090	0.079	0.066	0.057	0.050	0.044	0.047
37th	1875	0.244	0.140	0.101	0.075	0.064	0.053	0.045	0.040	0.037	0.039
38th	1925	0.308	0.197	0.127	0.088	0.074	0.063	0.055	0.048	0.043	0.047
39th	1975	0.276	0.147	0.105	0.073	0.063	0.054	0.046	0.041	0.038	0.042
40th	2025	0.276	0.165	0.125	0.083	0.066	0.056	0.048	0.040	0.037	0.041

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-3000@Working in photovoltaic grid-connected mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.314	0.120	0.083	0.063	0.0579	0.057	0.046	0.050	0.034	0.035
2.3	0.696	0.325	0.216	0.164	0.1227	0.100	0.086	0.079	0.065	0.070
2.5	0.494	0.201	0.183	0.085	0.0623	0.041	0.028	0.022	0.046	0.038
2.7	0.674	0.330	0.307	0.200	0.1567	0.131	0.112	0.115	0.104	0.122
2.9	0.217	0.100	0.116	0.084	0.0590	0.044	0.034	0.032	0.026	0.029
3.1	0.126	0.067	0.067	0.052	0.0374	0.027	0.021	0.026	0.022	0.019
3.3	0.183	0.083	0.059	0.044	0.0410	0.032	0.026	0.025	0.023	0.018
3.5	0.146	0.067	0.044	0.037	0.0303	0.025	0.021	0.019	0.022	0.017
3.7	0.193	0.091	0.063	0.053	0.0385	0.033	0.030	0.028	0.023	0.023
3.9	0.328	0.213	0.193	0.140	0.1109	0.092	0.082	0.073	0.067	0.065
4.1	0.352	0.202	0.172	0.110	0.0807	0.072	0.066	0.060	0.055	0.053
4.3	0.269	0.137	0.096	0.077	0.0596	0.055	0.048	0.041	0.038	0.035
4.5	0.152	0.078	0.057	0.043	0.0347	0.031	0.028	0.024	0.023	0.022
4.7	0.129	0.065	0.044	0.034	0.0271	0.023	0.022	0.019	0.018	0.018
4.9	0.101	0.052	0.035	0.026	0.0215	0.018	0.016	0.015	0.014	0.013
5.1	0.087	0.045	0.030	0.024	0.0187	0.016	0.014	0.012	0.012	0.011
5.3	0.087	0.046	0.031	0.023	0.0179	0.015	0.013	0.011	0.011	0.011
5.5	0.067	0.034	0.024	0.017	0.0135	0.012	0.010	0.009	0.008	0.008
5.7	0.062	0.032	0.021	0.016	0.0125	0.010	0.009	0.008	0.007	0.007
5.9	0.056	0.029	0.020	0.015	0.0115	0.010	0.008	0.008	0.007	0.007
6.1	0.063	0.033	0.023	0.018	0.0137	0.011	0.010	0.009	0.008	0.007
6.3	0.061	0.034	0.025	0.017	0.0128	0.011	0.009	0.008	0.007	0.007
6.5	0.051	0.029	0.025	0.017	0.0113	0.009	0.007	0.006	0.006	0.005
6.7	0.049	0.024	0.017	0.012	0.0094	0.008	0.007	0.006	0.005	0.005
6.9	0.047	0.024	0.016	0.012	0.0092	0.007	0.007	0.006	0.005	0.005
7.1	0.057	0.028	0.019	0.014	0.0114	0.010	0.008	0.007	0.006	0.006
7.3	0.053	0.027	0.018	0.013	0.0103	0.009	0.007	0.006	0.006	0.006
7.5	0.046	0.023	0.015	0.012	0.0090	0.008	0.007	0.006	0.005	0.005
7.7	0.047	0.023	0.015	0.012	0.0096	0.008	0.007	0.006	0.005	0.005
7.9	0.047	0.024	0.019	0.028	0.0162	0.011	0.008	0.007	0.006	0.006
8.1	0.049	0.023	0.018	0.028	0.0169	0.011	0.008	0.007	0.006	0.006
8.3	0.052	0.026	0.017	0.014	0.0105	0.009	0.007	0.007	0.006	0.006
8.5	0.056	0.029	0.020	0.013	0.0099	0.009	0.007	0.007	0.006	0.006
8.7	0.048	0.025	0.016	0.012	0.0093	0.008	0.007	0.006	0.005	0.006
8.9	0.047	0.026	0.017	0.013	0.0097	0.008	0.007	0.006	0.006	0.007

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-3000@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.012	0.010	0.004	0.005	0.006	0.006	0.005	0.005	0.006	0.005
3rd	0.050	0.157	0.201	0.242	0.263	0.282	0.299	0.315	0.333	0.352
4th	0.008	0.007	0.006	0.005	0.005	0.005	0.005	0.004	0.004	0.006
5th	0.046	0.057	0.073	0.103	0.120	0.130	0.137	0.144	0.148	0.153
6th	0.007	0.008	0.009	0.010	0.007	0.006	0.006	0.007	0.007	0.012
7th	0.078	0.054	0.053	0.075	0.089	0.100	0.106	0.110	0.112	0.112
8th	0.005	0.007	0.005	0.004	0.004	0.005	0.006	0.007	0.006	0.010
9th	0.032	0.021	0.014	0.031	0.038	0.043	0.047	0.050	0.051	0.053
10th	0.003	0.004	0.003	0.004	0.003	0.004	0.003	0.003	0.003	0.003
11th	0.010	0.007	0.012	0.003	0.011	0.018	0.023	0.028	0.032	0.036
12th	0.004	0.004	0.004	0.004	0.003	0.004	0.004	0.004	0.004	0.004
13th	0.004	0.009	0.007	0.008	0.009	0.012	0.014	0.018	0.022	0.025
14th	0.007	0.007	0.008	0.008	0.006	0.006	0.007	0.007	0.007	0.006
15th	0.006	0.014	0.007	0.004	0.010	0.016	0.019	0.021	0.023	0.024
16th	0.003	0.004	0.003	0.004	0.005	0.004	0.004	0.006	0.005	0.006
17th	0.008	0.012	0.013	0.006	0.012	0.016	0.018	0.018	0.018	0.019
18th	0.002	0.003	0.003	0.003	0.003	0.003	0.005	0.004	0.003	0.004
19th	0.007	0.007	0.014	0.005	0.011	0.015	0.016	0.016	0.017	0.018
20th	0.004	0.003	0.003	0.004	0.003	0.005	0.004	0.004	0.005	0.006
21th	0.007	0.009	0.012	0.006	0.006	0.011	0.014	0.015	0.015	0.013
22th	0.004	0.005	0.003	0.005	0.003	0.005	0.003	0.003	0.003	0.003
23th	0.009	0.012	0.009	0.008	0.007	0.011	0.011	0.011	0.011	0.011
24th	0.003	0.004	0.003	0.004	0.004	0.005	0.004	0.005	0.005	0.004
25th	0.009	0.009	0.005	0.008	0.004	0.009	0.010	0.010	0.012	0.012
26th	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.004	0.003	0.004
27th	0.007	0.006	0.005	0.010	0.005	0.006	0.010	0.013	0.015	0.016
28th	0.006	0.005	0.005	0.004	0.005	0.004	0.005	0.005	0.003	0.004
29th	0.009	0.008	0.010	0.011	0.006	0.006	0.009	0.013	0.015	0.016
30th	0.003	0.003	0.003	0.004	0.004	0.005	0.004	0.007	0.007	0.006
31th	0.011	0.008	0.010	0.009	0.006	0.004	0.009	0.011	0.012	0.013
32th	0.003	0.003	0.003	0.004	0.003	0.003	0.004	0.004	0.003	0.005
33th	0.009	0.006	0.008	0.006	0.005	0.003	0.005	0.007	0.010	0.010
34th	0.003	0.005	0.005	0.006	0.008	0.006	0.006	0.006	0.004	0.003
35th	0.011	0.006	0.008	0.007	0.007	0.004	0.006	0.008	0.011	0.011
36th	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.004	0.004	0.004
37th	0.013	0.008	0.006	0.005	0.009	0.004	0.007	0.011	0.012	0.012
38th	0.004	0.005	0.004	0.005	0.003	0.003	0.004	0.004	0.005	0.005
39th	0.013	0.009	0.007	0.006	0.008	0.006	0.006	0.011	0.013	0.012
40th	0.003	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-3000@Work in the grid to charge the battery mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.904	0.914	0.765	0.553	0.441	0.360	0.303	0.263	0.233	0.210
2nd	125	0.280	0.145	0.736	0.540	0.442	0.373	0.321	0.282	0.251	0.226
3rd	175	0.933	0.439	0.372	0.042	0.864	0.748	0.663	0.597	0.545	0.502
4th	225	0.857	0.389	0.296	0.957	0.791	0.682	0.604	0.545	0.497	0.458
5th	275	0.670	0.325	0.037	0.793	0.663	0.573	0.508	0.461	0.423	0.393
6th	325	0.265	0.125	0.219	0.904	0.756	0.656	0.583	0.528	0.484	0.448
7th	375	0.251	0.556	0.294	0.939	0.767	0.647	0.558	0.489	0.435	0.389
8th	425	0.720	0.331	0.366	0.023	0.846	0.727	0.636	0.561	0.500	0.447
9th	475	0.233	0.574	0.410	0.302	0.241	0.201	0.168	0.144	0.126	0.113
10th	525	0.924	0.433	0.458	0.312	0.243	0.196	0.161	0.134	0.114	0.099
11th	575	0.310	0.178	0.122	0.094	0.082	0.074	0.065	0.056	0.046	0.039
12th	625	0.362	0.148	0.100	0.061	0.046	0.041	0.040	0.038	0.035	0.031
13th	675	0.246	0.124	0.084	0.056	0.044	0.039	0.035	0.032	0.028	0.025
14th	725	0.266	0.127	0.076	0.055	0.045	0.037	0.032	0.030	0.029	0.030
15th	775	0.238	0.125	0.073	0.053	0.042	0.036	0.034	0.032	0.030	0.025
16th	825	0.226	0.118	0.079	0.060	0.050	0.046	0.043	0.040	0.036	0.033
17th	875	0.242	0.121	0.073	0.052	0.041	0.035	0.030	0.027	0.025	0.022
18th	925	0.215	0.113	0.081	0.058	0.046	0.038	0.032	0.028	0.026	0.024
19th	975	0.227	0.116	0.071	0.054	0.043	0.037	0.033	0.029	0.027	0.024
20th	1025	0.221	0.116	0.076	0.056	0.045	0.039	0.035	0.032	0.028	0.025
21th	1075	0.219	0.118	0.074	0.056	0.043	0.039	0.033	0.029	0.027	0.023
22th	1125	0.223	0.117	0.076	0.056	0.045	0.039	0.035	0.030	0.028	0.025
23th	1175	0.227	0.130	0.079	0.059	0.048	0.041	0.035	0.031	0.028	0.026
24th	1225	0.219	0.121	0.078	0.057	0.046	0.039	0.034	0.032	0.030	0.026
25th	1275	0.227	0.124	0.080	0.058	0.048	0.042	0.038	0.033	0.029	0.026
26th	1325	0.229	0.125	0.077	0.058	0.048	0.041	0.037	0.032	0.029	0.027
27th	1375	0.227	0.127	0.083	0.061	0.050	0.043	0.037	0.034	0.030	0.028
28th	1425	0.224	0.124	0.081	0.060	0.049	0.043	0.038	0.034	0.030	0.028
29th	1475	0.240	0.129	0.083	0.061	0.051	0.044	0.039	0.034	0.031	0.027
30th	1525	0.247	0.131	0.089	0.064	0.054	0.046	0.040	0.035	0.032	0.029
31th	1575	0.246	0.139	0.089	0.066	0.054	0.047	0.040	0.037	0.033	0.030
32th	1625	0.252	0.138	0.089	0.066	0.054	0.046	0.040	0.036	0.034	0.030
33th	1675	0.245	0.136	0.088	0.068	0.056	0.047	0.041	0.037	0.034	0.032
34th	1725	0.244	0.138	0.090	0.069	0.055	0.046	0.042	0.039	0.035	0.033
35th	1775	0.265	0.148	0.100	0.073	0.059	0.048	0.043	0.038	0.035	0.032
36th	1825	0.296	0.153	0.103	0.079	0.064	0.052	0.046	0.042	0.040	0.035
37th	1875	0.290	0.148	0.092	0.067	0.055	0.047	0.042	0.038	0.035	0.031
38th	1925	0.289	0.155	0.098	0.073	0.060	0.052	0.045	0.041	0.039	0.034
39th	1975	0.311	0.149	0.091	0.067	0.055	0.046	0.041	0.037	0.035	0.033
40th	2025	0.331	0.169	0.116	0.089	0.070	0.062	0.055	0.049	0.046	0.041

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-3000@Work in the grid to charge the battery mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.218	0.143	0.121	0.088	0.074	0.055	0.063	0.075	0.052	0.053
2.3	0.182	0.096	0.064	0.052	0.051	0.048	0.043	0.030	0.027	0.025
2.5	0.183	0.145	0.115	0.081	0.068	0.050	0.028	0.023	0.023	0.030
2.7	0.204	0.102	0.061	0.044	0.030	0.025	0.029	0.030	0.034	0.033
2.9	0.168	0.082	0.043	0.030	0.026	0.028	0.023	0.023	0.029	0.029
3.1	0.139	0.063	0.036	0.030	0.022	0.020	0.021	0.023	0.022	0.024
3.3	0.133	0.071	0.045	0.033	0.025	0.021	0.019	0.018	0.016	0.016
3.5	0.127	0.060	0.038	0.028	0.019	0.017	0.014	0.013	0.012	0.011
3.7	0.107	0.052	0.030	0.022	0.018	0.017	0.015	0.014	0.012	0.010
3.9	0.112	0.054	0.030	0.023	0.020	0.018	0.015	0.013	0.010	0.009
4.1	0.101	0.050	0.026	0.019	0.016	0.014	0.013	0.011	0.010	0.008
4.3	0.104	0.050	0.027	0.021	0.017	0.014	0.013	0.012	0.010	0.009
4.5	0.106	0.050	0.029	0.021	0.018	0.015	0.013	0.011	0.010	0.010
4.7	0.107	0.052	0.030	0.023	0.019	0.016	0.014	0.012	0.010	0.010
4.9	0.101	0.050	0.028	0.022	0.018	0.016	0.014	0.012	0.010	0.010
5.1	0.097	0.047	0.027	0.021	0.018	0.015	0.014	0.012	0.011	0.010
5.3	0.104	0.051	0.028	0.021	0.017	0.014	0.013	0.012	0.011	0.010
5.5	0.103	0.050	0.028	0.022	0.019	0.017	0.015	0.013	0.011	0.010
5.7	0.122	0.056	0.034	0.024	0.019	0.016	0.014	0.012	0.011	0.010
5.9	0.100	0.049	0.028	0.021	0.018	0.016	0.014	0.012	0.011	0.010
6.1	0.103	0.050	0.027	0.020	0.017	0.015	0.013	0.011	0.010	0.009
6.3	0.103	0.049	0.026	0.020	0.017	0.014	0.012	0.011	0.009	0.009
6.5	0.101	0.049	0.025	0.018	0.015	0.013	0.011	0.009	0.008	0.007
6.7	0.124	0.060	0.022	0.017	0.014	0.012	0.010	0.009	0.009	0.007
6.9	0.098	0.046	0.023	0.017	0.015	0.013	0.011	0.010	0.009	0.008
7.1	0.099	0.048	0.023	0.017	0.014	0.012	0.011	0.009	0.008	0.007
7.3	0.097	0.048	0.022	0.016	0.013	0.011	0.010	0.008	0.008	0.007
7.5	0.098	0.047	0.021	0.016	0.013	0.011	0.009	0.008	0.008	0.007
7.7	0.101	0.049	0.021	0.016	0.013	0.011	0.009	0.008	0.007	0.007
7.9	0.107	0.050	0.023	0.017	0.014	0.012	0.010	0.008	0.008	0.007
8.1	0.100	0.049	0.020	0.015	0.012	0.011	0.009	0.008	0.007	0.006
8.3	0.104	0.049	0.021	0.016	0.013	0.011	0.009	0.008	0.007	0.006
8.5	0.104	0.049	0.020	0.015	0.013	0.011	0.009	0.008	0.007	0.006
8.7	0.106	0.051	0.022	0.015	0.013	0.011	0.009	0.008	0.007	0.006
8.9	0.107	0.052	0.020	0.015	0.013	0.011	0.009	0.008	0.007	0.006

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Current harmonics										
Model	AIO2-INS-3000@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2nd	0.015	0.025	0.028	0.023	0.022	0.021	0.021	0.022	0.023	-*
3rd	0.078	0.103	0.139	0.156	0.171	0.183	0.197	0.211	0.223	-*
4th	0.004	0.008	0.003	0.006	0.006	0.004	0.004	0.004	0.004	-*
5th	0.015	0.031	0.067	0.088	0.098	0.103	0.103	0.104	0.103	-*
6th	0.006	0.010	0.008	0.009	0.006	0.004	0.004	0.005	0.004	-*
7th	0.054	0.028	0.047	0.065	0.077	0.083	0.088	0.089	0.091	-*
8th	0.005	0.005	0.006	0.002	0.004	0.005	0.006	0.007	0.006	-*
9th	0.021	0.025	0.030	0.045	0.052	0.059	0.062	0.065	0.067	-*
10th	0.005	0.005	0.003	0.002	0.006	0.004	0.003	0.003	0.002	-*
11th	0.014	0.024	0.023	0.031	0.038	0.043	0.047	0.050	0.052	-*
12th	0.004	0.004	0.004	0.004	0.003	0.004	0.004	0.004	0.004	-*
13th	0.012	0.016	0.016	0.020	0.030	0.033	0.035	0.039	0.041	-*
14th	0.005	0.007	0.006	0.008	0.005	0.007	0.008	0.009	0.008	-*
15th	0.007	0.010	0.015	0.017	0.023	0.028	0.030	0.032	0.033	-*
16th	0.003	0.003	0.003	0.005	0.004	0.004	0.004	0.004	0.005	-*
17th	0.009	0.011	0.017	0.015	0.021	0.025	0.028	0.030	0.031	-*
18th	0.003	0.004	0.003	0.004	0.003	0.005	0.004	0.003	0.003	-*
19th	0.007	0.010	0.013	0.013	0.019	0.024	0.026	0.027	0.029	-*
20th	0.003	0.004	0.005	0.004	0.006	0.004	0.003	0.004	0.005	-*
21th	0.004	0.010	0.011	0.014	0.016	0.019	0.023	0.025	0.026	-*
22th	0.003	0.003	0.004	0.003	0.003	0.002	0.004	0.004	0.004	-*
23th	0.008	0.008	0.010	0.013	0.014	0.017	0.020	0.022	0.024	-*
24th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004	-*
25th	0.002	0.004	0.006	0.010	0.011	0.016	0.018	0.020	0.022	-*
26th	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.005	0.006	-*
27th	0.002	0.005	0.007	0.010	0.011	0.015	0.018	0.020	0.021	-*
28th	0.003	0.003	0.003	0.004	0.005	0.004	0.006	0.005	0.005	-*
29th	0.008	0.009	0.011	0.013	0.014	0.016	0.019	0.021	0.023	-*
30th	0.005	0.005	0.005	0.004	0.005	0.004	0.005	0.006	0.004	-*
31th	0.003	0.006	0.008	0.009	0.012	0.013	0.016	0.018	0.020	-*
32th	0.003	0.005	0.005	0.005	0.005	0.005	0.006	0.005	0.005	-*
33th	0.005	0.004	0.005	0.007	0.009	0.010	0.013	0.015	0.017	-*
34th	0.002	0.002	0.003	0.003	0.003	0.004	0.004	0.004	0.004	-*
35th	0.008	0.006	0.008	0.008	0.010	0.012	0.013	0.016	0.018	-*
36th	0.003	0.003	0.003	0.004	0.003	0.004	0.004	0.004	0.004	-*
37th	0.008	0.008	0.008	0.009	0.012	0.013	0.014	0.017	0.019	-*
38th	0.002	0.003	0.003	0.003	0.004	0.004	0.003	0.004	0.003	-*
39th	0.009	0.008	0.008	0.009	0.011	0.012	0.012	0.015	0.016	-*
40th	0.005	0.006	0.006	0.007	0.006	0.006	0.008	0.006	0.006	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Inter-harmonics											
Model	AIO2-INS-3000@Working in battery discharge and grid connection mode										
P/P _n [%]	Frequency	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Order	[Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1st	75	0.725	0.526	0.440	0.349	0.284	0.241	0.212	0.188	0.173	-*
2nd	125	0.456	0.345	0.284	0.223	0.179	0.154	0.134	0.119	0.114	-*
3rd	175	0.071	0.747	0.684	0.519	0.414	0.342	0.296	0.262	0.241	-*
4th	225	0.029	0.041	0.284	0.223	0.182	0.155	0.136	0.123	0.116	-*
5th	275	0.955	0.535	0.257	0.200	0.162	0.135	0.118	0.105	0.098	-*
6th	325	1.027	0.545	0.307	0.235	0.184	0.155	0.132	0.116	0.108	-*
7th	375	0.964	0.405	0.365	0.285	0.228	0.191	0.164	0.147	0.136	-*
8th	425	0.990	0.436	0.299	0.233	0.185	0.155	0.133	0.119	0.110	-*
9th	475	0.479	0.275	0.155	0.116	0.090	0.075	0.064	0.056	0.051	-*
10th	525	0.020	0.510	0.114	0.089	0.072	0.060	0.051	0.047	0.044	-*
11th	575	0.364	0.267	0.066	0.053	0.042	0.035	0.029	0.027	0.026	-*
12th	625	0.505	0.290	0.063	0.050	0.042	0.035	0.030	0.029	0.027	-*
13th	675	0.335	0.213	0.063	0.050	0.041	0.033	0.031	0.029	0.027	-*
14th	725	0.317	0.189	0.062	0.048	0.040	0.034	0.029	0.026	0.024	-*
15th	775	0.262	0.169	0.062	0.049	0.040	0.033	0.033	0.028	0.027	-*
16th	825	0.232	0.143	0.063	0.050	0.041	0.034	0.030	0.026	0.024	-*
17th	875	0.287	0.168	0.064	0.051	0.041	0.035	0.032	0.030	0.032	-*
18th	925	0.246	0.146	0.063	0.049	0.040	0.035	0.030	0.028	0.026	-*
19th	975	0.258	0.159	0.065	0.051	0.043	0.036	0.031	0.030	0.031	-*
20th	1025	0.228	0.141	0.068	0.054	0.042	0.036	0.033	0.030	0.028	-*
21th	1075	0.214	0.151	0.069	0.054	0.044	0.038	0.032	0.030	0.028	-*
22th	1125	0.218	0.133	0.072	0.058	0.046	0.039	0.035	0.032	0.032	-*
23th	1175	0.253	0.137	0.073	0.057	0.047	0.040	0.033	0.031	0.028	-*
24th	1225	0.223	0.124	0.072	0.058	0.045	0.040	0.034	0.031	0.031	-*
25th	1275	0.209	0.121	0.076	0.059	0.047	0.040	0.034	0.031	0.028	-*
26th	1325	0.213	0.120	0.076	0.060	0.049	0.042	0.035	0.031	0.030	-*
27th	1375	0.220	0.124	0.079	0.062	0.051	0.042	0.036	0.032	0.031	-*
28th	1425	0.214	0.122	0.080	0.062	0.050	0.043	0.039	0.033	0.031	-*
29th	1475	0.228	0.130	0.080	0.063	0.052	0.043	0.038	0.034	0.032	-*
30th	1525	0.229	0.133	0.086	0.068	0.054	0.046	0.044	0.038	0.037	-*
31th	1575	0.240	0.129	0.083	0.065	0.054	0.046	0.040	0.036	0.034	-*
32th	1625	0.242	0.135	0.084	0.069	0.055	0.047	0.043	0.040	0.044	-*
33th	1675	0.249	0.134	0.086	0.068	0.056	0.048	0.043	0.038	0.037	-*
34th	1725	0.276	0.143	0.096	0.079	0.065	0.054	0.048	0.045	0.047	-*
35th	1775	0.269	0.139	0.087	0.068	0.055	0.049	0.044	0.041	0.040	-*
36th	1825	0.328	0.162	0.109	0.086	0.066	0.057	0.050	0.046	0.043	-*
37th	1875	0.326	0.176	0.106	0.084	0.065	0.055	0.051	0.044	0.044	-*
38th	1925	0.285	0.158	0.095	0.076	0.060	0.051	0.044	0.039	0.038	-*
39th	1975	0.406	0.201	0.103	0.076	0.063	0.055	0.048	0.046	0.047	-*
40th	2025	0.362	0.186	0.116	0.089	0.076	0.063	0.055	0.051	0.049	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

Higher Frequencies										
Model	AIO2-INS-3000@Working in battery discharge and grid connection mode									
P/P _n [%]	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2.1	0.281	0.129	0.086	0.062	0.055	0.040	0.037	0.040	0.046	-*
2.3	0.270	0.125	0.104	0.087	0.083	0.058	0.058	0.058	0.107	-*
2.5	0.155	0.086	0.093	0.059	0.050	0.036	0.032	0.027	0.032	-*
2.7	0.134	0.070	0.072	0.048	0.041	0.033	0.022	0.021	0.068	-*
2.9	0.117	0.062	0.064	0.055	0.038	0.027	0.023	0.024	0.053	-*
3.1	0.104	0.054	0.041	0.032	0.023	0.020	0.016	0.015	0.059	-*
3.3	0.099	0.048	0.045	0.038	0.028	0.023	0.020	0.018	0.035	-*
3.5	0.093	0.046	0.036	0.027	0.023	0.019	0.017	0.014	0.061	-*
3.7	0.092	0.044	0.033	0.026	0.021	0.017	0.014	0.013	0.027	-*
3.9	0.091	0.045	0.032	0.025	0.021	0.018	0.015	0.014	0.052	-*
4.1	0.088	0.043	0.028	0.022	0.017	0.014	0.015	0.012	0.045	-*
4.3	0.088	0.044	0.028	0.023	0.017	0.015	0.013	0.012	0.041	-*
4.5	0.100	0.049	0.029	0.022	0.017	0.015	0.012	0.011	0.019	-*
4.7	0.092	0.045	0.030	0.023	0.018	0.015	0.012	0.011	0.037	-*
4.9	0.094	0.045	0.029	0.024	0.019	0.015	0.012	0.011	0.033	-*
5.1	0.094	0.047	0.027	0.022	0.018	0.014	0.011	0.011	0.054	-*
5.3	0.093	0.045	0.027	0.022	0.018	0.014	0.012	0.010	0.019	-*
5.5	0.092	0.045	0.030	0.026	0.020	0.016	0.013	0.011	0.028	-*
5.7	0.088	0.042	0.035	0.026	0.021	0.017	0.015	0.013	0.021	-*
5.9	0.089	0.043	0.027	0.023	0.019	0.015	0.012	0.010	0.022	-*
6.1	0.098	0.047	0.026	0.021	0.017	0.013	0.011	0.010	0.014	-*
6.3	0.089	0.044	0.026	0.021	0.016	0.013	0.011	0.010	0.035	-*
6.5	0.118	0.055	0.026	0.020	0.016	0.013	0.011	0.010	0.024	-*
6.7	0.089	0.044	0.025	0.018	0.014	0.012	0.010	0.009	0.035	-*
6.9	0.090	0.046	0.023	0.019	0.014	0.012	0.010	0.009	0.018	-*
7.1	0.105	0.048	0.023	0.020	0.015	0.012	0.011	0.009	0.019	-*
7.3	0.088	0.041	0.022	0.018	0.014	0.011	0.010	0.008	0.019	-*
7.5	0.083	0.040	0.022	0.018	0.014	0.011	0.010	0.008	0.016	-*
7.7	0.081	0.039	0.022	0.017	0.014	0.011	0.009	0.008	0.015	-*
7.9	0.082	0.040	0.021	0.018	0.014	0.011	0.009	0.008	0.029	-*
8.1	0.083	0.039	0.021	0.018	0.014	0.012	0.010	0.008	0.014	-*
8.3	0.081	0.040	0.022	0.017	0.013	0.010	0.009	0.008	0.028	-*
8.5	0.085	0.041	0.021	0.016	0.013	0.011	0.009	0.008	0.011	-*
8.7	0.088	0.044	0.021	0.017	0.014	0.011	0.009	0.008	0.029	-*
8.9	0.086	0.042	0.022	0.017	0.013	0.011	0.009	0.008	0.013	-*

Note: *The grid current is limited by the battery charging and discharging current.

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	Power quality - Voltage fluctuations and flicker		P
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode		
Parameter	Limits	Test Value	
		Single Phase	
P _{st}	1.0	0.119	
P _{lt}	0.65	0.108	
d(t) – 500ms	3.3%	0	
dc%	3.3%	0.443	
d _{max}	4%	0.497	
Note: Maximum permissible flicker and voltage fluctuation as per EN 61000-3-11 (>16A)			

4.8	Power quality - Voltage fluctuations and flicker		P
Model	AIO2-INS-3000@Working in photovoltaic grid-connected mode		
Parameter	Limits	Test Value	
		Single Phase	
P _{st}	1.0	0.145	
P _{lt}	0.65	0.117	
d(t) – 500ms	3.3%	0	
dc%	3.3%	0.256	
d _{max}	4%	0.542	
Note: Maximum permissible flicker and voltage fluctuation as per EN 61000-3-3 (<16A)			

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.8	Power quality - Voltage fluctuations and flicker		P
Model	AIO2-INS-5000@Work in the grid to charge the battery mode		
Parameter	Limits	Test Value	
		Single Phase	
P _{st}	1.0	0.313	
P _{lt}	0.65	0.156	
d(t) – 500ms	3.3%	0	
dc%	3.3%	0.592	
d _{max}	4%	1.393	
Note: Maximum permissible flicker and voltage fluctuation as per EN 61000-3-11 (>16A)			

4.8	Power quality - Voltage fluctuations and flicker		P
Model	AIO2-INS-3000@Work in the grid to charge the battery mode		
Parameter	Limits	Test Value	
		Single Phase	
P _{st}	1.0	0.142	
P _{lt}	0.65	0.140	
d(t) – 500ms	3.3%	0	
dc%	3.3%	0.136	
d _{max}	4%	0.220	
Note: Maximum permissible flicker and voltage fluctuation as per EN 61000-3-3 (<16A)			


EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.8	Power quality - Voltage fluctuations and flicker		P
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode		
Parameter	Limits	Test Value	
		Single Phase	
P _{st}	1.0	0.111	
P _{lt}	0.65	0.099	
d(t) – 500ms	3.3%	0	
dc%	3.3%	0.247	
d _{max}	4%	0.734	
Note: Maximum permissible flicker and voltage fluctuation as per EN 61000-3-11(>16A)			

4.8	Power quality - Voltage fluctuations and flicker		P
Model	AIO2-INS-3000@Working in battery discharge and grid connection mode		
Parameter	Limits	Test Value	
		Single Phase	
P _{st}	1.0	0.101	
P _{lt}	0.65	0.085	
d(t) – 500ms	3.3%	0	
dc%	3.3%	0.446	
d _{max}	4%	0.486	
Note: Maximum permissible flicker and voltage fluctuation as per EN 61000-3-3(<16A)			

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection	P		
Model	AIO2-INS-5000@Working in photovoltaic grid-connected mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (108.69 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	1013.94	2528.85	3746.09	5009.06
DC inject current L1 (mA)	62.28	57.44	15.56	32.74


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-4600@Working in photovoltaic grid-connected mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (100 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	934.33	2326.48	3451.33	4610.31
DC inject current L1 (mA)	2.14	19.39	69.27	45.14


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-3680@Working in photovoltaic grid-connected mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (80 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	755.02	1874.64	2745.63	3702.79
DC inject current L1 (mA)	56.76	56.04	21.79	35.82


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-3000@Working in photovoltaic grid-connected mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (65.21 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	613.19	1521.88	2243.14	3028.37
DC inject current L1 (mA)	13.94	16.03	33.83	7.35


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-5000@Work in the grid to charge the battery mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (108.69 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	-1000.90	-2468.29	-3835.30	-4797.92
DC inject current L1 (mA)	36.30	40.50	66.66	44.53


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection	P		
Model	AIO2-INS-4600@Work in the grid to charge the battery mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (100 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	-901.76	-2323.12	-3739.99	-4390.18
DC inject current L1 (mA)	69.22	81.11	65.65	97.52


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-3680@Work in the grid to charge the battery mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (80 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	-750.06	-1858.76	-2742.41	-3467.91
DC inject current L1 (mA)	2.66	4.62	51.64	28.09

Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-3000@Work in the grid to charge the battery mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (65.21 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	-591.91	-1529.81	-2297.64	-2875.19
DC inject current L1 (mA)	4.43	2.15	39.14	24.18


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection	P		
Model	AIO2-INS-5000@Working in battery discharge and grid connection mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (108.69 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	995.02	2472.89	3735.91	4121.71
DC inject current L1 (mA)	52.58	55.51	75.73	64.08


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-4600@Working in battery discharge and grid connection mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (100 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	924.79	2355.01	3398.75	4386.55
DC inject current L1 (mA)	42.92	57.48	64.58	67.38


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-3680@Working in battery discharge and grid connection mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (80 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	731.40	1813.47	2705.97	N/A
DC inject current L1 (mA)	32.08	40.25	43.79	N/A


Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.8	TABLE: Power quality - DC injection			P
Model	AIO2-INS-3000@Working in battery discharge and grid connection mode			
EN 50549-1 Limit:	0.5 % of I_{nom} (65.21 mA)			
Power level	20%	50%	75%	100%
Output power (VA)	635.82	1533.21	2216.34	N/A
DC inject current L1 (mA)	35.70	41.81	45.07	N/A

Note:



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.2		TABLE: Under-voltage protection				P
Model		AIO2-INS-5000				
Test condition:		Output level: 50 ± 5% of its rated current output Frequency: 50 Hz				
Phase	Adjustment thresholds ranges [V]	Actual thresholds setting [V]	Measured trip value [V]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
L1 Phase	0.80Un	184	183.80	2	2	1.984
L2 Phase			183.90			1.994
L3 Phase			183.90			1.975


Note:

The minimum required accuracy for protection is:

for frequency measurement ± 0,05 Hz;

for voltage measurement ± 1 % of U_n ;

The reset time shall be ≤ 50 ms.





EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.2		TABLE: Under-voltage protection – Adjustable setting					P
Model		AIO2-INS-5000					
Test condition:		Output level: 50 ± 5% of its rated current output Frequency: 50 Hz					
Phase	Adjustment thresholds ranges [V]	Actual thresholds setting [V]	Measured trip value [V]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]	
Single Phase	0.2-1.0U _n (stage 1)	0.80U _n =184.0	183.03	0.1-100	0.1	0.099	
		0.85U _n =195.5	194.53		10	9.908	
		0.90U _n =203.0	202.94		100	99.79	
	0.2-1.0U _n (stage 2)	0.20U _n =46.0	45.79	0.1-5	0.1	0.073	
		0.50U _n =115.0	114.38		1	0.985	
		0.80U _n =184	183.01		5	4.901	
Note: The minimum required accuracy for protection is: for frequency measurement ± 0,05 Hz; for voltage measurement ± 1 % of U _n ; The reset time shall be ≤ 50 ms.							



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------





EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.3	TABLE: Overvoltage protection					P
Model	AIO2-INS-5000					
Test condition:	Output level: 50 ± 5% of its rated current output Frequency: 50 Hz					
Phase	Adjustment thresholds ranges [V]	Actual thresholds setting [V]	Measured trip value [V]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
L1 Phase	1.1Un	253	253.40	2	2	1.975
L2 Phase		253	253.70		2	1.976
L3 Phase		253	253.30		2	1.980


Note:

The minimum required accuracy for protection is:

for frequency measurement ± 0,05 Hz;

for voltage measurement ± 1 % of U_n ;



The reset time shall be ≤ 50 ms.



EN 50549-1						
Clause	Requirement - Test			Result - Remark		Verdict
4.9.3.3	TABLE: Overvoltage protection – Adjustable setting					P
Model	AIO2-INS-5000					
Test condition:	Output level: 50 ± 5% of its rated current output Frequency: 50 Hz					
Phase	Adjustment thresholds ranges [V]	Actual thresholds setting [V]	Measured trip value [V]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
L1 Phase	1.0-1.2Un (stage 1)	1.10Un=253.0	252.53	0.1-100s	100	99.77
		1.15Un=264.5	263.23		10	9.810
		1.20Un=276.0	274.41		0.1	0.076
	1.0-1.3Un (stage 2)	1.20Un=276.0	274.68	0.1-5s	5	4.975
		1.25Un=287.5	285.24		1	0.998
		1.30Un=299.0	298.52		0.1	0.098
Note: The minimum required accuracy for protection is: for frequency measurement ± 0,05 Hz; for voltage measurement ± 1 % of Un; The reset time shall be ≤ 50 ms.						

EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Over voltage stage 1 – 276.0V 0.1s –Single Phase




Over voltage stage 2 – 276.0V 5.0s –Single Phase




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Over voltage stage 2 – 287.5V 1s –Single Phase



Over voltage stage 2 – 299.0V 0.1s –Single Phase




EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.4	TABLE: Overvoltage 10 min mean protection			P
Model	AIO2-INS-5000			
Parameter:	Test voltage:(V)	Disconnection time:(s)	Limit:	
Single Phase	253.01	604.4	10 min	
<p>Note:</p> <p>Over-voltage – stage 1 U_n (100% - 115 %): 10-min-value corresponding to EN 50160. The calculation of the 10 min value shall comply with the 10 min aggregation of EN 61000-4-30, class S. The function shall be based on the calculation of the square root of the arithmetic mean of the squared input values over 10 min. In deviation from EN 61000-4-30, a moving window shall be used. The calculation of a new 10-min value at least every 3 s is sufficient, which is then to be compared with the trip value.</p>				

EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.5	TABLE: Under-frequency protection					P
Model	AIO2-INS-5000					
Test condition:	Output level: 100 ± 5% of its rated current output					
Adjustment thresholds ranges [Hz]	Actual thresholds setting [Hz]	Test voltage [V]	Measured trip value [Hz]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
47.0-50.0Hz (Stage 1)	47.5	1.00U _n	47.50	2	2	1.967
	47.5	1.00U _n	47.50		2	1.970
	47.5	1.00U _n	47.50		2	1.974


Note:

In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal. The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n.

Under 0.2 U_n the frequency protection is inhibited. Disconnection may only happen base on under voltage protection.

* the limit actual stage 1 frequency limits and stage 2 frequency limits are required of the standard, the interface protection of the product maybe required by the DSO.

** the limit time is the upper limit and the under limits of the under-frequency protect are required of the standard, the interface protection of the product maybe required by the DSO.




EN 50549-1						
Clause	Requirement - Test			Result - Remark		Verdict
4.9.3.5	TABLE: Under-frequency protection – Adjustable setting					P
Model	AIO2-INS-5000					
Test condition:	Output level: 100 ± 5% of its rated current output					
Adjustment thresholds ranges [Hz]	Actual thresholds setting [Hz]	Test voltage [V]	Measured trip value [Hz]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
47.0-50.0Hz (Stage 1)	49.5	0.2U _n	49.30	0.1-100s	100	99.77
	48.5	1.0U _n	48.54		10	9.808
	47.5	1.2U _n	47.48		0.1	0.095
47.0-50.0Hz (Stage 2)	48.0	0.2U _n	47.50	0.1-5s	5	4.094
	47.5	1.0U _n	47.52		1	0.997
	47.0	1.2U _n	46.99		0.1	0.081
<p>Note:</p> <p>In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal. The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n.</p> <p>Under 0.2 U_n the frequency protection is inhibited. Disconnection may only happen base on under voltage protection.</p> <p>* the limit actual stage 1 frequency limits and stage 2 frequency limits are required of the standard, the interface protection of the product maybe required by the DSO.</p> <p>** the limit time is the upper limit and the under limits of the underfrequency protect are required of the standard, the interface protection of the product maybe required by the DSO.</p>						


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Under frequency stage 1 – 0.2Un 49.5Hz 100s




Under frequency stage 1 – 1.0Un 48.5Hz 10s




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Under frequency stage 1 – 1.2Un 47.5Hz 0.1s





Under frequency stage 2 – 0.2Un 48.0Hz 5.0s



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.6	TABLE: Over-frequency protection					P
Model	AIO2-INS-5000					
Test condition:	Output level: 50 ± 5% of its rated current output					
Adjustment thresholds ranges [Hz]	Actual thresholds setting [Hz]	Test voltage [V]	Measured trip value [Hz]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
50.0-52.0Hz (Stage 1)	51	1.00U _n	51.02	2	2	1.947
	51	1.00U _n	51.02		2	1.948
	51	1.00U _n	51.02		2	1.952


Note:

In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal. The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n.

Under 0.2 U_n the frequency protection is inhibited. Disconnection may only happen base on under voltage protection.

* the limit actual stage 1 frequency limits and stage 2 frequency limits are required of the standard, the interface protection of the product maybe required by the DSO.

** the limit time is the upper limit and the under limits of the underfrequency protect are required of the standard, the interface protection of the product maybe required by the DSO.



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.9.3.6	TABLE: Over-frequency protection – Adjustable setting					P
Model	AIO2-INS-5000					
Test condition:	Output level: 50 ± 5% of its rated current output					
Adjustment thresholds ranges [Hz]	Actual thresholds setting [Hz]	Test voltage [V]	Measured trip value [Hz]	Adjustment disconnection time range [s]	Actual disconnection time setting [s]	Measured disconnection time [s]
50.0-52.0Hz (Stage 1)	50.5	0.2U _n	50.54	0.1-100s	100	99.79
	51.0	1.0U _n	51.01		10	9.805
	51.5	1.2U _n	51.51		0.1	0.098
50.0-52.0Hz (Stage 2)	51.0	0.2U _n	51.04	0.1-5s	5	4.104
	51.5	1.0U _n	51.51		1	0.985
	52.0	1.2U _n	52.01		0.1	0.099

Note:

In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal. The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n.



Under 0.2 U_n the frequency protection is inhibited. Disconnection may only happen base on under voltage protection.

* the limit actual stage 1 frequency limits and stage 2 frequency limits are required of the standard, the interface protection of the product maybe required by the DSO.

** the limit time is the upper limit and the under limits of the underfrequency protect are required of the standard, the interface protection of the product maybe required by the DSO.

EN 50549-1


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Over frequency stage 1 – 1.2Un 51.5Hz 0.1s




Over frequency stage 2 – 0.2Un 51.0Hz 5.0s



EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



EN 50549-1									
Clause	Requirement - Test					Result - Remark			Verdict
4.9.4.2	Active methods tested with a resonant circuit in accordance with EN 62116 - test condition A (EUT output = 100%)								P
Model	AIO2-INS-5000								
Test conditions A									
Disconnection limit		2 s							
No	$P_{EUT}^{a)}$ (% of EUT rating)	Reactive load (% of Q_L in 6.1.d) 1)	$P_{ac}^{b)}$ (% of nominal)	$Q_{ac}^{c)}$ (% of nominal)	Run on Time (ms)	P_{EUT} (W per phase)	Actual Q_f	V_{DC}	Remarks ^{d)}
1	100	100	0	0	421	5000	1.00	406	Test A at BL
2	100	100	0	- 5	290	5000	0.97	406	Test A at IB
3	100	100	0	+ 5	148	5000	1.02	406	Test A at IB
4	100	100	- 5	- 5	212	5000	1.03	406	Test A at IB
5	100	100	- 5	0	285	5000	1.05	406	Test A at IB
6	100	100	- 5	+ 5	298	5000	1.08	406	Test A at IB
7	100	100	+ 5	- 5	204	5000	0.93	406	Test A at IB
8	100	100	+ 5	0	234	5000	0.95	406	Test A at IB
9	100	100	+ 5	+ 5	160	5000	0.98	406	Test A at IB
10	100	100	- 5	- 10	312	5000	1.00	406	Test A at IB
11	100	100	- 5	+ 10	103	5000	1.10	406	Test A at IB
12	100	100	0	- 10	316	5000	0.95	406	Test A at IB
13	100	100	0	+ 10	249	5000	1.05	406	Test A at IB
14	100	100	+ 5	- 10	228	5000	0.90	406	Test A at IB
15	100	100	+ 5	+ 10	166	5000	1.00	406	Test A at IB
16	100	100	- 10	- 10	287	5000	1.05	406	Test A at IB
17	100	100	- 10	- 5	328	5000	1.14	406	Test A at IB
18	100	100	- 10	0	129	5000	1.11	406	Test A at IB
19	100	100	- 10	+ 5	165	5000	1.14	406	Test A at IB
20	100	100	- 10	+10	223	5000	1.16	406	Test A at IB
21	100	100	+ 10	- 10	218	5000	0.86	406	Test A at IB
22	100	100	+ 10	- 5	376	5000	0.88	406	Test A at IB
23	100	100	+ 10	0	197	5000	0.91	406	Test A at IB
24	100	100	+ 10	+ 5	134	5000	0.93	406	Test A at IB
25	100	100	+ 10	+ 10	160	5000	0.95	406	Test A at IB

EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict


4.9.4.2	Active methods tested with a resonant circuit in accordance with EN 62116 - test condition B (EUT output = 50 % – 66 %)								P
Model	AIO2-INS-5000								
Test conditions B									
Disconnection limit			2.0 s						
No	$P_{EUT}^{a)}$ (% of EUT rating)	Reactive load (% of Q_L in 6.1.d) 1)	$P_{ac}^{b)}$ (% of nominal)	$Q_{ac}^{c)}$ (% of nominal)	Run on Time (ms)	P_{EUT} (W per phase)	Actual Q_f	V_{DC}	Remarks ^{d)}
1	66	66	0	- 5	160	3300	0.91	312	Test B at IB
2	66	66	0	- 4	185	3300	0.94	312	Test B at IB
3	66	66	0	- 3	207	3300	0.96	312	Test B at IB
4	66	66	0	- 2	213	3300	0.96	312	Test B at IB
5	66	66	0	- 1	214	3300	0.97	312	Test B at IB
6	66	66	0	0	216	3300	1.00	312	Test B at BL
7	66	66	0	+ 1	202	3300	1.00	312	Test B at IB
8	66	66	0	+ 2	190	3300	0.99	312	Test B at IB
9	66	66	0	+ 3	172	3300	0.96	312	Test B at IB
10	66	66	0	+ 4	150	3300	0.95	312	Test B at IB
11	66	66	0	+ 5	138	3300	0.95	312	Test B at IB

EN 50549-1									
Clause	Requirement - Test					Result - Remark			Verdict
4.9.4.2	Active methods tested with a resonant circuit in accordance with EN 62116 - test condition C (EUT output = 25 %-33 %)								P
Model	AIO2-INS-5000								
Test conditions C									
Disconnection limit			2.0 s						
No	$P_{EUT}^{a)}$ (% of EUT rating)	Reactive load (% of Q_L in 6.1.d) 1)	$P_{ac}^{b)}$ (% of nominal)	$Q_{ac}^{c)}$ (% of nominal)	Run on Time (ms)	P_{EUT} (W per phase)	Actual Q_f	V_{DC}	Remarks ^{d)}
1	33	33	0	- 5	140	1650	0.94	200	Test C at IB
2	33	33	0	- 4	148	1650	0.91	200	Test C at IB
3	33	33	0	- 3	154	1650	0.95	200	Test C at IB
4	33	33	0	- 2	119	1650	0.94	200	Test C at IB
5	33	33	0	- 1	104	1650	0.93	200	Test C at IB
6	33	33	0	0	192	1650	1.00	200	Test C at BL
7	33	33	0	+ 1	139	1650	0.93	200	Test C at IB
8	33	33	0	+ 2	192	1650	0.95	200	Test C at IB
9	33	33	0	+ 3	148	1650	0.99	200	Test C at IB
10	33	33	0	+ 4	143	1650	0.95	200	Test C at IB
11	33	33	0	+ 5	168	1650	0.98	200	Test C at IB
<p>Note:</p> <p>^{a)} P_{EUT}: EUT output power</p> <p>^{b)} P_{ac}: Active power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.</p> <p>^{c)} Q_{ac}: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.</p> <p>^{d)} BL: Balance condition, IB: Imbalance condition.</p>									


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Graph of disconnection at P AC 0% and Q AC 0% reactive load and 100% nominal power



Graph of disconnection at P AC 0% and Q AC 0% reactive load and 66% nominal power



EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict




EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.10.2	TABLE: Automatic reconnection after tripping			P
Model	AIO2-INS-5000			
Setting values	Parameter	Range	Default setting	
	Lower frequency [Hz]:	47.0 – 50.0	49.5	
	Upper frequency [Hz]:	50.0 – 50.2	50.2	
	Lower voltage [V]:	115.0 – 230.0	195.5	
	Upper voltage [V]:	230.0 – 276.0	253.0	
	Observation time [s]:	10 – 600	60	
	Active power increase gradient:	6% - 3000%/min	10%/min	
Connecting conditions for frequencies:				
	f_{act}	Reconnection time:	Limit:	
a)	< 49.50 Hz	Not reconnect	No reconnection permitted	
	Switch to:			
b)	≥ 49.50 Hz	60.67s	≥ 60 s(0~600s)	
c)	> 50.20 Hz	Not reconnect	No reconnection permitted	
	Switch to:			
d)	≤ 50.20 Hz	61.40s	≥ 60 s	
Connecting conditions for voltages:				
	U_{act}		Limit:	
e)	< 0.85 U_n	Not reconnect	No reconnection permitted	
	Switch to:			
f)	≥ 0.85 U_n	61.03s	≥ 60 s	
g)	> 1.10 U_n	Not reconnect	No reconnection permitted	
	Switch to:			
h)	≤ 1.10 U_n	62.83s	≥ 60 s	
	After reconnection:	Active power gradient [%]	9.80	≤ 10 %
Note: After reconnection the active power generated by the generating plant shall not exceed a specified gradient expressed as a percentage of the active nominal power of the unit per minute. If no gradient is specified by the DSO, the default setting is 10 % P _n /min. Non-adjustable or partly adjustable generating units may connect after 1 min to 10 min (randomised value) or later				


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Connecting conditions for frequencies: ≥ 49.50 Hz




Connecting conditions for frequencies: ≤ 50.20 Hz




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Connecting conditions for voltages: $\geq 0.85 U_n$



Connecting conditions for voltages: $\leq 1.10 U_n$




EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict
4.10.3	TABLE: Start of generating electrical power		P
Setting values	Parameter	Range	Default setting
	Lower frequency [Hz]:	47.0 - 50.0	49.5
	Upper frequency [Hz]:	50.0 - 50.2	50.1
	Lower voltage [V]:	115.0 - 230.0	195.5
	Upper voltage [V]:	230.0 - 276.0	253.0
	Observation time [s]:	10 - 600	60
	Active power increase gradient:	6% - 3000%/min	10%/min
Start conditions for frequencies:			
	f_{act}	Reconnection time:	Limit:
a)	< 49.50 Hz	No starting	No starting permitted
	Switch to:		
b)	≥ 49.50 Hz	61.17s	≥ 60 s
c)	> 50,10 Hz	No starting	No starting permitted
	Switch to:		
d)	$\leq 50,10$ Hz	60.97s	≥ 60 s
Start conditions for voltages:			
	U_{act}	Reconnection time:	Limit:
e)	< 0,85 U_n	No starting	No starting permitted
	Switch to:		
f)	$\geq 0,85$ U_n	62.00s	≥ 60 s
g)	> 1,10 U_n	No starting	No starting permitted
	Switch to:		
h)	$\leq 1,10$ U_n	61.72s	≥ 60 s
	After reconnection:	Active power gradient [%]	9.77
			≤ 10 %
<p>Note:</p> <p>If applicable, the power gradient shall not exceed the maximum gradient specified by the DSO and the responsible party.</p> <p>For manual operations performed on site (e.g. for the purpose of initial start-up or maintenance) it is permitted to deviate from the observation time and ramp rate.</p>			


EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Start conditions for frequencies: ≥ 49.50 Hz




Start conditions for frequencies: $\leq 50,10$ Hz




EN 50549-1

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Start conditions for voltages: $\geq 0,85 U_n$



Start conditions for voltages: $\leq 1,10 U_n$




EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.11.1	TABLE: Ceasing active power	P
---------------	------------------------------------	----------

Reducing the active power from 100% P _n to 0		
Measured max power [W]	Ceasing time [s]	Limit [s]
5007.90	1	5.0

Note:
 Generating plants with a maximum capacity of 0.8 kW or more shall be equipped with a logic interface (input port) in order to cease active power output within five seconds following an instruction being received at the input port. If required by the DSO and the responsible party, this includes remote operation.




EN 50549-1			
Clause	Requirement - Test	Result - Remark	Verdict

4.11.2	TABLE: Reduction of active power on set point	P
---------------	--	----------

Reducing the active power from 100% P _n to 0		
Actual gradient setting [%]	Measured during time [s]	Measured Gradient [%]
0.33% P _n / s - 0.66% P _n / s	201	0.49%P _n / s

Note:
 A generation unit/plant shall be capable of carrying out the power output reduction to the respective limit within an envelope of not faster than 0,66 % P_n/s and not slower than 0,33 % P_n/ s with an accuracy of 5 % of nominal power. Generating plants are permitted to disconnect from the network at a limit value below it minimum regulating level. If required by the DSO, this includes remote operation.

With a programmable AC source, the PGU is operated at 100% P_n and 50±0,01 Hz, set power factor equal to 1.



EN 50549-1							
Clause	Requirement - Test					Result - Remark	Verdict
4.13	Testing in single fault condition						P
	ambient temperature (°C)					25.0	-
No.	component No.	fault	test voltage (V)	test time	fuse No.	fuse current (A)	result
1	Grid Voltage detection (R1180)	Short Circuit	360Vdc 230Vac	10min	--	--	Unit shut down, error message: "Utility Grid Voltage Abnormal". No damage, no hazard, no fire.
2	Grid Voltage detection (R1180)	Open Circuit	360Vdc 230Vac	10min	--	--	Unit shut down, error message: "Utility Grid Voltage Abnormal". No damage, no hazard, no fire.
3	Grid Voltage detection (R1184)	Short Circuit	360Vdc 230Vac	10min	--	--	Unit shut down, error message: "Utility Grid Voltage Abnormal". No damage, no hazard, no fire.
4	Grid Voltage detection (R1184)	Open Circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Utility Grid Voltage Abnormal". No damage, no hazard, no fire.
5	Grid Voltage detection (C38)	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Utility Grid Voltage Abnormal". No damage, no hazard, no fire.
6	Grid Frequency detection (R34)	Open circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Utility Grid Frequency Abnormal". No damage, no hazard, no fire.
7	RCMU (R1046)	Open Circuit Before start up	360Vdc/ 230Vac	10min	--	--	Unit cannot start up, self-detection fail, error message: "Leakage current sensor fault" No damage, no hazard, no fire
8	RCMU (C75)	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Leakage current over fault". No damage, no hazard, no fire.
9	RCMU (R144)	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Leakage current over fault". No damage, no hazard, no fire.
10	Standalone Voltage detection (R1190)	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit work normally, no damage, no hazard, no fire.
11	Standalone Voltage detection (R1190)	Open circuit	360Vdc/ 230Vac	10min	--	--	Unit work normally, no damage, no hazard, no fire.


EN 50549-1							
Clause	Requirement - Test					Result - Remark	Verdict
12	EPS current (C78)	Short Circuit	360Vdc/230Vac	10min	--	--	Unit work normally, no damage, no hazard, no fire.
13	INV current detection (C72)	short	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Inverter current over trip". No damage, no hazard, no fire.
14	AC relay (K1004)	Short Circuit Before start up	360Vdc/230Vac	10min	--	--	Unit cannot start up, self-detection fail, error message: "Grid-Tied Relay fault". No damage, no hazard, no fire
15	AC relay (K1005)	Short Circuit Before start up	360Vdc/230Vac	10min	--	--	Unit cannot start up, self-detection fail, error message: "Grid-Tied Relay fault". No damage, no hazard, no fire
16	AC relay (K1006)	Short Circuit Before start up	360Vdc/230Vac	10min	--	--	Unit cannot start up, self-detection fail, error message: "Grid-Tied Relay fault". No damage, no hazard, no fire.
17	AC relay (K1007)	Short Circuit Before start up	360Vdc/230Vac	10min	--	--	Unit cannot start up, self-detection fail, error message: "Grid-Tied Relay fault". No damage, no hazard, no fire.
18	Insulation Relay (K1010)	Short Circuit Before start up	360Vdc/230Vac	10min	--	--	Unit cannot start up, self-detection fail. No damage, no hazard, no fire
19	Bus Capacitor (C1031)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, display dark module damaged, no hazard, no fire.
20	Transformer T900 (between +12 V and C904)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, display dark. No damage, no hazard, no fire.
21	Transformer T900 (between -12 V and C911)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, display dark. No damage, no hazard, no fire.
22	Transformer T900 (between +7 V and C907)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, display dark. No damage, no hazard, no fire.
23	Transformer T1004 (between +12 V and DC)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, display dark. No damage, no hazard, no fire.

EN 50549-1							
Clause	Requirement - Test					Result - Remark	Verdict
24	Transformer T1004 (between +12 V and DC)	overload	360Vdc/230Vac	10min	--	--	Unit shut down, display dark. No damage, no hazard, no fire.
25	Q708	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Battery voltage abnormal". No damage, no hazard, no fire.
26	Transformer T700 (between +15 V and DR2)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Battery voltage abnormal". No damage, no hazard, no fire.
27	Q700	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Battery voltage abnormal". No damage, no hazard, no fire.
28	Low voltage Bus Capacitor (C701)	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Battery voltage abnormal". No damage, no hazard, no fire.
29	Low voltage Bus Capacitor (C701)	Reversed	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Battery voltage abnormal". C701 damaged, no hazard, no fire
30	C19	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "DSP/ARM Communication fault". No damage, no hazard, no fire
31	C73	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "DSP/ARM Communication fault". No damage, no hazard, no fire.
32	R156	Open circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "Inner Communication error between MCU1 & MCU2". No damage, no hazard, no fire.
33	C154	Short circuit	360Vdc/230Vac	10min	--	--	Unit shut down, error message: "DSP/ARM Communication fault". No damage, no hazard, no fire.


EN 50549-1							
Clause	Requirement - Test					Result - Remark	Verdict
34	R168	Open circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "DC BUS over voltage". No damage, no hazard, no fire.
35	R176	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Battery voltage abnormal". No damage, no hazard, no fire.
36	R180	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Battery charge over current". No damage, no hazard, no fire.
37	L, N	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Inverter current over trip". No damage, no hazard, no fire.
38	L-Ground	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Inverter current over trip". No damage, no hazard, no fire.
39	N-Ground	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit work normally. No damage, no hazard, no fire.
40	Ground disconnect	Open circuit	360Vdc/ 230Vac	10min	--	--	Unit cannot start up, self-detection fail, error message: "Potential from Utility Grid N Line to PE is higher than 30 Vrms". No damage, no hazard, no fire.
41	Off grid L,N	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down, error message: "Battery charge over current". No damage, no hazard, no fire.
42	PV+ to PV-	Short circuit	360Vdc/ 230Vac	10min	--	--	Unit shut down. No damage, no hazard, no fire.
43	PV+ to PV-	Reversed	360Vdc/ 230Vac	10min	--	--	Unit cannot start up. No damage, no hazard, no fire.
supplementary information							
PCE means power conversion equipment under test in this document.							
See technical documentation.							

Appendix: Pictures

Front View



Rear View



Right Side View



Left Side View




Top Side View



Bottom Connect Terminals View




Light board - Component view




Light board - Soldering view




EPS board - Component view




EPS board - Soldering view




HVDC board - Component view




HVDC board - Soldering view




LVDC board - Component view




LVDC board - Soldering view




PBAC board - Component view




PBAC board - Soldering view




Control board - Component view




Control board - Soldering view




Capacitor Board – Component Side




Capacitor Board – Soldering view




Low Voltage Board (Battery Side) – Component Side



Low Voltage Board (Battery Side) – Solder Side



Internal view of inverter



--- End of test report---