

INSTALLATION GUIDE

EV charger wiring into Giv-Gateway

- The GivEnergy EV charger connects directly from 32A RCD to the grid busbar screw terminals highlighted below
- Ensure grid breaker is isolated before commencing work
- 6mm single or larger required from RCD to busbar
- 32A 30mA RCD Type A
- If using config C, power for EVC ID01 meter can be taken from load side of RCD
- 6mm supply to EV

