



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-WM112VAA
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	27/07/2020 - 26/07/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.74
36°C	4.67
37°C	4.59
38°C	4.51
39°C	4.43
40°C	4.36
41°C	4.28
42°C	4.2
43°C	4.13
44°C	4.05
45°C	3.97
46°C	3.91
47°C	3.84
48°C	3.78
49°C	3.72
50°C	3.66
51°C	3.59
52°C	3.53
53°C	3.47
54°C	3.4
55°C	3.34
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0