



|                               |                         |
|-------------------------------|-------------------------|
| Manufacturer:                 | Mitsubishi              |
| Certification Body:           | HP Keymark              |
| Model Number:                 | PUZ-WM112YAA-BS         |
| Technology:                   | Air Source Heat Pump    |
| Sub-Type:                     | Air-to-Water            |
| Certification Period:         | 27/07/2020 - 26/07/2030 |
| Current Certification Status: | Certified               |
| Scheme:                       | Keymark                 |

| Flow Temperature | SCOP |
|------------------|------|
| 35°C             | 4.7  |
| 36°C             | 4.62 |
| 37°C             | 4.55 |
| 38°C             | 4.47 |
| 39°C             | 4.39 |
| 40°C             | 4.32 |
| 41°C             | 4.24 |
| 42°C             | 4.17 |
| 43°C             | 4.09 |
| 44°C             | 4.01 |
| 45°C             | 3.94 |
| 46°C             | 3.88 |
| 47°C             | 3.81 |
| 48°C             | 3.75 |
| 49°C             | 3.69 |
| 50°C             | 3.62 |
| 51°C             | 3.56 |
| 52°C             | 3.5  |
| 53°C             | 3.43 |
| 54°C             | 3.37 |
| 55°C             | 3.31 |
| 56°C             | 0    |
| 57°C             | 0    |
| 58°C             | 0    |
| 59°C             | 0    |
| 60°C             | 0    |
| 61°C             | 0    |
| 62°C             | 0    |
| 63°C             | 0    |
| 64°C             | 0    |
| 65°C             | 0    |