



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-WM112YAA
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	27/07/2020 - 26/07/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.7
36°C	4.62
37°C	4.55
38°C	4.47
39°C	4.39
40°C	4.32
41°C	4.24
42°C	4.17
43°C	4.09
44°C	4.01
45°C	3.94
46°C	3.88
47°C	3.81
48°C	3.75
49°C	3.69
50°C	3.62
51°C	3.56
52°C	3.5
53°C	3.43
54°C	3.37
55°C	3.31
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0