

Ecodan Power Inverter 10/12/14-200E Packaged R290

Certification Number: 037-161-25-4



Manufacturer:	Mitsubishi Electric Air Conditioning Systems Europe LTD
Model Number:	PUZ-WZ120YAA(-BS)
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	25/02/2025 - 24/02/2035
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.71
36°C	4.65
37°C	4.58
38°C	4.52
39°C	4.46
40°C	4.4
41°C	4.33
42°C	4.27
43°C	4.21
44°C	4.15
45°C	4.08
46°C	4.03
47°C	3.97
48°C	3.91
49°C	3.85
50°C	3.8
51°C	3.74
52°C	3.68
53°C	3.62
54°C	3.57
55°C	3.51
56°C	3.44
57°C	3.37
58°C	3.29
59°C	3.22
60°C	3.15
61°C	3.08
62°C	3
63°C	2.93
64°C	2.86
65°C	2.79