

Ecodan Power Inverter 10/12/14-200E Packaged R290

Certification Number: 037-161-25-3



|                               |                                                         |
|-------------------------------|---------------------------------------------------------|
| Manufacturer:                 | Mitsubishi Electric Air Conditioning Systems Europe LTD |
| Model Number:                 | PUZ-WZ120VAA(-BS)                                       |
| Technology:                   | Air Source Heat Pump                                    |
| Sub-Type:                     | Air-to-Water                                            |
| Certification Period:         | 25/02/2025 - 24/02/2035                                 |
| Current Certification Status: | Certified                                               |
| Scheme:                       | Keymark                                                 |

| Flow Temperature | SCOP |
|------------------|------|
| 35°C             | 4.71 |
| 36°C             | 4.65 |
| 37°C             | 4.58 |
| 38°C             | 4.52 |
| 39°C             | 4.46 |
| 40°C             | 4.4  |
| 41°C             | 4.33 |
| 42°C             | 4.27 |
| 43°C             | 4.21 |
| 44°C             | 4.15 |
| 45°C             | 4.08 |
| 46°C             | 4.03 |
| 47°C             | 3.97 |
| 48°C             | 3.91 |
| 49°C             | 3.85 |
| 50°C             | 3.8  |
| 51°C             | 3.74 |
| 52°C             | 3.68 |
| 53°C             | 3.62 |
| 54°C             | 3.57 |
| 55°C             | 3.51 |
| 56°C             | 3.44 |
| 57°C             | 3.37 |
| 58°C             | 3.29 |
| 59°C             | 3.22 |
| 60°C             | 3.15 |
| 61°C             | 3.08 |
| 62°C             | 3    |
| 63°C             | 2.93 |
| 64°C             | 2.86 |
| 65°C             | 2.79 |