



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-HWM140VHA
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	27/07/2020 - 26/07/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.33
36°C	4.28
37°C	4.22
38°C	4.16
39°C	4.11
40°C	4.05
41°C	3.99
42°C	3.94
43°C	3.88
44°C	3.82
45°C	3.77
46°C	3.72
47°C	3.67
48°C	3.62
49°C	3.56
50°C	3.51
51°C	3.46
52°C	3.41
53°C	3.36
54°C	3.31
55°C	3.26
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0