



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-HWM140YHA-BS
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	27/07/2020 - 26/07/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.3
36°C	4.25
37°C	4.19
38°C	4.14
39°C	4.08
40°C	4.03
41°C	3.97
42°C	3.91
43°C	3.86
44°C	3.8
45°C	3.75
46°C	3.7
47°C	3.65
48°C	3.6
49°C	3.55
50°C	3.5
51°C	3.45
52°C	3.4
53°C	3.35
54°C	3.29
55°C	3.24
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0