



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-WM50VHA-BS
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	22/06/2020 - 21/06/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.62
36°C	4.55
37°C	4.48
38°C	4.41
39°C	4.34
40°C	4.27
41°C	4.2
42°C	4.13
43°C	4.06
44°C	4
45°C	3.93
46°C	3.86
47°C	3.79
48°C	3.72
49°C	3.65
50°C	3.58
51°C	3.51
52°C	3.45
53°C	3.38
54°C	3.31
55°C	3.24
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0