

Ecodan Power Inverter 5_6-200E Packaged R290

Certification Number: 037-0135-23-4



Manufacturer:	Mitsubishi Electric Air Conditioning Systems Europe LTD
Model Number:	PUZ-WZ60VAA(-BS)
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	31/08/2023 - 30/08/2033
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.39
36°C	4.34
37°C	4.29
38°C	4.24
39°C	4.19
40°C	4.14
41°C	4.09
42°C	4.04
43°C	4
44°C	3.95
45°C	3.9
46°C	3.85
47°C	3.8
48°C	3.76
49°C	3.71
50°C	3.66
51°C	3.61
52°C	3.57
53°C	3.52
54°C	3.47
55°C	3.43
56°C	3.36
57°C	3.3
58°C	3.23
59°C	3.17
60°C	3.11
61°C	3.04
62°C	2.98
63°C	2.91
64°C	2.85
65°C	2.79