



|                               |                         |
|-------------------------------|-------------------------|
| Manufacturer:                 | Mitsubishi              |
| Certification Body:           | HP Keymark              |
| Model Number:                 | PUZ-WM60VAA-BS          |
| Technology:                   | Air Source Heat Pump    |
| Sub-Type:                     | Air-to-Water            |
| Certification Period:         | 22/06/2020 - 21/06/2030 |
| Current Certification Status: | Certified               |
| Scheme:                       | Keymark                 |

| Flow Temperature | SCOP |
|------------------|------|
| 35°C             | 4.81 |
| 36°C             | 4.73 |
| 37°C             | 4.66 |
| 38°C             | 4.59 |
| 39°C             | 4.51 |
| 40°C             | 4.44 |
| 41°C             | 4.37 |
| 42°C             | 4.29 |
| 43°C             | 4.22 |
| 44°C             | 4.14 |
| 45°C             | 4.07 |
| 46°C             | 4.02 |
| 47°C             | 3.97 |
| 48°C             | 3.92 |
| 49°C             | 3.87 |
| 50°C             | 3.82 |
| 51°C             | 3.77 |
| 52°C             | 3.72 |
| 53°C             | 3.67 |
| 54°C             | 3.62 |
| 55°C             | 3.57 |
| 56°C             | 0    |
| 57°C             | 0    |
| 58°C             | 0    |
| 59°C             | 0    |
| 60°C             | 0    |
| 61°C             | 0    |
| 62°C             | 0    |
| 63°C             | 0    |
| 64°C             | 0    |
| 65°C             | 0    |