



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-WM60VAA
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	22/06/2020 - 21/06/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.81
36°C	4.73
37°C	4.66
38°C	4.59
39°C	4.51
40°C	4.44
41°C	4.37
42°C	4.29
43°C	4.22
44°C	4.14
45°C	4.07
46°C	4.02
47°C	3.97
48°C	3.92
49°C	3.87
50°C	3.82
51°C	3.77
52°C	3.72
53°C	3.67
54°C	3.62
55°C	3.57
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0