

Ecodan Power Inverter 8.5/9/11.5-200E Packaged R290

Certification Number: 037-0159-25-2



|                               |                                                         |
|-------------------------------|---------------------------------------------------------|
| Manufacturer:                 | Mitsubishi Electric Air Conditioning Systems Europe LTD |
| Model Number:                 | PUZ-WZ85YAA(-BS)                                        |
| Technology:                   | Air Source Heat Pump                                    |
| Sub-Type:                     | Air-to-Water                                            |
| Certification Period:         | 25/02/2025 - 24/02/2035                                 |
| Current Certification Status: | Certified                                               |
| Scheme:                       | Keymark                                                 |

| Flow Temperature | SCOP |
|------------------|------|
| 35°C             | 4.47 |
| 36°C             | 4.41 |
| 37°C             | 4.36 |
| 38°C             | 4.31 |
| 39°C             | 4.26 |
| 40°C             | 4.21 |
| 41°C             | 4.16 |
| 42°C             | 4.11 |
| 43°C             | 4.06 |
| 44°C             | 4.01 |
| 45°C             | 3.96 |
| 46°C             | 3.91 |
| 47°C             | 3.87 |
| 48°C             | 3.82 |
| 49°C             | 3.78 |
| 50°C             | 3.73 |
| 51°C             | 3.69 |
| 52°C             | 3.65 |
| 53°C             | 3.6  |
| 54°C             | 3.56 |
| 55°C             | 3.51 |
| 56°C             | 3.45 |
| 57°C             | 3.38 |
| 58°C             | 3.32 |
| 59°C             | 3.25 |
| 60°C             | 3.19 |
| 61°C             | 3.12 |
| 62°C             | 3.06 |
| 63°C             | 2.99 |
| 64°C             | 2.93 |
| 65°C             | 2.86 |