



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-WM85YAA-BS
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	22/06/2020 - 21/06/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.81
36°C	4.74
37°C	4.67
38°C	4.6
39°C	4.54
40°C	4.47
41°C	4.4
42°C	4.33
43°C	4.26
44°C	4.19
45°C	4.12
46°C	4.05
47°C	3.99
48°C	3.92
49°C	3.85
50°C	3.79
51°C	3.72
52°C	3.66
53°C	3.59
54°C	3.53
55°C	3.46
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0