



Manufacturer:	Mitsubishi
Certification Body:	HP Keymark
Model Number:	PUZ-WM85VAA-BS
Technology:	Air Source Heat Pump
Sub-Type:	Air-to-Water
Certification Period:	22/06/2020 - 21/06/2030
Current Certification Status:	Certified
Scheme:	Keymark

Flow Temperature	SCOP
35°C	4.84
36°C	4.77
37°C	4.7
38°C	4.63
39°C	4.56
40°C	4.49
41°C	4.42
42°C	4.35
43°C	4.28
44°C	4.21
45°C	4.14
46°C	4.07
47°C	4.01
48°C	3.94
49°C	3.88
50°C	3.81
51°C	3.74
52°C	3.68
53°C	3.61
54°C	3.55
55°C	3.48
56°C	0
57°C	0
58°C	0
59°C	0
60°C	0
61°C	0
62°C	0
63°C	0
64°C	0
65°C	0