

EU Type Examination Certificate Number: 0120/ SGS0103/R1

EM-Lite Limited

1 Stevern Way Peterborough Cambridgeshire PE1 5EL

Instrument Identification:

ECA2.* Single Phase, Active Import/ Export, Electricity Meter Instrument Traceable Number 0120/SGS0103

has been assessed and certified as meeting the requirements of

EU Directive 20 4/32/E

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

> This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 22nd March 2030

Issue 3

Certification is based on report number(s) EMA157563/1 dated 18th June 2012 EMA277439/1 dated 18th March 2020

Authorised Signature

Mikko Välimäki

SGS Fimko OY, Notified Body 0598 Takomotie 8, FI-00380 Helsinki, Finland t+358 9 6963 61 www.sqs.fi



EU Type Examination Cert.

Page 1 of 7



0120/SGS0103/R1

Issue Number: 3

Dated: 01st December 2022

1. Technical Data

Manufacturer	EM-Lite Ltd
Meter Type	ECA2.*
Voltage Rating (Un)	220V – 240V
Current Rating (Imin – Iref (Imax))	0,25-5(100) 0,5-10(100) 0,75-15(100) 1-20(100)
Frequency (Fn)	
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Firmware Version No's	V1.01-5 Checksum 50787 V1.01-6 Checksum 50814 V1.01-7 Checksum 10446 V1.01-8 Checksum 26153 V1.01-9 Checksum 42819 V1.02-0 Checksum 27098
Identification Location	
Bill Of Materials No's	ECA2.z & ECA2.nz ECA2-4001- 02 REV A, ECA2-4001-03 REV A ECA2-4001-03 REV B, ECA2-4001-04 REV A ECA2-4001-05 REV A, ECA2-4001-06 REV A ECA2.v & ECA.nv ECA2-4002-02 REV A, ECA2-4002-03 REV A ECA2-4002-03 REV B, ECA2-4002-04 REV A ECA2-4002-5 REV A, ECA2-4002-06 REV A
IP Rating	acconservation of second secon
Insulation Protective Class	
LED Pulse Constant	Australisation of the second s
Impulse Voltage Rating	
AC Voltage Rating	4kV
Terminal Cover Sealing Type	Wire & Crimp
Main Cover Sealing Type	Press Fit Non-removable Lasered Plastic Seals
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	BS
Location of Manufacturers Address	Nameplate



0120/SGS0103/R1

Issue Number: 3

Dated: 01st December 2022

2. Photograph of Meter and Sealing Plan





3. Examples of Nameplates





0120/SGS0103/R1

Issue Number: 3

Dated: 01st December 2022

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

δ e (*T*, *U*, *f*) = √ (δ e² (*T*, *I*, cosφ), δ e² (*U*, *I*, cosφ), δ e² (*f*, *I*, cosφ))

where

$\delta e(T, I, \cos \varphi)$	=	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos \varphi)$	=	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos \phi)$	=	Additional error due to variation of the frequency at the same load

second and a second sec									
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
Imin	1.0	1.04	1.18	1.00	0.66	0.08	0.24	0.84	0.58
ltr	1.0	1.31	1.22	0.95	0.64	0.10	0.19	0.64	0.86
10ltr	1.0	1.02	0.79	0.52	0.30	0.17	0.35	0.62	0.82
Imax	1.0	0.91	0.27	0.15	0.20	0.52	0.68	0.95	0.72
ltr	0.5ind	0.88	1.25	0.99	0.63	0.12	0.26	0.75	0.89
10ltr	0.5ind	1.06	0.72	0.41	0.20	0.32	0.44	0.71	0.82
Imax	0.5ind	0.90	0.32	0.52	0.71	1.07	1.24	1.49	0.76
ltr	0.8cap	1.03	1.17	0.90	0.57	0.20	0.39	0.80	1.13
10ltr	0.8cap	1.06	0.77	0.48	0.27	0.20	0.39	0.63	0.94
Imax	0.8cap	0.94	0.16	0.13	0.29	0.66	0.83	1.09	0.87





5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter		
ECA2.z	4 terminal basic variant, no auxiliary connections		
ECA2.v	4 terminal with electronic pulsed output variant		
ECA2.nz	4 terminal basic variant, no auxiliary connections, including Net Register		
ECA2.nv	4 terminal with electronic pulsed output variant, including Net Register		

Modifications to the meter(s) described according to approval No.0120/SGS0103 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).





0120/SGS0103/R1

Issue Number: 3

Dated: 01st December 2022

6. Document Revision History

Issue	Date	Comments
1	23/03/2020	Initial Issue
2	26/05/2022	Issue 1 for SGS Fimko NB 0598 The original approval certificate issued 23/03/2022 Additional BoM versions ECA2-4001-03 REV B, ECA2-4001-04 REV A & ECA2-4002-03 REV B, ECA2-4002-04 REV A. New software version V1.01-8
3	01/12/2022	New software versions V1.01-9 & V1.02-0



This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE